

**Attachment Q.2 –
Acceptable Low-Lead End-Use
Plumbing Components**

**Seattle Public Schools
Drinking Water Quality Improvement Program**

**Approved End-Use Plumbing Components List
10/9/2006**

The following is the list of end-use plumbing components for all drinking water locations that meet SPS requirements for drinking water quality. End-use plumbing components are those components starting with the stop valve at the lateral up to and including the bubbler head or faucet.

Component	Type / Model	Comments
Stop valve	DAHL mini ball valve stop	Rinse clean before installation.
Flexible connector tubing	Polyethylene / PolyFLEX 50 or equal	
Fittings for flexible tubing (tees, elbows, connectors)	Polypropylene / Parflex or equal	
Rigid connector pipe and fittings	PVC Schedule 80	
Nipple	Stainless steel	Rinse clean before installation.
Bubbler	Halsey Taylor Model #3041 and Model # 2507	Pre-condition bubbler per SPS standard procedure prior to installation. One model is for hallway bubblers and the other for deck-mount in classroom sinks.
Sink faucet	Moen Model #7425	Pre-condition faucet per SPS standard procedure prior to installation.

