

Seattle Public Schools
Drinking Water Quality Program

Summary Status
for
ALKI ELEMENTARY SCHOOL

Updated January 15, 2008

Status:

All sources meet the criteria except:

Signs will be posted: Office sink (#27)

The school will be flushed after any break longer than five days.

Follow-up monitoring: Will be performed in 2010.