

Seattle Public Schools
Drinking Water Quality Program

**Summary Status
for
Bagley Elementary**

Updated August 27, 2007

Status:

All sources meet the policy except:

A sign will be posted at room 104 (#23).

The school will be flushed after any breaks longer than five days.

Follow-up monitoring: Will be performed in 2010.