

**Seattle Public Schools  
Drinking Water Quality Program**

**Summary Status  
for  
Ballard High School**

Dated April 29, 2009

Status:

All sources meet the policy criteria, except:

Sign will be posted:

Kitchen, double faucets sink – left (#56).

Drinking fountain at 233 gym (#21) need to be tested. Will be disabled till finish the testing.

The school will be flushed after any breaks longer than five days.

Follow-up monitoring: Will be performed in 2009.