

Seattle Public Schools
Drinking Water Quality Program

Results of Water Quality Testing
for
B.F. Day Elementary School

Updated January 08, 2008

General Information:

Plumbing piping materials: mainly copper

Remediation plan:

This remediation plan is based on a Water Quality policy approved by the School Board. The policy includes standards for the presence of lead, cadmium, copper, iron and other substances in drinking water.

Status:

Policy Criteria:

All sources meet the policy criteria.

All bottled water will be removed from the school.

Follow-up monitoring: Will be performed in 2010.

Service: The school will be flushed after any breaks longer than five days.

Water Quality Testing Results:

Legend	
Symbol	Definition
SE	service entry (main)
B	bubbler
S	sink (faucet)
B/S	sink/bubbler combination
S/B	sink/bubbler combination
ppb	parts per billion
ppm	parts per million
NA	not applicable
None	no action required
Unk	unknown status or action
Sample	sample needs to be taken
Re-test	fixture needs to be resampled
Conf	resample to confirm measurement
No flush	not flushed before sampling
Sink	sampled faucet of S/B combo
Used	recently used; no 1st draw sample possible
PS	post sign
Disable(d)	fixture disabled in response to water quality testing
IF	install filter
RB	replace bubbler
RB/IF	replace bubbler and/or install filter
RF	replace faucet
RF/IF	replace faucet and/or install filter
BW	disable fixture and provide bottled water until remediated
Leaks	leaking fixture
NW	not working properly (sample S when B of S/B NW)
OS	out of service - disabled until fixed
RS	return to service - now passes testing
Rem	Removed from system - no longer exists

Table 1. Summary of Results

CURRENT STATUS											
FIXTURE INFORMATION			LEAD		CADMIUM		COPPER		IRON		OK?
Fixture ID	Type	Location	Pass/Fail	Status	Pass/Fail	Status	Pass/Fail	Status	Pass/Fail	Status	Yes/No/Status
01	B	Hall - south 1st floor	P	None	P	None	P	None	P	None	Yes
02	B/S	room 100, after school daycare	P	None	P	None	P	None	P	None	Yes
03	B/S	room 101, special education	P	None	P	None	P	None	P	None	Yes
04	B/S	room 102, 1st grade	P	None	P	None	P	None	P	None	Yes
05	B/S	room 103, 1st grade	P	None	P	None	P	None	P	None	Yes
06	B/S	room 104, music classroom	P	None	P	None	P	None	P	None	Yes
07	B/S	room 105, math coach	P	None	P	None	P	None	P	None	Yes
08	B/S	room 202, kindergarten	P	None	P	None	P	None	P	None	Yes
09	B	hall north 2nd floor	P	None	P	None	P	None	P	None	Yes
10	S	room 203, kindergarten	P	None	P	None	P	None	P	None	Yes
11	B/S	room 205, 2nd grade	P	None	P	None	P	None	P	None	Yes
12	B/S	room 206, 2nd grade	P	None	P	None	P	None	P	None	Yes
13	B/S	room 207, computer lab	P	None	P	None	P	None	P	None	Yes
14	B/S	room 310, 4th grade	P	None	P	None	P	None	P	None	Yes
15	B/S	room 311, Art classroom	P	None	P	None	P	None	P	None	Yes
17	B/S	room 300, 3rd and 4th grade	P	None	P	None	P	None	P	None	Yes
18	B/S	room 301, bilingual	P	None	P	None	P	None	P	None	Yes
19	B/S	room 304, 3rd grade	P	None	P	None	P	None	P	None	Yes
20	B/S	room 305, 4/5 th grade	P	None	P	None	P	None	P	None	Yes
21	B/S	room 306, 5th grade	P	None	P	None	P	None	P	None	Yes
22	B/S	room 307, empty	P	None	P	None	P	None	P	None	Yes
23	B	day care	P	None	P	None	P	None	P	None	Yes
24	B/S	library - staff	P	None	P	None	P	None	P	None	Yes
34	S	day care kitchen	P	None	P	None	P	None	P	None	Yes
35	S	kitchen (south east)	P	None	P	None	P	None	P	None	Yes
36	S	kitchen (east, left fixture)	P	None	P	None	P	None	P	None	Yes
36A	S	kitchen (east, right fixture)	P	None	P	None	P	None	P	None	Yes
37	S	nurses	P	None	P	None	P	None	P	None	Yes
38	S	staff office	P	None	P	None	P	None	P	None	Yes
39	S	staff lounge	P	None	P	None	P	None	P	None	Yes
40	S	custodial sink, room 302	P	None	P	None	P	None	P	None	Yes
41	S	resource room	P	None	P	None	P	None	n/a	None	Yes
42	S	resource room	P	None	P	None	P	None	n/a	None	Yes
43	S	kitchen handwash	P	None	P	None	P	None	n/a	None	Yes
44	Sp	kitchen spray	P	None	P	None	P	None	n/a	None	Yes
45	S	daycare	P	None	P	None	P	None	n/a	None	Yes

Table 2. Lead Test Results

FIXTURE INFORMATION			Initial Sampling				Follow-up Sampling 1				Follow-up Sampling 2				Follow-up Sampling 3				Follow-up Sampling 4				Follow-up Sampling 5				
Fixture ID	Type	Location	Sampled	1st Draw	Flush 30s	Pass /Fail	Sampled	1st Draw	Flush 30s	Pass /Fail	Sampled	1st Draw	Flush 30s	Pass /Fail	Sampled	1st Draw	Flush 30s	Pass /Fail	Sampled	1st Draw	Flush 30s	Pass /Fail	Sampled	1st Draw	Flush 30s	Pass /Fail	
01	B	Hall - south 1st floor	4/30/04	19	24		4/4/05	500	6		7/15/05	2	<1	P	10/12/05	4	<1	P									
02	B/S	room 100, after school daycare	4/30/04	8	5	P													1/24/06	5	8	P	1/25/06	5	7	P	
03	B/S	room 101, special education	4/30/04	34	12		4/4/05	4	3	P																	
04	B/S	room 102, 1st grade	4/30/04	44	4		4/4/05	4	1	P																	
05	B/S	room 103, 1st grade	4/30/04	9	4	P																					
06	B/S	room 104, music classroom	4/30/04	5	2	P													1/24/06	2	<1	P	1/25/06	<1	2	P	
07	B/S	room 105, math coach	4/30/04	16	1		4/4/05	2	3	P																	
08	B/S	room 202, kindergarten	4/30/04	4	<1	P																					
09	B	hall north 2nd floor	4/30/04	58	26		4/4/05	96	16		7/15/05	3	6	P	10/12/05	20	11										
10	S	room 203, kindergarten	4/30/04	14	28		4/4/05	8	3	P																	
11	B/S	room 205, 2nd grade	4/30/04	13	2		4/4/05	19	6		7/15/05	21	2		10/12/05	2	<1	P									
12	B/S	room 206, 2nd grade	4/30/04	7	3	P																					
13	B/S	room 207, computer lab	4/30/04	7	2	P																					
14	B/S	room 310, 4th grade	4/30/04	5	2	P																					
15	B/S	room 311, Art classroom	4/30/04	11	2		4/4/05	2	2	P																	
17	B/S	room 300, 3rd and 4th grade	4/30/04	8	7	P																					
18	B/S	room 301, bilingual	4/30/04	40	13		4/4/05	27	4		7/15/05	22	7		10/12/05	15	11										
19	B/S	room 304, 3rd grade	4/30/04	14	2		4/4/05	6	<1	P	7/15/05			P													
20	B/S	room 305, 4/5 th grade	4/30/04	8	2	P													1/24/06	3	<1	P	1/25/06	2	<1	P	
21	B/S	room 306, 5th grade	4/30/04	8	2	P																					
22	B/S	room 307, empty	4/30/04	59	2		4/4/05	2	1	P																	
23	B	day care	4/30/04	3	1	P																					
24	B/S	library - staff	4/30/04	25	11		4/4/05	5	<1	P																	
34	S	day care kitchen	4/30/04	2	<1	P																					
35	S	kitchen (south east)	4/30/04	4	2	P																					
36	S	kitchen (east, left fixture)	4/30/04	8	1	P																					
36A	S	kitchen (east, right fixture)																									
37	S	nurses	4/30/04	1	<1	P																					
38	S	staff office	4/30/04	5	17		4/4/05	26	2		7/15/05																
39	S	staff lounge	4/30/04	4	1	P																					
40	S	custodial sink, room 302	4/30/04		1	P					7/15/05	2		P													
41	S	resource room																									
42	S	resource room																									
43	S	kitchen handwash																									
44	Sp	kitchen spray																									
45	S	daycare																									

Table 2. Lead Test Results (continued)

FIXTURE INFORMATION			Follow-up Sampling 6				Follow-up Sampling 7				Follow-up Sampling 8				Follow-up Sampling 9				Follow-up Sampling 10				Summary Status	
Fixture ID	Type	Location	Sampled	1st Draw	Flush 30s	Pass /Fail	Sampled	1st Draw	Flush 30s	Pass /Fail	Sampled	1st Draw	Flush 30s	Pass /Fail	Sampled	1st Draw	Flush 30s	Pass /Fail	Sampled	1st Draw	Flush 30s	Pass /Fail	Pass/Fail	Status
01	B	Hall - south 1st floor																	11/30/2007	<1	<1	P	P	None
02	B/S	room 100, after school daycare	1/26/2006	1	<1	P	1/27/2006	<1	<1	P									11/30/2007	<1	<1	P	P	None
03	B/S	room 101, special education																	11/30/2007	<1	<1	P	P	None
04	B/S	room 102, 1st grade																	11/30/2007	<1	<1	P	P	None
05	B/S	room 103, 1st grade																	11/30/2007	2	1	P	P	None
06	B/S	room 104, music classroom	1/26/2006	2	2	P	1/27/2006	2	2	P									11/30/2007	3	<1	P	P	None
07	B/S	room 105, math coach																	11/30/2007	<1	<1	P	P	None
08	B/S	room 202, kindergarten																	11/30/2007	2	<1	P	P	None
09	B	hall north 2nd floor																	11/30/2007	3	6	P	P	None
10	S	room 203, kindergarten																	11/30/2007	1	2	P	P	None
11	B/S	room 205, 2nd grade																	11/30/2007	<1	<1	P	P	None
12	B/S	room 206, 2nd grade																	11/30/2007	3	<1	P	P	None
13	B/S	room 207, computer lab																	11/30/2007	5	2	P	P	None
14	B/S	room 310, 4th grade																	11/30/2007	3	<1	P	P	None
15	B/S	room 311, Art classroom																	11/30/2007	<1	<1	P	P	None
17	B/S	room 300, 3rd and 4th grade																	11/30/2007	3	<1	P	P	None
18	B/S	room 301, bilingual									5/5/2006	2	3	P					11/30/2007	2	<1	P	P	None
19	B/S	room 304, 3rd grade																	11/30/2007	<1	<1	P	P	None
20	B/S	room 305, 4/5 th grade	1/26/2006	2	2	P	1/27/2006	1	2	P									11/30/2007	2	<1	P	P	None
21	B/S	room 306, 5th grade																	11/30/2007	2	<1	P	P	None
22	B/S	room 307, empty																	11/30/2007	<1	<1	P	P	None
23	B	day care																	11/30/2007	3	<1	P	P	None
24	B/S	library - staff																	11/30/2007	<1	<1	P	P	None
34	S	day care kitchen																	11/30/2007	<1	<1	P	P	None
35	S	kitchen (south east)																	11/30/2007	2	<1	P	P	None
36	S	kitchen (east, left fixture)																	11/30/2007	1	<1	P	P	None
36A	S	kitchen (east, right fixture)									5/5/2006	2	<1	P					11/30/2007	3	<1	P	P	None
37	S	nurses																	11/30/2007	2	<1	P	P	None
38	S	staff office									5/5/2006	2	<1	P					11/30/2007	4	<1	P	P	None
39	S	staff lounge													5/26/2006	8	<1	P	11/30/2007	5	<1	P	P	None
40	S	custodial sink, room 302																	11/30/2007	<1	<1	P	P	None
41	S	resource room																	11/30/2007	<1	<1	P	P	None
42	S	resource room																	11/30/2007	4	<1	P	P	None
43	S	kitchen handwash																	11/30/2007	8	<1	P	P	None
44	Sp	kitchen spray																	11/30/2007	3	<1	P	P	None
45	S	daycare																	11/30/2007	<1	<1	P	P	None

Table 3. Cadmium Test Results

Test Results (Cadmium/Cd, ppb)																													
FIXTURE INFORMATION			Initial Sampling				Follow-up Sampling 1				Follow-up Sampling 2				Follow-up Sampling 3				Follow-up Sampling 4				Follow-up Sampling 5				Summary Status		
Fixture ID	Type	Location	Sampled	1st Draw	Flush 30s	Pass/Fail	Sampled	1st Draw	Flush 30s	Pass/Fail	Sampled	1st Draw	Flush 30s	Pass/Fail	Sampled	1st Draw	Flush 30s	Pass/Fail	Sampled	1st Draw	Flush 30s	Pass/Fail	Sampled	1st Draw	Flush 30s	Pass/Fail	Pass/Fail	Status	
01	B	Hall - south 1st floor room 100,					7/15/05	<1	<1	P	10/12/05	<1	<1	P															
02	B/S	after school daycare room 101, special education					7/15/05	<1	<1	P																			
03	B/S	Room 102, 1st grade					7/15/05	<1	<1	P																			
04	B/S	Room 103, 1st grade					7/15/05	<1	<1	P																			
05	B/S	Room 104, music classroom					7/15/05	<1	<1	P																			
06	B/S	room 105, math coach					7/15/05	<1	<1	P																			
07	B/S	room 202, kindergarten					7/15/05	<1	<1	P																			
08	B	hall north 2nd floor					7/15/05	<1	<1	P	10/12/05	<1	<1	P															
09	S	Room 203, kindergarten					7/15/05	<1	<1	P																			
10	B/S	Room 205, 2nd grade					7/15/05	<1	<1	P	10/12/05	<1	<1	P															
11	B/S	Room 206, 2nd grade					7/15/05	<1	<1	P																			
12	B/S	room 207, computer lab					7/15/05	<1	<1	P																			
13	B/S	Room 310, 4th grade					7/15/05	<1	<1	P																			
14	B/S	room 311, Art classroom					7/15/05	<1	<1	P																			
15	B/S	room 300, 3rd and 4th grade					7/15/05	<1	<1	P																			
17	B/S	room 301, bilingual					7/15/05	<1	<1	P	10/12/05	<1	<1	P															
18	B/S	Room 304, 3rd grade	4/30/04	<1	<1	P																							
19	B/S	room 305, 4/5 th grade					7/15/05	<1	<1	P																			
20	B/S	Room 306, 5th grade					7/15/05	<1	<1	P																			
21	B/S	room 307, empty	4/30/04	<1		P	7/15/05		<1	P																			
22	B	day care	4/30/04	<1	<1	P																							
23	B/S	library - staff	4/30/04	<1	<1	P																							
24	S	Day care kitchen	4/30/04	<1	<1	P																							
25	S	kitchen (south east)	4/30/04	<1	<1	P																							
26	S	kitchen (east, left fixture)	4/30/04	<1	<1	P																							
27	S	kitchen (east, right fixture)													5/5/06	<1	<1	P											
28	S	nurses	4/30/04	<1	<1	P																							
29	S	staff office	4/30/04	2	<1	P																							
30	S	staff lounge	4/30/04	<1	<1	P																5/26/06	<1	<1	P				
31	S	custodial sink, room 302	4/30/04		1	P	7/15/05	<1		P																			
32	S	resource room																											
33	S	resource room																											
34	S	kitchen handwash																											
35	Sp	kitchen spray																											
36	S	daycare																											

Table 4. Copper Test Results

FIXTURE INFORMATION			Initial Sampling				Follow-up Sampling 1				Follow-up Sampling 2				Follow-up Sampling 3				Follow-up Sampling 4				Summary Status	
Fixture ID	Type	Location	Sampled	1st Draw	Flush 2m	Pass /Fail	Sampled	1st Draw	Flush 30s	Pass /Fail	Sampled	1st Draw	Flush 30s	Pass /Fail	Sampled	1st Draw	Flush 30s	Pass /Fail	Sampled	1st Draw	Flush 30s	Pass /Fail	Pass/Fail	Status
01	B	Hall - south 1st floor					7/15/2005	0.016	0.046	P	10/12/2005	0.776	1.04	P					11/30/2007	0.38	0.39	P	P	None
02	B/S	room 100, after school daycare					7/15/2005	1	1.4										11/30/2007	0.028	0.058	P	P	None
03	B/S	room 101, special education					7/15/2005	0.73	0.98	P									11/30/2007	0.033	0.029	P	P	None
04	B/S	room 102, 1st grade					7/15/2005	0.88	1	P									11/30/2007	0.323	0.292	P	P	None
05	B/S	room 103, 1st grade					7/15/2005	0.64	0.93	P									11/30/2007	0.312	0.227	P	P	None
06	B/S	room 104, music classroom					7/15/2005	0.71	1	P									11/30/2007	0.44	0.344	P	P	None
07	B/S	room 105, math coach					7/15/2005	0.74	1	P									11/30/2007	0.36	0.176	P	P	None
08	B/S	room 202, kindergarten					7/15/2005	0.8	0.7	P									11/30/2007	0.283	0.151	P	P	None
09	B	hall north 2nd floor					7/15/2005	0.014	0.069	P	10/12/2005	0.768	0.57	P					11/30/2007	0.3	0.232	P	P	None
10	S	room 203, kindergarten					7/15/2005	0.7	0.48	P									11/30/2007	0.294	0.143	P	P	None
11	B/S	room 205, 2nd grade					7/15/2005	0.051	0.086	P	10/12/2005	0.584	0.33	P					11/30/2007	0.302	0.162	P	P	None
12	B/S	room 206, 2nd grade					7/15/2005	0.55	0.76	P									11/30/2007	0.326	0.198	P	P	None
13	B/S	room 207, computer lab					7/15/2005	0.67	0.79	P									11/30/2007	0.266	0.192	P	P	None
14	B/S	room 310, 4th grade					7/15/2005	0.35	0.14	P									11/30/2007	0.355	0.16	P	P	None
15	B/S	room 311, Art classroom					7/15/2005	0.54	0.86	P									11/30/2007	0.265	0.327	P	P	None
17	B/S	room 300, 3rd and 4th grade					7/15/2005	0.4	0.16	P									11/30/2007	0.168	0.029	P	P	None
18	B/S	room 301, bilingual					7/15/2005	0.032	0.028	P	10/12/2005	0.62	0.694	P					11/30/2007	0.174	0.029	P	P	None
19	B/S	room 304, 3rd grade	4/30/2004	0.54	0.33	P	7/15/2005		0.76	P									11/30/2007	0.234	0.207	P	P	None
20	B/S	room 305, 4/5 th grade					7/15/2005	0.49	0.57	P									11/30/2007	0.18	0.17	P	P	None
21	B/S	room 306, 5th grade					7/15/2005	0.64	0.46	P									11/30/2007	0.298	0.193	P	P	None
22	B/S	room 307, empty	4/30/2004	0.6	0.17	P	7/15/2005		0.75	P									11/30/2007	0.255	0.187	P	P	None
23	B	day care	4/30/2004	0.54	0.34	P	7/15/2005		0.66	P									11/30/2007	0.256	0.288	P	P	None
24	B/S	library - staff	4/30/2004	1	0.77	P	7/15/2005		1.2	P									11/30/2007	0.332	0.385	P	P	None
34	S	day care kitchen	4/30/2004	0.44		P	7/15/2005		0.4	P									11/30/2007	0.127	0.094	P	P	None
35	S	kitchen (south east)	4/30/2004	0.63		P	7/15/2005		0.83	P									11/30/2007	0.281	0.231	P	P	None
36	S	kitchen (east, left fixture)	4/30/2004	0.46		P	7/15/2005		0.75	P									11/30/2007	0.267	0.187	P	P	None
36A	S	kitchen (east, right fixture)					7/15/2005		0.48	P									11/30/2007	0.277	0.154	P	P	None
37	S	nurses	4/30/2004	0.48		P	7/15/2005		0.52	P									11/30/2007	0.246	0.036	P	P	None
38	S	staff office	4/30/2004	0.73		P	7/15/2005		0.44	P									11/30/2007	0.33	0.061	P	P	None
39	S	staff lounge	4/30/2004	0.49		P	7/15/2005		0.76	P					5/26/2006	0.548	0.482	P	11/30/2007	0.377	0.214	P	P	None
40	S	custodial sink, room 302					7/15/2005	0.58	0.48	P									11/30/2007	0.196	0.098	P	P	None
41	S	resource room																	11/30/2007	0.285	0.188	P	P	None
42	S	resource room																	11/30/2007	0.255	0.214	P	P	None
43	S	kitchen handwash																	11/30/2007	0.259	0.219	P	P	None
44	Sp	kitchen spray																	11/30/2007	0.23	0.068	P	P	None
45	S	daycare																	11/30/2007	0.263	0.191	P	P	None

Table 5. Iron Test Results

FIXTURE INFORMATION			Initial Sampling				Follow-up Sampling 1				Follow-up Sampling 2				Follow-up Sampling 3				Summary Status	
Fixture ID	Type	Location	Sampled	1st Draw	Flush 2m	Pass/Fail	Sampled	1st Draw	Flush 2m	Pass/Fail	Sampled	1st Draw	Flush 2m	Pass/Fail	Sampled	1st Draw	Flush 2m	Pass/Fail	Pass/Fail	Status
01	B	Hall - south 1st floor					7/15/2005		<0.05	P	10/12/2005		0.192	P					P	None
02	B/S	room 100, after school daycare					7/15/2005		0.27	P									P	None
03	B/S	room 101, special education					7/15/2005		0.23	P									P	None
04	B/S	room 102, 1st grade					7/15/2005		0.2	P									P	None
05	B/S	room 103, 1st grade					7/15/2005		0.21	P									P	None
06	B/S	room 104, music classroom					7/15/2005		0.22	P									P	None
07	B/S	room 105, math coach					7/15/2005		0.22	P									P	None
08	B/S	room 202, kindergarten					7/15/2005		0.22	P									P	None
09	B	hall north 2nd floor					7/15/2005		0.18	P	10/12/2005		0.165	P					P	None
10	S	room 203, kindergarten					7/15/2005		0.24	P									P	None
11	B/S	room 205, 2nd grade					7/15/2005		0.17	P	10/12/2005		0.192	P					P	None
12	B/S	room 206, 2nd grade					7/15/2005		0.3	P									P	None
13	B/S	room 207, computer lab					7/15/2005		0.24	P									P	None
14	B/S	room 310, 4th grade					7/15/2005		0.19	P									P	None
15	B/S	room 311, Art classroom					7/15/2005		0.19	P									P	None
17	B/S	room 300, 3rd and 4th grade					7/15/2005		0.2	P									P	None
18	B/S	room 301, bilingual					7/15/2005		0.13	P	10/12/2005		0.152	P					P	None
19	B/S	room 304, 3rd grade	4/30/2004	0.17	0.14	P													P	None
20	B/S	room 305, 4/5 th grade					7/15/2005		0.22	P									P	None
21	B/S	room 306, 5th grade					7/15/2005		0.21	P									P	None
22	B/S	room 307, empty	4/30/2004	0.17	0.24	P	7/15/2005		0.23	P									P	None
23	B	day care	4/30/2004	0.13	0.21	P	7/15/2005		0.21	P									P	None
24	B/S	library - staff	4/30/2004	0.43	0.2	P	7/15/2005		0.18	P									P	None
34	S	day care kitchen	4/30/2004	0.14		P	7/15/2005		0.2	P									P	None
35	S	kitchen (south east)	4/30/2004	0.29		P	7/15/2005		0.22	P									P	None
36	S	kitchen (east, left fixture)	4/30/2004	0.24		P	7/15/2005		0.21	P									P	None
36A	S	kitchen (east, right fixture)					7/15/2005		0.22	P									P	None
37	S	nurses	4/30/2004	0.15		P	7/15/2005		0.19	P									P	None
38	S	staff office	4/30/2004	0.15		P	7/15/2005		0.19	P									P	None
39	S	staff lounge	4/30/2004	0.18		P	7/15/2005		0.23	P					5/26/2006		0.178	P	P	None
40	S	custodial sink, room 302					7/15/2005		0.2	P									P	None
41	S	resource room																	n/a	None
42	S	resource room																	n/a	None
43	S	kitchen handwash																	n/a	None
44	Sp	kitchen spray																	n/a	None
45	S	daycare																	n/a	None

Table 6. Service Entry Test Results

Test Results (Service Entry/SE, Units as Shown)						
SOURCE INFORMATION			Most Recent Sampling			
Fixture ID	Type	Location	Item	Sampled	Max Value	Pass/Fail
00	SE	3/4" HB custodian room 008	Arsenic	05-May-06	2 ppb	P
00	SE	3/4" HB custodian room 008	Cadmium	30-Nov-07	1 ppb	P
00	SE	3/4" HB custodian room 008	Copper	30-Nov-07	0.23 ppm	P
00	SE	3/4" HB custodian room 008	E coli	30-Apr-04	<1 Colonies	P
00	SE	3/4" HB custodian room 008	Iron	30-Apr-04	0.19 ppm	P
00	SE	3/4" HB custodian room 008	Lead	30-Nov-07	3 ppb	P
00	SE	3/4" HB custodian room 008	Total Coliforms	30-Apr-04	<1 Colonies	P

"<" means: less than the value shown (below analytical detection limits).

"n/a" means: not applicable.

Table 7. Bacteriological Test Results

Bacteriological Characteristics

Bacteriological testing of selected samples indicated no (zero) coliform bacteria.