

Seattle Public Schools
Drinking Water Quality Program

Results of Water Quality Testing
for
Green Lake Elementary

Updated January 2, 2009

General Information:

Plumbing piping materials: copper

Remediation plan:

This remediation plan is based on a Water Quality policy approved by the School Board. The policy includes standards for the presence of lead, cadmium, copper, iron and other substances in drinking water.

Status:

Policy Criteria: This school has one source that does not meet the policy criteria. A sign will be posted at: room 116-storage room (#23).

Follow-up monitoring: Will be performed in 2011.

Service: The school will be flushed after any breaks longer than five days.

Water Quality Testing Results:

Legend	
Symbol	Definition
SE	service entry (main)
B	bubbler
S	sink (faucet)
B/S	sink/bubbler combination
S/B	sink/bubbler combination
ppb	parts per billion
ppm	parts per million
NA	not applicable
None	no action required
Unk	unknown status or action
Sample	sample needs to be taken
Re-test	fixture needs to be resampled
Conf	resample to confirm measurement
No flush	not flushed before sampling
Sink	sampled faucet of S/B combo
Used	recently used; no 1st draw sample possible
PS	post sign
Disable(d)	fixture disabled in response to water quality testing
IF	install filter
RB	replace bubbler
RB/IF	replace bubbler and/or install filter
RF	replace faucet
RF/IF	replace faucet and/or install filter
BW	disable fixture and provide bottled water until remediated
Leaks	leaking fixture
NW	not working properly (sample S when B of S/B NW)
OS	out of service - disabled until fixed
RS	return to service - now passes testing
Rem	Removed from system - no longer exists

Table 1. Summary of Results

CURRENT STATUS											
FIXTURE INFORMATION			LEAD		CADMIUM		COPPER		IRON		OK?
Fixture ID	Type	Location	Pass/Fail	Status	Pass/Fail	Status	Pass/Fail	Status	Pass/Fail	Status	Yes/No/Status
01	S/B	room 102, room 9, left	P	None	P	None	P	None	P	None	Yes
02	S/B	room 102, room 9, right	P	None	P	None	P	None	P	None	Yes
03	S/B	room 101, pod C1	P	None	P	None	P	None	P	None	Yes
04	S/B	room 101, pod C	P	None	P	None	P	None	P	None	Yes
05	S/B	room 101, pod C	P	None	P	None	P	None	P	None	Yes
06	S/B	room 101, pod C2	P	None	P	None	P	None	P	None	Yes
07	S/B	room 105, room 8, Therapy office	P	None	P	None	P	None	P	None	Yes
08	S/B	room 137, room 7	P	None	P	None	P	None	P	None	Yes
09	S/B	room 133, pod B1	P	None	P	None	P	None	P	None	Yes
10	S/B	room 133, pod B	P	None	P	None	P	None	P	None	Yes
11	S/B	room 133, pod B	P	None	P	None	P	None	P	None	Yes
12	S/B	room 133, pod B2	P	None	P	None	P	None	P	None	Yes
13	S/B	room 132, room 5	P	None	P	None	P	None	P	None	Yes
14	S/B	room 132, room 5	P	None	P	None	P	None	P	None	Yes
15	S/B	room 127, room 2, tutoring	P	None	P	None	P	None	P	None	Yes
16	B	room 123, Pod K1	P	None	P	None	P	None	P	None	Yes
17	S/B	room 122, room 1	P	None	P	None	P	None	P	None	Yes
18	B	room 123, Pod K2	P	None	P	None	P	None	P	None	Yes
19	S/B	room 118, room 3	P	None	P	None	P	None	P	None	Yes
20	S/B	room 115, pod A3	P	None	P	None	P	None	P	None	Yes
21	S/B	room 115, pod A2	P	None	P	None	P	None	P	None	Yes
22	S/B	room 115, pod A1	P	None	P	None	P	None	P	None	Yes
23	S	room 116 - storage room, room 4	F	PS	P	None	F	PS	P	None	PS
24	B	office	P	None	P	None	P	None	P	None	Yes
25	B	near gym, lower level	P	None	P	None	P	None	P	None	Yes
26	S/B	lower level, in art room	P	None	P	None	P	None	P	None	Yes
28	S	facilty lounge rm #112	P	None	P	None	P	None	P	None	Yes
29	S	nurse's office	P	None	P	None	P	None	P	None	Yes
30	S	Room 120 - food warming room, kitchen, left	P	None	P	None	P	None	P	None	Yes
34	S	Teacher prep room C - Room 103	P	None	P	None	P	None	P	None	Yes
35	S	Teacher prep room B - Room 134	P	None	P	None	P	None	P	None	Yes
36	S	Teacher prep room A - Room 117	P	None	P	None	P	None	P	None	Yes
37	S	Teacher prep room - Room 124	P	None	P	None	P	None	P	None	Yes
38	S	office storage room	P	None	P	None	P	None	P	None	Yes
39	S	Room 120 - food warming room, kitchen, right	P	None	P	None	P	None	N/A	None	Yes

Table 2. Lead Test Results

FIXTURE INFORMATION			Initial Sampling				Follow-up Sampling 1				Follow-up Sampling 2				Follow-up Sampling 3				Follow-up Sampling 4			
Fixture ID	Type	Location	Sampled	1st Draw	Flush 30s	Pass /Fail	Sampled	1st Draw	Flush 30s	Pass /Fail	Sampled	1st Draw	Flush 30s	Pass /Fail	Sampled	1 st Draw	Flush 30s	Pass /Fail	Sampled	1st Draw	Flush 30s	Pass /Fail
01	S/B	room 102, room 9, left	5/5/2004	38	1		4/29/2005	27	1		7/14/2005	57	<1						10/5/2005	28	1	
02	S/B	room 102, room 9, right	5/5/2004	45	4														10/5/2005			
03	S/B	room 101, pod C1	5/5/2004	15	1						7/14/2005	2	<1	P	8/11/2005	2	<1	P				
04	S/B	room 101, pod C	5/5/2004	63	2														10/5/2005			
05	S/B	room 101, pod C	5/5/2004	54	2														10/5/2005			
06	S/B	room 101, pod C2	5/5/2004	98	4														10/5/2005			
07	S/B	room 105, room 8, Therapy office	5/5/2004	66	6		4/29/2005	15	<1		7/14/2005	16	2						10/5/2005	7	<1	P
08	S/B	room 137, room 7	5/5/2004	180	2		4/29/2005	3	<1	P												
09	S/B	room 133, pod B1	5/5/2004	120	2		4/29/2005	2	<1	P												
10	S/B	room 133, pod B	5/5/2004	180	6		4/29/2005	10	2	P												
11	S/B	room 133, pod B	5/5/2004	9	3	P																
12	S/B	room 133, pod B2	5/5/2004	280	<1														10/5/2005			
13	S/B	room 132, room 5	5/5/2004	67	2		4/29/2005	6	<1	P												
14	S/B	room 132, room 5	5/5/2004	74	2														10/5/2005			
15	S/B	room 127, room 2, tutoring	5/5/2004	140	21		4/29/2005	43	1		7/14/2005	22	4						10/5/2005	11	1	
16	B	room 123, Pod K1	5/5/2004	18	2						7/14/2005	15	3		8/11/2005	11	2		10/5/2005	9	4	P
17	S/B	room 122, room 1	5/5/2004	26	4		4/29/2005	20	2		7/14/2005	27	4						10/5/2005	19	2	
18	B	room 123, Pod K2	5/5/2004	140	3						7/14/2005	15	3		8/11/2005	7	2	P				
19	S/B	room 118, room 3	5/5/2004	280	5		4/29/2005	13	1		7/14/2005	16	1						10/5/2005	13	<1	
20	S/B	room 115, pod A3	5/5/2004	99	5		4/29/2005	10	1	P												
21	S/B	room 115, pod A2	5/5/2004	170	2														10/5/2005			
22	S/B	room 115, pod A1	5/5/2004	190	2														10/5/2005			
23	S	room 116 - storage room, room 4					4/29/2005	78	2										10/5/2005			
24	B	office	5/5/2004	<1	<1	P																
25	B	near gym, lower level	5/5/2004	29	4		4/29/2005	270	5		7/14/2005	41	5						10/5/2005	34	4	
26	S/B	lower level, in art room	5/5/2004	1	<1	P	4/29/2005	4	<1	P												
28	S	facilty lounge rm #112	5/5/2004	<1	<1	P																
29	S	nurse's office	5/5/2004	2	<1	P																
30	S	Room 120 - food warming room, kitchen, left																				
34	S	Teacher prep room C - Room 103																				
35	S	Teacher prep room B - Room 134																				
36	S	Teacher prep room A - Room 117																				
37	S	Teacher prep room - Room 124																				
38	S	office storage room																				
39	S	Room 120 - food warming room, kitchen, right																				

Table 2. Lead Test Results (Continued)

Test Results (Lead/Pb, ppb)																								
FIXTURE INFORMATION			Follow-up Sampling 5				Follow-up Sampling 6				Follow-up Sampling 7				Follow-up Sampling 8				Follow-up Sampling 9				Summary Status	
Fixture ID	Type	Location	Sampled	1st Draw	Flush 30s	Pass /Fail	Sampled	1st Draw	Flush 30s	Pass /Fail	Sampled	1st Draw	Flush 30s	Pass /Fail	Sampled	1st Draw	Flush 30s	Pass /Fail	Sampled	1st Draw	Flush 30s	Pass /Fail	Pass/Fail	Status
01	S/B	room 102, room 9, left	5/10/2006	1	1	P	3/2/2007	<1	<1	P	3/13/2007	22	<1		10/8/2008	<1	<1	P					P	None
02	S/B	room 102, room 9, right	5/10/2006	23	1		3/2/2007	8	<1	P	3/13/2007	32	1		10/8/2008	5	<1	P					P	None
03	S/B	room 101, pod C1													10/8/2008	<1	<1	P					P	None
04	S/B	room 101, pod C	5/10/2006	156	1		3/2/2007	14	<1		3/13/2007	19	<1		10/8/2008	1	<1	P					P	None
05	S/B	room 101, pod C	5/10/2006	89	2		3/2/2007	10	<1	P	3/13/2007	17	<1		10/8/2008	7	<1	P					P	None
06	S/B	room 101, pod C2	5/10/2006	24	3		3/2/2007	9	<1	P	3/13/2007	16	<1		10/8/2008	2	<1	P					P	None
07	S/B	room 105, room 8, Therapy office													10/8/2008	3	<1	P					P	None
08	S/B	room 137, room 7													10/8/2008	<1	<1	P					P	None
09	S/B	room 133, pod B1													10/8/2008	<1	<1	P					P	None
10	S/B	room 133, pod B													10/8/2008	<1	<1	P					P	None
11	S/B	room 133, pod B									3/13/2007	21	<1		10/8/2008	<1	<1	P					P	None
12	S/B	room 133, pod B2	5/10/2006	49	1		3/2/2007	<1	<1	P	3/13/2007	10	<1	P	10/8/2008	<1	<1	P					P	None
13	S/B	room 132, room 5													10/8/2008	5	2	P					P	None
14	S/B	room 132, room 5	5/10/2006	35	1		3/2/2007	<1	<1	P	3/13/2007	12	<1		10/8/2008	<1	<1	P					P	None
15	S/B	room 127, room 2, tutoring	5/10/2006	1	3	P	3/2/2007	4	<1	P	3/13/2007	25	<1		10/8/2008	6	<1	P					P	None
16	B	room 123, Pod K1													10/8/2008	3	<1	P					P	None
17	S/B	room 122, room 1	5/10/2006	1	1	P	3/2/2007	3	1	P	3/13/2007	34	1		10/8/2008	<1	1	P					P	None
18	B	room 123, Pod K2													10/8/2008	3	<1	P					P	None
19	S/B	room 118, room 3	5/10/2006	1	1	P	3/2/2007	2	<1	P	3/13/2007	26	<1		10/8/2008	<1	<1	P					P	None
20	S/B	room 115, pod A3													10/8/2008	4	<1	P					P	None
21	S/B	room 115, pod A2	5/10/2006	96	5		3/2/2007	20	<1		3/13/2007	45	2		10/8/2008	18	<1		12/2/2008	6	1	P	P	None
22	S/B	room 115, pod A1	5/10/2006	60	1		3/2/2007	9	<1	P	3/13/2007	30	<1		10/8/2008	2	<1	P					P	None
23	S	room 116 - storage room, room 4	5/10/2006	37	5		3/2/2007	34	1		3/13/2007	38	<1		10/8/2008	28	2						F	PS
24	B	office													10/8/2008	<1	<1	P					P	None
25	B	near gym, lower level	5/10/2006	1	1	P	3/2/2007	1	2	P					10/8/2008	<1	<1	P					P	None
26	S/B	lower level, in art room													10/8/2008	<1	<1	P					P	None
28	S	faculty lounge rm #112													10/8/2008	<1	<1	P					P	None
29	S	nurse's office													10/8/2008	1	<1	P					P	None
30	S	Room 120 - food warming room, kitchen, left									3/13/2007	20	1		10/8/2008	1	<1	P					P	None
34	S	Teacher prep room C - Room 103									3/13/2007	9	<1	P	10/8/2008	3	<1	P					P	None
35	S	Teacher prep room B - Room 134									3/13/2007	3	<1	P	10/8/2008	2	<1	P					P	None
36	S	Teacher prep room A - Room 117									3/13/2007	<1	<1	P	10/8/2008	<1	<1	P					P	None
37	S	Teacher prep room - Room 124									3/13/2007	1	<1	P	10/8/2008	<1	<1	P					P	None
38	S	office storage room													10/8/2008	<1	<1	P					P	None
39	S	Room 120 - food warming room, kitchen, right													10/8/2008	10	<1	P					P	None

Table 3. Cadmium Test Results

Test Results (Cadmium/Cd, ppb)																												
FIXTURE INFORMATION			Initial Sampling				Follow-up Sampling 1				Follow-up Sampling 2				Follow-up Sampling 3				Follow-up Sampling 4				Follow-up Sampling 5				Summary Status	
Fixture ID	Type	Location	Date	1st Draw	Flush 30s	Pass /Fail	Sampled	1st Draw	Flush 30s	Pass /Fail	Date	1st Draw	Flush 30s	Pass /Fail	Sampled	1st Draw	Flush 30s	Pass /Fail	Date	1st Draw	Flush 30s	Pass /Fail	Date	1st Draw	Flush 30s	Pass /Fail	Pass/Fail	Status
01	S/B	room 102, room 9, left					4/29/05	4	<1	P	7/14/05	1	<1	P									10/8/08	<1	<1	P	P	None
02	S/B	room 102, room 9, right									7/14/05				3/2/07	<1	<1	P					10/8/08	<1	<1	P	P	None
03	S/B	room 101, pod C1									7/14/05	<1	<1	P									10/8/08	<1	<1	P	P	None
04	S/B	room 101, pod C	5/5/04	<1	<1	P																	10/8/08	<1	<1	P	P	None
05	S/B	room 101, pod C									7/14/05				3/2/07	1	<1	P					10/8/08	<1	<1	P	P	None
06	S/B	room 101, pod C2									7/14/05				3/2/07	<1	<1	P					10/8/08	<1	<1	P	P	None
07	S/B	room 105, room 8, Therapy office					4/29/05	11	<1		7/14/05	4	<1	P									10/8/08	<1	<1	P	P	None
08	S/B	room 137, room 7					4/29/05	<1	<1	P													10/8/08	<1	<1	P	P	None
09	S/B	room 133, pod B1					4/29/05	<1	<1	P													10/8/08	<1	<1	P	P	None
10	S/B	room 133, pod B					4/29/05	<1	<1	P													10/8/08	<1	<1	P	P	None
11	S/B	room 133, pod B	5/5/04	<1	<1	P																	10/8/08	<1	<1	P	P	None
12	S/B	room 133, pod B2									7/14/05				3/2/07	<1	<1	P					10/8/08	<1	<1	P	P	None
13	S/B	room 132, room 5					4/29/05	<1	<1	P													10/8/08	1	<1	P	P	None
14	S/B	room 132, room 5									7/14/05				3/2/07	<1	<1	P					10/8/08	<1	<1	P	P	None
15	S/B	room 127, room 2, tutoring					4/29/05	<1	<1	P	7/14/05	<1	<1	P									10/8/08	<1	<1	P	P	None
16	B	room 123, Pod K1									7/14/05	<1	<1	P									10/8/08	<1	<1	P	P	None
17	S/B	room 122, room 1					4/29/05	<1	<1	P	7/14/05	<1	<1	P									10/8/08	<1	<1	P	P	None
18	B	room 123, Pod K2	5/5/04	<1	<1	P	4/29/05		<1	P	7/14/05	<1	<1	P									10/8/08	<1	<1	P	P	None
19	S/B	room 118, room 3					4/29/05	<1	<1	P	7/14/05	<1	<1	P									10/8/08	<1	<1	P	P	None
20	S/B	room 115, pod A3					4/29/05	<1	<1	P													10/8/08	<1	<1	P	P	None
21	S/B	room 115, pod A2									7/14/05				3/2/07	<1	<1	P					10/8/08	2	<1	P	P	None
22	S/B	room 115, pod A1									7/14/05				3/2/07	<1	<1	P					10/8/08	<1	<1	P	P	None
23	S	room 116 – storage room, room 4					4/29/05	<1	<1	P													10/8/08	<1	<1	P	P	None
24	B	office	5/5/04	<1	<1	P																	10/8/08	<1	<1	P	P	None
25	B	near gym, lower level					4/29/05	<1	<1	P	7/14/05	<1	<1	P									10/8/08	<1	<1	P	P	None
26	S/B	lower level, in art room					4/29/05	<1	<1	P													10/8/08	<1	<1	P	P	None
28	S	factly lounge rm #112	5/5/04	<1	<1	P																	10/8/08	<1	<1	P	P	None
29	S	nurse's office	5/5/04	<1	<1	P																	10/8/08	<1	<1	P	P	None
30	S	Room 120 - food warming room, kitchen, left																	3/13/07	<1	<1	P	10/8/08	<1	<1	P	P	None
34	S	Teacher prep room C - Room 103																	3/13/07	<1	<1	P	10/8/08	<1	<1	P	P	None
35	S	Teacher prep room B - Room 134																	3/13/07	<1	<1	P	10/8/08	<1	<1	P	P	None
36	S	Teacher prep room A - Room 117																	3/13/07	<1	<1	P	10/8/08	<1	<1	P	P	None
37	S	Teacher prep room - Room 124																	3/13/07	<1	<1	P	10/8/08	<1	<1	P	P	None
38	S	office storage room																					10/8/08	<1	<1	P	P	None
39	S	Room 120 - food warming room, kitchen, right																					10/8/08	<1	<1	P	P	None

Table 4. Copper Test Results

FIXTURE INFORMATION			Initial Sampling				Follow-up Sampling 1				Follow-up Sampling 2				Follow-up Sampling 3			
Fixture ID	Type	Location	Sampled	1st Draw	Flush 2m	Pass/Fail	Sampled	1st Draw	Flush 30s	Pass/Fail	Sampled	1st Draw	Flush 30s	Pass/Fail	Sampled	1st Draw	Flush 30s	Pass/Fail
01	S/B	room 102, room 9, left					4/29/2005	0.9	0.65	P	7/14/2005	0.79	0.81	P				
02	S/B	room 102, room 9, right													10/5/2005			
03	S/B	room 101, pod C1									7/14/2005	0.64	0.7	P				
04	S/B	room 101, pod C	5/5/2004	1.5	0.74						7/14/2005				10/5/2005			
05	S/B	room 101, pod C													10/5/2005			
06	S/B	room 101, pod C2													10/5/2005			
07	S/B	room 105, room 8, Therapy office					4/29/2005	0.5	0.69	P	7/14/2005	0.36	0.88	P				
08	S/B	room 137, room 7					4/29/2005	1	0.48	P								
09	S/B	room 133, pod B1					4/29/2005	0.92	0.9	P								
10	S/B	room 133, pod B					4/29/2005	3.2	1						10/5/2005	0.938	0.902	P
11	S/B	room 133, pod B	5/5/2004	3.6	0.73		4/29/2005		2.6						10/5/2005	1.09	2.25	
12	S/B	room 133, pod B2													10/5/2005			
13	S/B	room 132, room 5					4/29/2005	1	0.72	P								
14	S/B	room 132, room 5													10/5/2005			
15	S/B	room 127, room 2, tutoring					4/29/2005	0.86	0.16	P	7/14/2005	0.69	0.43	P				
16	B	room 123, Pod K1									7/14/2005	0.58	0.42	P				
17	S/B	room 122, room 1					4/29/2005	0.69	0.3	P	7/14/2005	0.86	0.6	P				
18	B	room 123, Pod K2	5/5/2004	1.3	0.23	P	4/29/2005		0.28	P	7/14/2005	0.59	0.58	P				
19	S/B	room 118, room 3					4/29/2005	1.1	0.17	P	7/14/2005	0.83	0.6	P				
20	S/B	room 115, pod A3					4/29/2005	0.81	0.46	P								
21	S/B	room 115, pod A2													10/5/2005			
22	S/B	room 115, pod A1													10/5/2005			
23	S	room 116 - storage room, room 4					4/29/2005	2	0.1						10/5/2005			
24	B	office	5/5/2004	0.59	0.12	P	4/29/2005		0.4	P								
25	B	near gym, lower level					4/29/2005	1.2	0.95	P	7/14/2005	0.91	0.7	P				
26	S/B	lower level, in art room					4/29/2005	0.44	0.33	P								
28	S	faculty lounge rm #112	5/5/2004	0.048		P	4/29/2005		0.045	P								
29	S	nurse's office	5/5/2004	0.38		P	4/29/2005		0.37	P								
30	S	Room 120 - food warming room, kitchen, left																
34	S	Teacher prep room C - Room 103																
35	S	Teacher prep room B - Room 134																
36	S	Teacher prep room A - Room 117																
37	S	Teacher prep room - Room 124																
38	S	office storage room																
39	S	Room 120 - food warming room, kitchen, right																

Table 4. Copper Test Results (Continued)

FIXTURE INFORMATION			Follow-up Sampling 4				Follow-up Sampling 5				Follow-up Sampling 6				Follow-up Sampling 7				Summary Status	
Fixture ID	Type	Location	Sampled	1st Draw	Flush 30s	Pass/Fail	Sampled	1st Draw	Flush 30s	Pass/Fail	Sampled	1st Draw	Flush 30s	Pass/Fail	Sampled	1st Draw	Flush 30s	Pass/Fail	Pass/Fail	Status
01	S/B	room 102, room 9, left													10/8/2008	0.004	0.006	P	P	None
02	S/B	room 102, room 9, right					3/2/2007	0.367	0.373	P					10/8/2008	0.227	0.233	P	P	None
03	S/B	room 101, pod C1													10/8/2008	0.306	0.287	P	P	None
04	S/B	room 101, pod C	5/10/2006	2.2	0.703		3/2/2007	0.554	0.395	P					10/8/2008	0.36	0.352	P	P	None
05	S/B	room 101, pod C					3/2/2007	0.472	0.388	P					10/8/2008	0.337	0.374	P	P	None
06	S/B	room 101, pod C2					3/2/2007	0.322	0.328	P					10/8/2008	0.276	0.234	P	P	None
07	S/B	room 105, room 8, Therapy office													10/8/2008	0.119	0.24	P	P	None
08	S/B	room 137, room 7													10/8/2008	0.627	0.258	P	P	None
09	S/B	room 133, pod B1													10/8/2008	0.438	0.51	P	P	None
10	S/B	room 133, pod B													10/8/2008	0.552	0.258	P	P	None
11	S/B	room 133, pod B	5/10/2006	0.022	0.02	P									10/8/2008	<0.002	0.002	P	P	None
12	S/B	room 133, pod B2					3/2/2007	0.489	0.411	P					10/8/2008	0.257	0.236	P	P	None
13	S/B	room 132, room 5													10/8/2008	0.813	0.149	P	P	None
14	S/B	room 132, room 5					3/2/2007	0.345	0.114	P					10/8/2008	0.176	0.047	P	P	None
15	S/B	room 127, room 2, tutoring													10/8/2008	0.093	0.06	P	P	None
16	B	room 123, Pod K1													10/8/2008	0.152	0.046	P	P	None
17	S/B	room 122, room 1													10/8/2008	0.003	0.008	P	P	None
18	B	room 123, Pod K2													10/8/2008	0.139	0.141	P	P	None
19	S/B	room 118, room 3													10/8/2008	0.012	0.002	P	P	None
20	S/B	room 115, pod A3													10/8/2008	0.222	0.231	P	P	None
21	S/B	room 115, pod A2					3/2/2007	0.204	0.161	P					10/8/2008	0.147	0.132	P	P	None
22	S/B	room 115, pod A1					3/2/2007	2.32	0.626		3/13/2007	0.75	0.092	P	10/8/2008	0.332	0.217	P	P	None
23	S	room 116 - storage room, room 4	5/10/2006	2.13	0.112		3/2/2007	0.253	0.126	P					10/8/2008	13	0.539		F	PS
24	B	office													10/8/2008	0.472	0.235	P	P	None
25	B	near gym, lower level													10/8/2008	<0.002	0.002	P	P	None
26	S/B	lower level, in art room													10/8/2008	0.148	0.109	P	P	None
28	S	faculty lounge rm #112													10/8/2008	0.049	0.028	P	P	None
29	S	nurse's office													10/8/2008	0.3	0.17	P	P	None
30	S	Room 120 - food warming room, kitchen, left									3/13/2007	0.164	0.196	P	10/8/2008	0.162	0.047	P	P	None
34	S	Teacher prep room C - Room 103									3/13/2007	0.381	0.062	P	10/8/2008	0.363	0.058	P	P	None
35	S	Teacher prep room B - Room 134									3/13/2007	0.386	0.328	P	10/8/2008	0.559	0.257	P	P	None
36	S	Teacher prep room A - Room 117									3/13/2007	0.453	0.242	P	10/8/2008	0.263	0.158	P	P	None
37	S	Teacher prep room - Room 124									3/13/2007	0.391	0.204	P	10/8/2008	0.338	0.106	P	P	None
38	S	office storage room													10/8/2008	0.442	0.143	P	P	None
39	S	Room 120 - food warming room, kitchen, right													10/8/2008	0.212	0.049	P	P	None

Table 5. Iron Test Results

Test Results (Iron/Fe, ppm)																								
FIXTURE INFORMATION			Initial Sampling				Follow-up Sampling 1				Follow-up Sampling 2				Follow-up Sampling 3				Follow-up Sampling 4				Summary Status	
Fixture ID	Type	Location	Sampled	1st Draw	Flush 2m	Pass /Fail	Sampled	1st Draw	Flush 2m	Pass /Fail	Sampled	1st Draw	Flush 2m	Pass /Fail	Sampled	1st Draw	Flush 2m	Pass /Fail	Sampled	1st Draw	Flush 2m	Pass /Fail	Pass/Fail	Status
01	S/B	room 102, room 9, left					4/29/2005		0.14	P	7/14/2005		0.29	P									P	None
02	S/B	room 102, room 9, right									7/14/2005				3/13/2007		0.162	P	10/8/2008		0.053	P	P	None
03	S/B	room 101, pod C1									7/14/2005		0.17	P									P	None
04	S/B	room 101, pod C	5/5/2004	0.39	0.22	P													10/8/2008		0.055	P	P	None
05	S/B	room 101, pod C									7/14/2005				3/13/2007		0.181	P					P	None
06	S/B	room 101, pod C2									7/14/2005				3/13/2007		0.162	P					P	None
07	S/B	room 105, room 8, Therapy office					4/29/2005		0.12	P													P	None
08	S/B	room 137, room 7					4/29/2005		0.11	P	7/14/2005		0.26	P									P	None
09	S/B	room 133, pod B1					4/29/2005		0.17	P	7/14/2005		0.29	P									P	None
10	S/B	room 133, pod B					4/29/2005		0.16	P	7/14/2005		0.38	P									P	None
11	S/B	room 133, pod B	5/5/2004	0.21	0.21	P	4/29/2005		0.12	P									10/8/2008		<0.05	P	P	None
12	S/B	room 133, pod B2									7/14/2005				3/13/2007		0.137	P					P	None
13	S/B	room 132, room 5					4/29/2005		0.12	P	7/14/2005		0.26	P									P	None
14	S/B	room 132, room 5									7/14/2005				3/13/2007		0.148	P					P	None
15	S/B	room 127, room 2, tutoring					4/29/2005		0.1	P	7/14/2005		0.28	P									P	None
16	B	room 123, Pod K1									7/14/2005		0.28	P									P	None
17	S/B	room 122, room 1					4/29/2005		0.12	P	7/14/2005		0.28	P									P	None
18	B	room 123, Pod K2	5/5/2004	0.69	0.17		4/29/2005		0.11	P	7/14/2005		0.33	P					10/8/2008		<0.05	P	P	None
19	S/B	room 118, room 3					4/29/2005		0.08	P	7/14/2005		0.32	P									P	None
20	S/B	room 115, pod A3					4/29/2005		0.13	P	7/14/2005		0.26	P									P	None
21	S/B	room 115, pod A2									7/14/2005				3/13/2007		0.134	P	10/8/2008		0.051	P	P	None
22	S/B	room 115, pod A1									7/14/2005				3/13/2007		0.146	P					P	None
23	S	room 116 - storage room, room 4					4/29/2005		0.1	P	7/14/2005												P	None
24	B	office	5/5/2004	0.2	0.16	P	4/29/2005		0.1	P													P	None
25	B	near gym, lower level					4/29/2005		0.1	P	7/14/2005		0.4	P									P	None
26	S/B	lower level, in art room					4/29/2005		0.15	P	7/14/2005		0.33	P									P	None
28	S	faculty lounge rm #112	5/5/2004	0.2		P	4/29/2005		0.1	P	7/14/2005		0.44	P									P	None
29	S	nurse's office	5/5/2004	0.23		P	4/29/2005		0.1	P	7/14/2005		0.42	P									P	None
30	S	Room 120 - food warming room, kitchen, left													3/13/2007		0.159	P					P	None
34	S	Teacher prep room C - Room 103													3/13/2007		0.177	P					P	None
35	S	Teacher prep room B - Room 134													3/13/2007		0.129	P					P	None
36	S	Teacher prep room A - Room 117													3/13/2007		0.201	P					P	None
37	S	Teacher prep room - Room 124													3/13/2007		0.148	P					P	None
38	S	office storage room																	10/8/2008		0.051	P	P	None
39	S	Room 120 - food warming room, kitchen, right																					n/a	None

Table 6. Service Entry Test Results

Test Results (Service Entry/SE, Units as Shown)						
SOURCE INFORMATION			Most Recent Sampling			
Fixture ID	Type	Location	Item	Sampled	Max Value	Pass/Fail
00	SE	boiler room	Arsenic	08-Oct-08	2 ppb	P
00	SE	boiler room	Cadmium	08-Oct-08	1 ppb	P
00	SE	boiler room	Copper	08-Oct-08	0.028 ppm	P
00	SE	boiler room	Iron	08-Oct-08	0.069 ppm	P
00	SE	boiler room	Lead	08-Oct-08	1 ppb	P
00	SE	boiler room	Total Coliforms	08-Oct-08	<1 Colonies	P

"<" means: less than the value shown (below analytical detection limits).

"n/a" means: not applicable.

Table 7. Bacteriological Test Results

Bacteriological Characteristics

Bacteriological testing of selected samples indicated no (zero) coliform bacteria.