

**Seattle Public Schools  
Drinking Water Quality Program**

**Results of Water Quality Testing  
for  
GENESEE HILL SCHOOL**

Updated March 3, 2020

**General Information:**

Plumbing piping materials: mainly copper

**Remediation plan:**

*This remediation plan is based on a Water Quality policy approved by the School Board. The policy includes standards for the presence of lead, cadmium, copper, iron and other substances in drinking water.*

**Sinks (S in the report) are not considered drinking water sources.** We recognize that there is the potential for students to want to drink from classroom hand-washing sinks, so we test all of those. Where a student's choice to drink from a sink could be a problem, we post a reminder sign, as we do at all restroom sinks.

Status:

Policy Criteria:

All fixtures meet the policy criteria.

Follow-up monitoring: Will be performed in school year 2022-2023

Service: The school will be returned to regular service and will be flushed after any breaks longer than five days.

## Water Quality Testing Results:

### Legend

| Symbol     | Definition   |
|------------|--|
| SE         | service entry (main)                                       |
| B          | bubbler  |
| S          | sink (faucet)  |
| B/S        | sink/bubbler combination                                   |
| S/B        | sink/bubbler combination                                   |
| ppb        | parts per billion  |
| ppm        | parts per million  |
| NA         | not applicable   |
| None       | no action required   |
| Unk        | unknown status or action                                   |
| Sample     | sample needs to be taken                                   |
| Re-test    | fixture needs to be resampled                              |
| Conf       | resample to confirm measurement                            |
| No flush   | not flushed before sampling                                |
| Sink       | sampled faucet of S/B combo                                |
| Used       | recently used; no 1st draw sample possible                 |
| PS         | post sign  |
| Disable(d) | fixture disabled in response to water quality testing      |
| BDSS       | Bubbler disabled, sign on sink                             |
| IF         | install filter   |
| RB         | replace bubbler  |
| RB/IF      | replace bubbler and/or install filter                      |
| RF         | replace faucet   |
| RF/IF      | replace faucet and/or install filter                       |
| BW         | disable fixture and provide bottled water until remediated |
| Leaks      | leaking fixture  |
| NW         | not working properly (sample S when B of S/B NW)           |
| OS         | out of service - disabled until fixed                      |
| RS         | return to service - now passes testing                     |
| Rem        | Removed from system - no longer exists                     |

Table 1. Summary of Results

| FIXTURE INFORMATION |      |                           | LEAD      |        | CADMIUM   |        | COPPER    |        | IRON      |        | OK?           |
|---------------------|------|---------------------------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|---------------|
| Fixture ID          | Type | Location                  | Pass/Fail | Status | Pass/Fail | Status | Pass/Fail | Status | Pass/Fail | Status | Yes/No/Status |
| 01                  | S    | room 1308                 | P         | None   | P         | None   | P         | None   |           |        | Yes           |
| 02                  | S    | kitchen                   | P         | None   | P         | None   | P         | None   |           |        | Yes           |
| 05                  | S    | Kitchen , left            | P         | None   | P         | None   | P         | None   |           |        | Yes           |
| 06                  | S    | kitchen, right            | P         | None   | P         | None   | P         | None   |           |        | Yes           |
| 07                  | S    | kitchen, handwash         | P         | None   | P         | None   | P         | None   |           |        | Yes           |
| 08                  | B    | lunch room, left          | P         | None   | P         | None   | P         | None   |           |        | Yes           |
| 09                  | B    | lunch room, right         | P         | None   | P         | None   | P         | None   |           |        | Yes           |
| 10                  | B    | gym, left                 | P         | None   | P         | None   | P         | None   | P         | None   | Yes           |
| 11                  | B    | gym, right                | P         | None   | P         | None   | P         | None   | P         | None   | Yes           |
| 12                  | B    | East entry, left          | P         | None   | P         | None   | P         | None   | P         | None   | Yes           |
| 13                  | B    | East entry, right         | P         | None   | P         | None   | P         | None   |           |        | Yes           |
| 14                  | B    | bottle filler, east entry | P         | None   | P         | None   | P         | None   |           |        | Yes           |
| 15                  | S/B  | stage                     | P         | None   | P         | None   | P         | None   |           |        | Yes           |
| 16                  | S/B  | music room 1303           | P         | None   | P         | None   | P         | None   |           |        | Yes           |
| 17                  | S/B  | daycare                   | P         | None   | P         | None   | P         | None   |           |        | Yes           |
| 18                  | S/B  | daycare                   | P         | None   | P         | None   | P         | None   |           |        | Yes           |
| 19                  | S    | daycare kitchen, left     | P         | None   | P         | None   | P         | None   | P         | None   | Yes           |
| 20                  | S    | daycare kitchen, middle   | P         | None   | P         | None   | P         | None   |           |        | Yes           |
| 21                  | S    | daycare kitchen, right    | P         | None   | P         | None   | P         | None   |           |        | Yes           |
| 22                  | S/B  | daycare                   | P         | None   | P         | None   | P         | None   | P         | None   | Yes           |
| 23                  | S/B  | daycare                   | P         | None   | P         | None   | P         | None   |           |        | Yes           |
| 24                  | S    | workroom 1211             | P         | None   | P         | None   | P         | None   |           |        | Yes           |
| 25                  | S/B  | Special Ed. room 1219     | P         | None   | P         | None   | P         | None   | P         | None   | Yes           |
| 26                  | S/B  | special Ed kitchen, 1221  | P         | None   | P         | None   | P         | None   |           |        | Yes           |
| 27                  | S/B  | special Ed. 1220          | P         | None   | P         | None   | P         | None   |           |        | Yes           |
| 28                  | S    | library office            | P         | None   | P         | None   | P         | None   |           |        | Yes           |
| 29                  | S    | teacher's lounge          | P         | None   | P         | None   | P         | None   | P         | None   | Yes           |
| 30                  | S    | art room 2202, left       | P         | None   | P         | None   | P         | None   |           |        | Yes           |
| 31                  | S    | art room 2202, right      | P         | None   | P         | None   | P         | None   | P         | None   | Yes           |
| 32                  | S/B  | flex room 3114            | P         | None   | P         | None   | P         | None   |           |        | Yes           |
| 33                  | B    | 3rd floor hallway, left   | P         | None   | P         | None   | P         | None   |           |        | Yes           |
| 34                  | B    | 3rd floor hallway, right  | P         | None   | P         | None   | P         | None   | P         | None   | Yes           |
| 35                  | S/B  | room 3105                 | P         | None   | P         | None   | P         | None   |           |        | Yes           |
| 36                  | S/B  | room 3102                 | P         | None   | P         | None   | P         | None   |           |        | Yes           |
| 37                  | S/B  | room 3103                 | P         | None   | P         | None   | P         | None   |           |        | Yes           |
| 38                  | S/B  | room 3104                 | P         | None   | P         | None   | P         | None   |           |        | Yes           |
| 39                  | S    | workroom 3107             | P         | None   | P         | None   | P         | None   |           |        | Yes           |
| 40                  | S/B  | room 3110                 | P         | None   | P         | None   | P         | None   |           |        | Yes           |
| 41                  | S/B  | room 3111                 | P         | None   | P         | None   | P         | None   | P         | None   | Yes           |
| 42                  | S/B  | room 3112                 | P         | None   | P         | None   | P         | None   |           |        | Yes           |
| 43                  | S/B  | room 3109                 | P         | None   | P         | None   | P         | None   | P         | None   | Yes           |
| 44                  | S/B  | room 2104                 | P         | None   | P         | None   | P         | None   |           |        | Yes           |
| 45                  | S/B  | room 2103                 | P         | None   | P         | None   | P         | None   | P         | None   | Yes           |
| 46                  | S/B  | room 2102                 | P         | None   | P         | None   | P         | None   |           |        | Yes           |
| 47                  | S/B  | room 2105                 | P         | None   | P         | None   | P         | None   |           |        | Yes           |
| 48                  | S    | room 2107                 | P         | None   | P         | None   | P         | None   |           |        | Yes           |

|    |     |                          |   |      |   |      |   |      |   |      |     |
|----|-----|--------------------------|---|------|---|------|---|------|---|------|-----|
| 49 | S/B | room 2109                | P | None | P | None | P | None |   |      | Yes |
| 50 | S/B | room 2112                | P | None | P | None | P | None | P | None | Yes |
| 51 | S/B | room 2111                | P | None | P | None | P | None |   |      | Yes |
| 52 | S/B | room 2110                | P | None | P | None | P | None |   |      | Yes |
| 53 | B   | 2nd floor hallway, left  | P | None | P | None | P | None |   |      | Yes |
| 54 | B   | 2nd floor hallway, right | P | None | P | None | P | None |   |      | Yes |
| 55 | S/B | room 1104                | P | None | P | None | P | None | P | None | Yes |
| 56 | S/B | room 1103                | P | None | P | None | P | None |   |      | Yes |
| 57 | S/B | room 1102                | P | None | P | None | P | None | P | None | Yes |
| 58 | S/B | room 1105                | P | None | P | None | P | None |   |      | Yes |
| 59 | B   | 1st floor hallway, left  | P | None | P | None | P | None |   |      | Yes |
| 60 | B   | 1st floor hallway, right | P | None | P | None | P | None |   |      | Yes |
| 61 | S/B | room 1109                | P | None | P | None | P | None |   |      | Yes |
| 62 | S/B | room 1112                | P | None | P | None | P | None |   |      | Yes |
| 63 | S/B | room 1111                | P | None | P | None | P | None |   |      | Yes |
| 64 | S/B | room 1110                | P | None | P | None | P | None |   |      | Yes |
| 65 | S/B | room 1114                | P | None | P | None | P | None | P | None | Yes |
| 66 | S/B | room 2114                | P | None | P | None | P | None | P | None | Yes |
| 67 | S/B | nurse office, 1210       | P | None | P | None | P | None | P | None | Yes |

Table 2. Lead Test Results

| Test Results (Lead/Pb, ppb) |      |                           |           |           |           |           |           |           |           |           |           |                |        |
|-----------------------------|------|---------------------------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|----------------|--------|
| FIXTURE INFORMATION         |      |                           | 7/19/2016 |           |           | 9/15/2016 |           |           | 2/19/2020 |           |           | Summary Status |        |
| Fixture ID                  | Type | Location                  | 1st Draw  | Flush 30s | Pass/Fail | 1st Draw  | Flush 30s | Pass/Fail | 1st Draw  | Flush 30s | Pass/Fail | Pass/Fail      | Status |
| 01                          | S    | room 1308                 |           |           |           | <1        | <1        | P         | <1        | <1        | P         | P              | None   |
| 02                          | S    | kitchen                   | <1        | <1        | P         |           |           |           | <1        | <1        | P         | P              | None   |
| 05                          | S    | Kitchen , left            | <1        | <1        | P         |           |           |           | <1        | <1        | P         | P              | None   |
| 06                          | S    | kitchen, right            | <1        | <1        | P         |           |           |           | <1        | <1        | P         | P              | None   |
| 07                          | S    | kitchen, handwash         | <1        | <1        | P         |           |           |           | <1        | <1        | P         | P              | None   |
| 08                          | B    | lunch room, left          | <1        | <1        | P         |           |           |           | <1        | <1        | P         | P              | None   |
| 09                          | B    | lunch room, right         | <1        | <1        | P         |           |           |           | <1        | <1        | P         | P              | None   |
| 10                          | B    | gym, left                 | <1        | <1        | P         |           |           |           | <1        | <1        | P         | P              | None   |
| 11                          | B    | gym, right                | <1        | <1        | P         |           |           |           | <1        | <1        | P         | P              | None   |
| 12                          | B    | East entry, left          | <1        | <1        | P         |           |           |           | <1        | <1        | P         | P              | None   |
| 13                          | B    | East entry, right         | <1        | <1        | P         |           |           |           | <1        | <1        | P         | P              | None   |
| 14                          | B    | bottle filler, east entry | <1        | <1        | P         |           |           |           | <1        | <1        | P         | P              | None   |
| 15                          | S/B  | stage                     | <1        | <1        | P         |           |           |           | <1        | <1        | P         | P              | None   |
| 16                          | S/B  | music room 1303           | <1        | <1        | P         |           |           |           | <1        | <1        | P         | P              | None   |
| 17                          | S/B  | daycare                   | <1        | <1        | P         |           |           |           | <1        | <1        | P         | P              | None   |
| 18                          | S/B  | daycare                   | <1        | <1        | P         |           |           |           | <1        | <1        | P         | P              | None   |
| 19                          | S    | daycare kitchen, left     | 2         | <1        | P         |           |           |           | <1        | <1        | P         | P              | None   |
| 20                          | S    | daycare kitchen, middle   | <1        | <1        | P         |           |           |           | <1        | <1        | P         | P              | None   |
| 21                          | S    | daycare kitchen, right    | 1         | <1        | P         |           |           |           | 1         | <1        | P         | P              | None   |
| 22                          | S/B  | daycare                   | <1        | <1        | P         |           |           |           | <1        | <1        | P         | P              | None   |
| 23                          | S/B  | daycare                   | <1        | <1        | P         |           |           |           | <1        | <1        | P         | P              | None   |
| 24                          | S    | workroom 1211             | <1        | <1        | P         |           |           |           | <1        | <1        | P         | P              | None   |
| 25                          | S/B  | Special Ed. room 1219     | 1         | <1        | P         |           |           |           | <1        | <1        | P         | P              | None   |
| 26                          | S/B  | special Ed kitchen, 1221  | <1        | <1        | P         |           |           |           | <1        | <1        | P         | P              | None   |
| 27                          | S/B  | special Ed. 1220          | <1        | <1        | P         |           |           |           | <1        | <1        | P         | P              | None   |
| 28                          | S    | library office            | 4         | <1        | P         |           |           |           | <1        | <1        | P         | P              | None   |
| 29                          | S    | teacher's lounge          | <1        | <1        | P         |           |           |           | <1        | <1        | P         | P              | None   |
| 30                          | S    | art room 2202, left       | <1        | <1        | P         |           |           |           | <1        | <1        | P         | P              | None   |
| 31                          | S    | art room 2202, right      | 1         | <1        | P         |           |           |           | <1        | <1        | P         | P              | None   |
| 32                          | S/B  | flex room 3114            | <1        | <1        | P         |           |           |           | <1        | <1        | P         | P              | None   |
| 33                          | B    | 3rd floor hallway, left   | <1        | <1        | P         |           |           |           | <1        | <1        | P         | P              | None   |
| 34                          | B    | 3rd floor hallway, right  | <1        | <1        | P         |           |           |           | <1        | <1        | P         | P              | None   |
| 35                          | S/B  | room 3105                 | <1        | <1        | P         |           |           |           | <1        | <1        | P         | P              | None   |
| 36                          | S/B  | room 3102                 | <1        | <1        | P         |           |           |           | <1        | <1        | P         | P              | None   |
| 37                          | S/B  | room 3103                 | <1        | <1        | P         |           |           |           | <1        | <1        | P         | P              | None   |
| 38                          | S/B  | room 3104                 | 1         | <1        | P         |           |           |           | <1        | <1        | P         | P              | None   |
| 39                          | S    | workroom 3107             | <1        | <1        | P         |           |           |           | <1        | <1        | P         | P              | None   |
| 40                          | S/B  | room 3110                 | 1         | <1        | P         |           |           |           | <1        | <1        | P         | P              | None   |
| 41                          | S/B  | room 3111                 | <1        | <1        | P         |           |           |           | <1        | <1        | P         | P              | None   |
| 42                          | S/B  | room 3112                 | 2         | <1        | P         |           |           |           | <1        | <1        | P         | P              | None   |
| 43                          | S/B  | room 3109                 | 2         | <1        | P         |           |           |           | <1        | <1        | P         | P              | None   |
| 44                          | S/B  | room 2104                 | <1        | <1        | P         |           |           |           | <1        | <1        | P         | P              | None   |
| 45                          | S/B  | room 2103                 | 1         | <1        | P         |           |           |           | <1        | <1        | P         | P              | None   |
| 46                          | S/B  | room 2102                 | 1         | <1        | P         |           |           |           | <1        | <1        | P         | P              | None   |
| 47                          | S/B  | room 2105                 | 1         | <1        | P         |           |           |           | <1        | <1        | P         | P              | None   |
| 48                          | S    | room 2107                 | 2         | <1        | P         |           |           |           | <1        | <1        | P         | P              | None   |
| 49                          | S/B  | room 2109                 | <1        | <1        | P         |           |           |           | <1        | <1        | P         | P              | None   |

|    |     |                          |    |    |   |  |  |  |    |    |   |   |      |
|----|-----|--------------------------|----|----|---|--|--|--|----|----|---|---|------|
| 50 | S/B | room 2112                | <1 | <1 | P |  |  |  | <1 | <1 | P | P | None |
| 51 | S/B | room 2111                | <1 | <1 | P |  |  |  | <1 | <1 | P | P | None |
| 52 | S/B | room 2110                | 1  | <1 | P |  |  |  | <1 | <1 | P | P | None |
| 53 | B   | 2nd floor hallway, left  | <1 | <1 | P |  |  |  | <1 | <1 | P | P | None |
| 54 | B   | 2nd floor hallway, right | <1 | <1 | P |  |  |  | <1 | <1 | P | P | None |
| 55 | S/B | room 1104                | 1  | <1 | P |  |  |  | <1 | <1 | P | P | None |
| 56 | S/B | room 1103                | 1  | <1 | P |  |  |  | <1 | <1 | P | P | None |
| 57 | S/B | room 1102                | 1  | <1 | P |  |  |  | <1 | <1 | P | P | None |
| 58 | S/B | room 1105                | 1  | <1 | P |  |  |  | <1 | <1 | P | P | None |
| 59 | B   | 1st floor hallway, left  | <1 | <1 | P |  |  |  | <1 | <1 | P | P | None |
| 60 | B   | 1st floor hallway, right | <1 | <1 | P |  |  |  | <1 | <1 | P | P | None |
| 61 | S/B | room 1109                | <1 | <1 | P |  |  |  | <1 | <1 | P | P | None |
| 62 | S/B | room 1112                | <1 | <1 | P |  |  |  | <1 | <1 | P | P | None |
| 63 | S/B | room 1111                | <1 | <1 | P |  |  |  | <1 | <1 | P | P | None |
| 64 | S/B | room 1110                | <1 | <1 | P |  |  |  | <1 | <1 | P | P | None |
| 65 | S/B | room 1114                | 1  | <1 | P |  |  |  | <1 | <1 | P | P | None |
| 66 | S/B | room 2114                | <1 | <1 | P |  |  |  | <1 | <1 | P | P | None |
| 67 | S/B | nurse office, 1210       | 1  | <1 | P |  |  |  | <1 | <1 | P | P | None |

Table 3. Cadmium Test Results

| Test Results (Cadmium/Cd, ppb) |      |                           |           |           |           |           |           |           |           |           |           |                |        |
|--------------------------------|------|---------------------------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|----------------|--------|
| FIXTURE INFORMATION            |      |                           | 7/19/2016 |           |           | 9/15/2016 |           |           | 2/19/2020 |           |           | Summary Status |        |
| Fixture ID                     | Type | Location                  | 1st Draw  | Flush 30s | Pass/Fail | 1st Draw  | Flush 30s | Pass/Fail | 1st Draw  | Flush 30s | Pass/Fail | Pass/Fail      | Status |
| 01                             | S    | room 1308                 |           |           |           | <1        | <1        | P         | <1        | <1        | P         | P              | None   |
| 02                             | S    | kitchen                   | <1        | <1        | P         |           |           |           | <1        | <1        | P         | P              | None   |
| 05                             | S    | Kitchen , left            | <1        | <1        | P         |           |           |           | <1        | <1        | P         | P              | None   |
| 06                             | S    | kitchen, right            | <1        | <1        | P         |           |           |           | <1        | <1        | P         | P              | None   |
| 07                             | S    | kitchen, handwash         | <1        | <1        | P         |           |           |           | <1        | <1        | P         | P              | None   |
| 08                             | B    | lunch room, left          | <1        | <1        | P         |           |           |           | <1        | <1        | P         | P              | None   |
| 09                             | B    | lunch room, right         | <1        | <1        | P         |           |           |           | <1        | <1        | P         | P              | None   |
| 10                             | B    | gym, left                 | <1        | <1        | P         |           |           |           | <1        | <1        | P         | P              | None   |
| 11                             | B    | gym, right                | <1        | <1        | P         |           |           |           | <1        | <1        | P         | P              | None   |
| 12                             | B    | East entry, left          | <1        | <1        | P         |           |           |           | <1        | <1        | P         | P              | None   |
| 13                             | B    | East entry, right         | <1        | <1        | P         |           |           |           | <1        | <1        | P         | P              | None   |
| 14                             | B    | bottle filler, east entry | <1        | <1        | P         |           |           |           | <1        | <1        | P         | P              | None   |
| 15                             | S/B  | stage                     | <1        | <1        | P         |           |           |           | <1        | <1        | P         | P              | None   |
| 16                             | S/B  | music room 1303           | <1        | <1        | P         |           |           |           | <1        | <1        | P         | P              | None   |
| 17                             | S/B  | daycare                   | <1        | <1        | P         |           |           |           | <1        | <1        | P         | P              | None   |
| 18                             | S/B  | daycare                   | <1        | <1        | P         |           |           |           | <1        | <1        | P         | P              | None   |
| 19                             | S    | daycare kitchen, left     | <1        | <1        | P         |           |           |           | <1        | <1        | P         | P              | None   |
| 20                             | S    | daycare kitchen, middle   | <1        | <1        | P         |           |           |           | <1        | <1        | P         | P              | None   |
| 21                             | S    | daycare kitchen, right    | <1        | <1        | P         |           |           |           | <1        | <1        | P         | P              | None   |
| 22                             | S/B  | daycare                   | <1        | <1        | P         |           |           |           | <1        | <1        | P         | P              | None   |
| 23                             | S/B  | daycare                   | <1        | <1        | P         |           |           |           | <1        | <1        | P         | P              | None   |
| 24                             | S    | workroom 1211             | <1        | <1        | P         |           |           |           | <1        | <1        | P         | P              | None   |
| 25                             | S/B  | Special Ed. room 1219     | <1        | <1        | P         |           |           |           | <1        | <1        | P         | P              | None   |
| 26                             | S/B  | special Ed kitchen, 1221  | <1        | <1        | P         |           |           |           | <1        | <1        | P         | P              | None   |
| 27                             | S/B  | special Ed. 1220          | <1        | <1        | P         |           |           |           | <1        | <1        | P         | P              | None   |
| 28                             | S    | library office            | <1        | <1        | P         |           |           |           | <1        | <1        | P         | P              | None   |
| 29                             | S    | teacher's lounge          | <1        | <1        | P         |           |           |           | <1        | <1        | P         | P              | None   |
| 30                             | S    | art room 2202, left       | <1        | <1        | P         |           |           |           | <1        | <1        | P         | P              | None   |
| 31                             | S    | art room 2202, right      | <1        | <1        | P         |           |           |           | <1        | <1        | P         | P              | None   |
| 32                             | S/B  | flex room 3114            | <1        | <1        | P         |           |           |           | <1        | <1        | P         | P              | None   |
| 33                             | B    | 3rd floor hallway, left   | <1        | <1        | P         |           |           |           | <1        | <1        | P         | P              | None   |
| 34                             | B    | 3rd floor hallway, right  | <1        | <1        | P         |           |           |           | <1        | <1        | P         | P              | None   |
| 35                             | S/B  | room 3105                 | <1        | <1        | P         |           |           |           | <1        | <1        | P         | P              | None   |
| 36                             | S/B  | room 3102                 | <1        | <1        | P         |           |           |           | <1        | <1        | P         | P              | None   |
| 37                             | S/B  | room 3103                 | <1        | <1        | P         |           |           |           | <1        | <1        | P         | P              | None   |
| 38                             | S/B  | room 3104                 | <1        | <1        | P         |           |           |           | <1        | <1        | P         | P              | None   |
| 39                             | S    | workroom 3107             | <1        | <1        | P         |           |           |           | <1        | <1        | P         | P              | None   |
| 40                             | S/B  | room 3110                 | <1        | <1        | P         |           |           |           | <1        | <1        | P         | P              | None   |
| 41                             | S/B  | room 3111                 | <1        | <1        | P         |           |           |           | <1        | <1        | P         | P              | None   |
| 42                             | S/B  | room 3112                 | <1        | <1        | P         |           |           |           | <1        | <1        | P         | P              | None   |
| 43                             | S/B  | room 3109                 | <1        | <1        | P         |           |           |           | <1        | <1        | P         | P              | None   |
| 44                             | S/B  | room 2104                 | <1        | <1        | P         |           |           |           | <1        | <1        | P         | P              | None   |
| 45                             | S/B  | room 2103                 | <1        | <1        | P         |           |           |           | <1        | <1        | P         | P              | None   |
| 46                             | S/B  | room 2102                 | <1        | <1        | P         |           |           |           | <1        | <1        | P         | P              | None   |
| 47                             | S/B  | room 2105                 | <1        | <1        | P         |           |           |           | <1        | <1        | P         | P              | None   |
| 48                             | S    | room 2107                 | <1        | <1        | P         |           |           |           | <1        | <1        | P         | P              | None   |

|    |     |                          |    |    |   |  |  |  |    |    |   |   |      |
|----|-----|--------------------------|----|----|---|--|--|--|----|----|---|---|------|
| 49 | S/B | room 2109                | <1 | <1 | P |  |  |  | <1 | <1 | P | P | None |
| 50 | S/B | room 2112                | <1 | <1 | P |  |  |  | <1 | <1 | P | P | None |
| 51 | S/B | room 2111                | <1 | <1 | P |  |  |  | <1 | <1 | P | P | None |
| 52 | S/B | room 2110                | <1 | <1 | P |  |  |  | <1 | <1 | P | P | None |
| 53 | B   | 2nd floor hallway, left  | <1 | <1 | P |  |  |  | <1 | <1 | P | P | None |
| 54 | B   | 2nd floor hallway, right | <1 | <1 | P |  |  |  | <1 | <1 | P | P | None |
| 55 | S/B | room 1104                | <1 | <1 | P |  |  |  | <1 | <1 | P | P | None |
| 56 | S/B | room 1103                | <1 | <1 | P |  |  |  | <1 | <1 | P | P | None |
| 57 | S/B | room 1102                | <1 | <1 | P |  |  |  | <1 | <1 | P | P | None |
| 58 | S/B | room 1105                | <1 | <1 | P |  |  |  | <1 | <1 | P | P | None |
| 59 | B   | 1st floor hallway, left  | <1 | <1 | P |  |  |  | <1 | <1 | P | P | None |
| 60 | B   | 1st floor hallway, right | <1 | <1 | P |  |  |  | <1 | <1 | P | P | None |
| 61 | S/B | room 1109                | <1 | <1 | P |  |  |  | <1 | <1 | P | P | None |
| 62 | S/B | room 1112                | <1 | <1 | P |  |  |  | <1 | <1 | P | P | None |
| 63 | S/B | room 1111                | <1 | <1 | P |  |  |  | <1 | <1 | P | P | None |
| 64 | S/B | room 1110                | <1 | <1 | P |  |  |  | <1 | <1 | P | P | None |
| 65 | S/B | room 1114                | <1 | <1 | P |  |  |  | <1 | <1 | P | P | None |
| 66 | S/B | room 2114                | <1 | <1 | P |  |  |  | <1 | <1 | P | P | None |
| 67 | S/B | nurse office, 1210       | <1 | <1 | P |  |  |  | <1 | <1 | P | P | None |



Table 4. Copper Test Results

| Test Results (Copper/Cu, ppm) |      |                           |           |           |           |           |           |           |           |           |           |                |        |
|-------------------------------|------|---------------------------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|----------------|--------|
| FIXTURE INFORMATION           |      |                           | 7/19/2016 |           |           | 9/15/2016 |           |           | 2/19/2020 |           |           | Summary Status |        |
| Fixture ID                    | Type | Location                  | 1st Draw  | Flush 30s | Pass/Fail | 1st Draw  | Flush 30s | Pass/Fail | 1st Draw  | Flush 30s | Pass/Fail | Pass/Fail      | Status |
| 01                            | S    | room 1308                 |           |           |           | 0.202     | 0.201     | P         | 0.22      | 0.253     | P         | P              | None   |
| 02                            | S    | kitchen                   | 0.037     | 0.198     | P         |           |           |           | 0.194     | 0.203     | P         | P              | None   |
| 05                            | S    | Kitchen , left            | 0.178     | 0.189     | P         |           |           |           | 0.229     | 0.201     | P         | P              | None   |
| 06                            | S    | kitchen, right            | 0.155     | 0.157     | P         |           |           |           | 0.369     | 0.205     | P         | P              | None   |
| 07                            | S    | kitchen, handwash         | 0.161     | 0.171     | P         |           |           |           | 0.223     | 0.286     | P         | P              | None   |
| 08                            | B    | lunch room, left          | 0.157     | 0.176     | P         |           |           |           | 0.243     | 0.222     | P         | P              | None   |
| 09                            | B    | lunch room, right         | 0.203     | 0.18      | P         |           |           |           | 0.254     | 0.223     | P         | P              | None   |
| 10                            | B    | gym, left                 | 0.19      | 0.171     | P         |           |           |           | 0.233     | 0.174     | P         | P              | None   |
| 11                            | B    | gym, right                | 0.173     | 0.171     | P         |           |           |           | 0.178     | 0.149     | P         | P              | None   |
| 12                            | B    | East entry, left          | 0.21      | 0.179     | P         |           |           |           | 0.251     | 0.192     | P         | P              | None   |
| 13                            | B    | East entry, right         | 0.14      | 0.179     | P         |           |           |           | 0.244     | 0.19      | P         | P              | None   |
| 14                            | B    | bottle filler, east entry | 0.178     | 0.174     | P         |           |           |           | 0.191     | 0.184     | P         | P              | None   |
| 15                            | S/B  | stage                     | 0.147     | 0.224     | P         |           |           |           | 0.19      | 0.182     | P         | P              | None   |
| 16                            | S/B  | music room 1303           | 0.08      | 0.155     | P         |           |           |           | 0.184     | 0.215     | P         | P              | None   |
| 17                            | S/B  | daycare                   | 0.128     | 0.2       | P         |           |           |           | 0.209     | 0.156     | P         | P              | None   |
| 18                            | S/B  | daycare                   | 0.193     | 0.191     | P         |           |           |           | 0.183     | 0.147     | P         | P              | None   |
| 19                            | S    | daycare kitchen, left     | 0.34      | 0.186     | P         |           |           |           | 0.161     | 0.164     | P         | P              | None   |
| 20                            | S    | daycare kitchen, middle   | 0.188     | 0.19      | P         |           |           |           | 0.189     | 0.153     | P         | P              | None   |
| 21                            | S    | daycare kitchen, right    | 0.375     | 0.184     | P         |           |           |           | 0.241     | 0.167     | P         | P              | None   |
| 22                            | S/B  | daycare                   | 0.176     | 0.184     | P         |           |           |           | 0.194     | 0.165     | P         | P              | None   |
| 23                            | S/B  | daycare                   | 0.2       | 0.226     | P         |           |           |           | 0.221     | 0.151     | P         | P              | None   |
| 24                            | S    | workroom 1211             | 0.084     | 0.078     | P         |           |           |           | 0.247     | 0.182     | P         | P              | None   |
| 25                            | S/B  | Special Ed. room 1219     | 0.167     | 0.133     | P         |           |           |           | 0.262     | 0.256     | P         | P              | None   |
| 26                            | S/B  | special Ed kitchen, 1221  | 0.103     | 0.146     | P         |           |           |           | 0.329     | 0.24      | P         | P              | None   |
| 27                            | S/B  | special Ed. 1220          | 0.135     | 0.127     | P         |           |           |           | 0.196     | 0.223     | P         | P              | None   |
| 28                            | S    | library office            | 0.162     | 0.188     | P         |           |           |           | 0.168     | 0.193     | P         | P              | None   |
| 29                            | S    | teacher's lounge          | 0.483     | 0.265     | P         |           |           |           | 0.3       | 0.317     | P         | P              | None   |
| 30                            | S    | art room 2202, left       | 0.26      | 0.225     | P         |           |           |           | 0.175     | 0.226     | P         | P              | None   |
| 31                            | S    | art room 2202, right      | 0.342     | 0.217     | P         |           |           |           | 0.298     | 0.175     | P         | P              | None   |
| 32                            | S/B  | flex room 3114            | 0.233     | 0.233     | P         |           |           |           | 0.19      | 0.229     | P         | P              | None   |
| 33                            | B    | 3rd floor hallway, left   | 0.214     | 0.192     | P         |           |           |           | 0.293     | 0.291     | P         | P              | None   |
| 34                            | B    | 3rd floor hallway, right  | 0.202     | 0.196     | P         |           |           |           | 0.239     | 0.288     | P         | P              | None   |
| 35                            | S/B  | room 3105                 | 0.198     | 0.226     | P         |           |           |           | 0.194     | 0.205     | P         | P              | None   |
| 36                            | S/B  | room 3102                 | 0.207     | 0.232     | P         |           |           |           | 0.221     | 0.191     | P         | P              | None   |
| 37                            | S/B  | room 3103                 | 0.214     | 0.23      | P         |           |           |           | 0.214     | 0.206     | P         | P              | None   |
| 38                            | S/B  | room 3104                 | 0.206     | 0.236     | P         |           |           |           | 0.204     | 0.176     | P         | P              | None   |
| 39                            | S    | workroom 3107             | 0.145     | 0.223     | P         |           |           |           | 0.205     | 0.319     | P         | P              | None   |
| 40                            | S/B  | room 3110                 | 0.231     | 0.185     | P         |           |           |           | 0.262     | 0.204     | P         | P              | None   |
| 41                            | S/B  | room 3111                 | 0.237     | 0.206     | P         |           |           |           | 0.24      | 0.215     | P         | P              | None   |
| 42                            | S/B  | room 3112                 | 0.272     | 0.245     | P         |           |           |           | 0.261     | 0.234     | P         | P              | None   |
| 43                            | S/B  | room 3109                 | 0.248     | 0.222     | P         |           |           |           | 0.198     | 0.256     | P         | P              | None   |
| 44                            | S/B  | room 2104                 | 0.28      | 0.242     | P         |           |           |           | 0.212     | 0.289     | P         | P              | None   |
| 45                            | S/B  | room 2103                 | 0.253     | 0.245     | P         |           |           |           | 0.303     | 0.241     | P         | P              | None   |
| 46                            | S/B  | room 2102                 | 0.253     | 0.202     | P         |           |           |           | 0.26      | 0.203     | P         | P              | None   |
| 47                            | S/B  | room 2105                 | 0.29      | 0.241     | P         |           |           |           | 0.264     | 0.283     | P         | P              | None   |
| 48                            | S    | room 2107                 | 0.5       | 0.187     | P         |           |           |           | 0.279     | 0.337     | P         | P              | None   |

|    |     |                          |       |       |   |  |  |  |       |       |   |   |      |
|----|-----|--------------------------|-------|-------|---|--|--|--|-------|-------|---|---|------|
| 49 | S/B | room 2109                | 0.221 | 0.221 | P |  |  |  | 0.206 | 0.268 | P | P | None |
| 50 | S/B | room 2112                | 0.236 | 0.237 | P |  |  |  | 0.247 | 0.257 | P | P | None |
| 51 | S/B | room 2111                | 0.227 | 0.238 | P |  |  |  | 0.244 | 0.246 | P | P | None |
| 52 | S/B | room 2110                | 0.238 | 0.228 | P |  |  |  | 0.277 | 0.216 | P | P | None |
| 53 | B   | 2nd floor hallway, left  | 0.268 | 0.195 | P |  |  |  | 0.285 | 0.259 | P | P | None |
| 54 | B   | 2nd floor hallway, right | 0.238 | 0.193 | P |  |  |  | 0.295 | 0.278 | P | P | None |
| 55 | S/B | room 1104                | 0.168 | 0.182 | P |  |  |  | 0.222 | 0.246 | P | P | None |
| 56 | S/B | room 1103                | 0.16  | 0.192 | P |  |  |  | 0.211 | 0.261 | P | P | None |
| 57 | S/B | room 1102                | 0.168 | 0.199 | P |  |  |  | 0.228 | 0.25  | P | P | None |
| 58 | S/B | room 1105                | 0.167 | 0.188 | P |  |  |  | 0.26  | 0.191 | P | P | None |
| 59 | B   | 1st floor hallway, left  | 0.227 | 0.169 | P |  |  |  | 0.291 | 0.284 | P | P | None |
| 60 | B   | 1st floor hallway, right | 0.21  | 0.166 | P |  |  |  | 0.3   | 0.275 | P | P | None |
| 61 | S/B | room 1109                | 0.13  | 0.18  | P |  |  |  | 0.311 | 0.224 | P | P | None |
| 62 | S/B | room 1112                | 0.132 | 0.126 | P |  |  |  | 0.281 | 0.192 | P | P | None |
| 63 | S/B | room 1111                | 0.153 | 0.206 | P |  |  |  | 0.322 | 0.306 | P | P | None |
| 64 | S/B | room 1110                | 0.182 | 0.204 | P |  |  |  | 0.345 | 0.314 | P | P | None |
| 65 | S/B | room 1114                | 0.139 | 0.201 | P |  |  |  | 0.25  | 0.235 | P | P | None |
| 66 | S/B | room 2114                | 0.221 | 0.266 | P |  |  |  | 0.243 | 0.227 | P | P | None |
| 67 | S/B | nurse office, 1210       | 0.204 | 0.118 | P |  |  |  | 0.254 | 0.247 | P | P | None |

Table 5. Iron Test Results

| Test Results (Iron/Fe, ppm) |      |                           |           |           |           |           |                |        |
|-----------------------------|------|---------------------------|-----------|-----------|-----------|-----------|----------------|--------|
| FIXTURE INFORMATION         |      |                           | 7/19/2016 |           | 2/19/2020 |           | Summary Status |        |
| Fixture ID                  | Type | Location                  | Flush 2m  | Pass/Fail | Flush 2m  | Pass/Fail | Pass/Fail      | Status |
| 01                          | S    | room 1308                 |           |           |           |           |                |        |
| 02                          | S    | kitchen                   |           |           |           |           |                |        |
| 05                          | S    | Kitchen , left            |           |           |           |           |                |        |
| 06                          | S    | kitchen, right            |           |           |           |           |                |        |
| 07                          | S    | kitchen, handwash         |           |           |           |           |                |        |
| 08                          | B    | lunch room, left          |           |           |           |           |                |        |
| 09                          | B    | lunch room, right         |           |           |           |           |                |        |
| 10                          | B    | gym, left                 |           |           | <0.05     | P         | P              | None   |
| 11                          | B    | gym, right                | <0.05     | P         |           |           | P              | None   |
| 12                          | B    | East entry, left          | <0.05     | P         |           |           | P              | None   |
| 13                          | B    | East entry, right         |           |           |           |           |                |        |
| 14                          | B    | bottle filler, east entry |           |           |           |           |                |        |
| 15                          | S/B  | stage                     |           |           |           |           |                |        |
| 16                          | S/B  | music room 1303           |           |           |           |           |                |        |
| 17                          | S/B  | daycare                   |           |           |           |           |                |        |
| 18                          | S/B  | daycare                   |           |           |           |           |                |        |
| 19                          | S    | daycare kitchen, left     |           |           | <0.05     | P         | P              | None   |
| 20                          | S    | daycare kitchen, middle   |           |           |           |           |                |        |
| 21                          | S    | daycare kitchen, right    |           |           |           |           |                |        |
| 22                          | S/B  | daycare                   | <0.05     | P         |           |           | P              | None   |
| 23                          | S/B  | daycare                   |           |           |           |           |                |        |
| 24                          | S    | workroom 1211             |           |           |           |           |                |        |
| 25                          | S/B  | Special Ed. room 1219     | 0.052     | P         | <0.05     | P         | P              | None   |
| 26                          | S/B  | special Ed kitchen, 1221  |           |           |           |           |                |        |
| 27                          | S/B  | special Ed. 1220          |           |           |           |           |                |        |
| 28                          | S    | library office            |           |           |           |           |                |        |
| 29                          | S    | teacher's lounge          | 0.107     | P         |           |           | P              | None   |
| 30                          | S    | art room 2202, left       |           |           |           |           |                |        |
| 31                          | S    | art room 2202, right      | <0.05     | P         |           |           | P              | None   |
| 32                          | S/B  | flex room 3114            |           |           |           |           |                |        |
| 33                          | B    | 3rd floor hallway, left   |           |           |           |           |                |        |
| 34                          | B    | 3rd floor hallway, right  |           |           | 0.055     | P         | P              | None   |
| 35                          | S/B  | room 3105                 |           |           |           |           |                |        |
| 36                          | S/B  | room 3102                 |           |           |           |           |                |        |
| 37                          | S/B  | room 3103                 |           |           |           |           |                |        |
| 38                          | S/B  | room 3104                 |           |           |           |           |                |        |
| 39                          | S    | workroom 3107             |           |           |           |           |                |        |
| 40                          | S/B  | room 3110                 |           |           |           |           |                |        |
| 41                          | S/B  | room 3111                 | <0.05     | P         |           |           | P              | None   |
| 42                          | S/B  | room 3112                 |           |           |           |           |                |        |
| 43                          | S/B  | room 3109                 |           |           | <0.05     | P         | P              | None   |
| 44                          | S/B  | room 2104                 |           |           |           |           |                |        |
| 45                          | S/B  | room 2103                 | <0.05     | P         |           |           | P              | None   |
| 46                          | S/B  | room 2102                 |           |           |           |           |                |        |
| 47                          | S/B  | room 2105                 |           |           |           |           |                |        |

|    |     |                          |       |   |       |   |   |      |
|----|-----|--------------------------|-------|---|-------|---|---|------|
| 48 | S   | room 2107                |       |   |       |   |   |      |
| 49 | S/B | room 2109                |       |   |       |   |   |      |
| 50 | S/B | room 2112                |       |   | <0.05 | P | P | None |
| 51 | S/B | room 2111                |       |   |       |   |   |      |
| 52 | S/B | room 2110                |       |   |       |   |   |      |
| 53 | B   | 2nd floor hallway, left  |       |   |       |   |   |      |
| 54 | B   | 2nd floor hallway, right |       |   |       |   |   |      |
| 55 | S/B | room 1104                | 0.215 | P |       |   | P | None |
| 56 | S/B | room 1103                |       |   |       |   |   |      |
| 57 | S/B | room 1102                |       |   | <0.05 | P | P | None |
| 58 | S/B | room 1105                |       |   |       |   |   |      |
| 59 | B   | 1st floor hallway, left  |       |   |       |   |   |      |
| 60 | B   | 1st floor hallway, right |       |   |       |   |   |      |
| 61 | S/B | room 1109                |       |   |       |   |   |      |
| 62 | S/B | room 1112                |       |   |       |   |   |      |
| 63 | S/B | room 1111                |       |   |       |   |   |      |
| 64 | S/B | room 1110                |       |   |       |   |   |      |
| 65 | S/B | room 1114                | <0.05 | P | <0.05 | P | P | None |
| 66 | S/B | room 2114                | 0.052 | P |       |   | P | None |
| 67 | S/B | nurse office, 1210       | 0.053 | P |       |   | P | None |

Table 6. Service Entry Test Results

| Test Results (Service Entry/SE, Units as Shown) |      |                         |                      |           |             |           |
|---|------|-------------------------|----------------------|-----------|-------------|-----------|
| SOURCE INFORMATION                              |      |                         | Most Recent Sampling |           |             |           |
| Fixture ID                                      | Type | Location                | Item                 | Sampled   | Max Value   | Pass/Fail |
| 00  | SE   | outside by loading dock | Arsenic              | 19-Jul-16 | 2 ppb       | P         |
| 00  | SE   | outside by loading dock | Cadmium              | 19-Jul-16 | 1 ppb       | P         |
| 00  | SE   | outside by loading dock | Copper               | 19-Jul-16 | 0.068 ppm   | P         |
| 00  | SE   | outside by loading dock | Iron                 | 19-Jul-16 | 0.07 ppm    | P         |
| 00  | SE   | outside by loading dock | Lead                 | 19-Jul-16 | 1 ppb       | P         |
| 00  | SE   | outside by loading dock | Total Coliforms      | 19-Jul-16 | <1 Colonies | P         |

"<" means: less than the value shown (below analytical detection limits).

"n/a" means: not applicable.

Table 7. Bacteriological Test Results

**Bacteriological Characteristics**

Bacteriological testing of selected samples indicated no (zero) coliform bacteria.