

**Seattle Public Schools
Drinking Water Quality Program**

**Results of Water Quality Testing
for
Hamilton Middle school**

Updated July 14, 2020

General Information:

Plumbing piping materials: mainly copper

Remediation plan:

This remediation plan is based on a Water Quality policy approved by the School Board. The policy includes standards for the presence of lead, cadmium, copper, iron and other substances in drinking water.

Sinks (S in the report) are not considered drinking water sources. We recognize that there is the potential for students to want to drink from classroom hand-washing sinks, so we test all of those. Where a student's choice to drink from a sink could be a problem, we post a reminder sign, as we do at all restroom sinks.

Status:

Policy Criteria: All sources meet the policy criteria.

Follow-up monitoring: Will be performed in school year 2022-2023.

Service: The school will be flushed after any breaks longer than five days.

Water Quality Testing Results:

Legend

Symbol	Definition
SE	service entry (main)
B	bubbler
S	sink (faucet)
B/S	sink/bubbler combination
S/B	sink/bubbler combination
ppb	parts per billion
ppm	parts per million
NA	not applicable
None	no action required
Unk	unknown status or action
Sample	sample needs to be taken
Re-test	fixture needs to be resampled
Conf	resample to confirm measurement
No flush	not flushed before sampling
Sink	sampled faucet of S/B combo
Used	recently used; no 1st draw sample possible
PS	post sign
Disable(d)	fixture disabled in response to water quality testing
BDSS	Bubbler disabled, sign on sink
IF	install filter
RB	replace bubbler
RB/IF	replace bubbler and/or install filter
RF	replace faucet
RF/IF	replace faucet and/or install filter
BW	disable fixture and provide bottled water until remediated
Leaks	leaking fixture
NW	not working properly (sample S when B of S/B NW)
OS	out of service - disabled until fixed
RS	return to service - now passes testing
Rem	Removed from system - no longer exists

Table 1. Summary of Results

FIXTURE INFORMATION			LEAD		CADMIUM		COPPER		IRON		OK?
Fixture ID	Type	Location	Pass/Fail	Status	Pass/Fail	Status	Pass/Fail	Status	Pass/Fail	Status	Yes/No/Status
101	S	PTSA, room 104	P	None	P	None	P	None			Yes
102	S	main office, room 101A	P	None	P	None	P	None	P	None	Yes
103	S	Health center, room 106H	P	None	P	None	P	None	P	None	Yes
104	S	Health center, room 106H	P	None	P	None	P	None	P	None	Yes
105	S	HEALTH CENTER, EXAM ROOM 106I	P	None	P	None	P	None	P	None	Yes
106	S/B	WORK ROOM 107B	P	None	P	None	P	None			Yes
107	S	STAGE	P	None	P	None	P	None			Yes
108	S/B	BAND ROOM 111	P	None	P	None	P	None			Yes
109	S/B	BAND ROOM 112	P	None	P	None	P	None	P	None	Yes
110	S	GATEWAY SHOP, ROOM 113A	P	None	P	None	P	None	P	None	Yes
111	S	KITCHEN, LEFT	P	None	P	None	P	None	P	None	Yes
112	S	KITCHEN, RIGHT	P	None	P	None	P	None	P	None	Yes
113	S	KITCHEN, MIDDLE ISLAND	P	None	P	None	P	None			Yes
114	S	KITCHEN	P	None	P	None	P	None			Yes
115	K	KITCHEN, KETTLE	P	None	P	None	P	None			Yes
116	B	FIRST FLOOR HALLWAY, OUTSIDE LOCKER ROOM, LEFT	P	None	P	None	P	None			Yes
117	B	FIRST FLOOR HALLWAY, OUTSIDE LOCKER ROOM, RIGHT	P	None	P	None	P	None			Yes
118	S	LIBRARY OFFICE, ROOM 103B	P	None	P	None	P	None			Yes
119	B	FIRST FLOOR HALLWAY, OUTSIDE ROOM 103, LEFT	P	None	P	None	P	None			Yes
120	B	FIRST FLOOR HALLWAY, OUTSIDE ROOM 103, RIGHT	P	None	P	None	P	None			Yes
122	S	STAFF LOUNGE, ROOM 126	P	None	P	None	P	None	P	None	Yes
123	S	ROOM 219	P	None	P	None	P	None	P	None	Yes
125	S	ROOM 218	P	None	P	None	P	None	P	None	Yes
127	S/B	ROOM 221	P	None	P	None	P	None	P	None	Yes
128	S	TEACHER'S PREP ROOM 226	P	None	P	None	P	None			Yes
129	S/B	ROOM 227	P	None	P	None	P	None			Yes
130	S	FLEX SPACE 230	P	None	P	None	P	None			Yes
131	B	FLEX SPACE 230, LEFT	P	None	P	None	P	None	P	None	Yes
132	B	FLEX SPACE 230, RIGHT	P	None	P	None	P	None			Yes
133	S	FLEX PSACE 204	P	None	P	None	P	None			Yes
134	B	FLEX PSACE 204, LEFT	P	None	P	None	P	None			Yes
135	B	FLEX PSACE 204, RIGHT	P	None	P	None	P	None			Yes
136	S/B	ROOM 206	P	None	P	None	P	None			Yes
137	S	ROOM 212B	P	None	P	None	P	None			Yes
140	S	ROOM 209	P	None	P	None	P	None			Yes
142	S	ROOM 215	P	None	P	None	P	None	P	None	Yes
143	S	ROOM 214	P	None	P	None	P	None	P	None	Yes
144	S	FLEX SPACE 337	P	None	P	None	P	None	P	None	Yes
145	B	FLEX SPACE 337, LEFT	P	None	P	None	P	None	P	None	Yes
146	B	FLEX SPACE 337, RIGHT	P	None	P	None	P	None			Yes
147	S/B	ROOM 331	P	None	P	None	P	None			Yes
148	S	ROOM 330, TECHER'S PREP ROOM	P	None	P	None	P	None			Yes
150	S	FLEX SPACE 326	P	None	P	None	P	None			Yes
151	B	FLEX SPACE 326, LEFT	P	None	P	None	P	None	P	None	Yes
152	B	FLEX SPACE 326, RIGHT	P	None	P	None	P	None	P	None	Yes
153	S	FLEX SPACE 316	P	None	P	None	P	None	P	None	Yes

154	B	FLEX SPACE 316, LEFT	P	None	P	None	P	None	P	None	Yes
155	B	FLEX SPACE 316, RIGHT	P	None	P	None	P	None			Yes
156	S	TEACHER'S PREP ROOM 309	P	None	P	None	P	None			Yes
158	S/B	ROOM 306	P	None	P	None	P	None			Yes
159	S	FLEX SPACE 305	P	None	P	None	P	None			Yes
160	B	FLEX SPACE 305, LEFT	P	None	P	None	P	None			Yes
161	B	FLEX SPACE 305, RIGHT	P	None	P	None	P	None	P	None	Yes
162	S	GYM CONCESSION	P	None	P	None	P	None	P	None	Yes
163	B	GYM, LEFT	P	None	P	None	P	None	P	None	Yes
164	B	GYM, RIGHT	P	None	P	None	P	None			Yes
200	B	FIRST FLOOR, COMMONS	P	None	P	None	P	None	P	None	Yes
201	B	FIRST FLOOR, COMMONS	P	None	P	None	P	None			Yes

Table 2. Lead Test Results

FIXTURE INFORMATION			7/13/2010			8/11/2010			8/31/2010			9/14/2010			7/19/2013			6/29/2016			6/4/2020			Summary Status	
Fixture ID	Type	Location	1st Draw	Flush 30s	Pass /Fail	1st Draw	Flush 30s	Pass/ Fail	1st Draw	Flush 30s	Pass /Fail	1st Draw	Flush 30s	Pass /Fail	1st Draw	Flush 30s	Pass /Fail	1st Draw	Flush 30s	Pass /Fail	1st Draw	Flush 30s	Pass /Fail	Pass /Fail	Status
101	S	PTSA, room 104	11	4		6	1	P							12	2		3	<1	P	<1	1	P	P	None
102	S	main office, room 101A	9	2	P										5	<1	P	<1	<1	P	<1	<1	P	P	None
103	S	Health center, room 106H	1	<1	P										19	2		<1	<1	P	<1	<1	P	P	None
104	S	Health center, room 106H	9	8	P										<1	<1	P	<1	<1	P	<1	<1	P	P	None
105	S	HEALTH CENTER, EXAM ROOM 106I										8	1	P	<1	<1	P	7	<1	P	3	<1	P	P	None
106	S/B	WORK ROOM 107B	4	<1	P										2	<1	P	<1	<1	P	1	<1	P	P	None
107	S	STAGE	10	1	P										35	8		2	<1	P	<1	<1	P	P	None
108	S/B	BAND ROOM 111	4	1	P										2	<1	P	<1	<1	P	2	<1	P	P	None
109	S/B	BAND ROOM 112	3	<1	P										<1	<1	P	<1	<1	P	2	<1	P	P	None
110	S	GATEWAY SHOP, ROOM 113A	9	<1	P										10	<1	P	2	<1	P	2	<1	P	P	None
111	S	KITCHEN, LEFT	<1	7	P										7	<1	P	3	<1	P	<1	<1	P	P	None
112	S	KITCHEN, RIGHT	<1	<1	P										7	<1	P	<1	<1	P	<1	<1	P	P	None
113	S	KITCHEN, MIDDLE ISLAND	2	<1	P										<1	<1	P	2	<1	P	<1	<1	P	P	None
114	S	KITCHEN	<1	1	P										4	<1	P	<1	<1	P	<1	<1	P	P	None
115	K	KITCHEN, KETTLE	<1	1	P										<1	<1	P	<1	<1	P	<1	<1	P	P	None
116	B	FIRST FLOOR HALLWAY, OUTSIDE LOCKER ROOM, LEFT	<1	1	P										2	<1	P	<1	<1	P	<1	<1	P	P	None
117	B	FIRST FLOOR HALLWAY, OUTSIDE LOCKER ROOM, RIGHT	1	<1	P										<1	<1	P	<1	<1	P	<1	<1	P	P	None
118	S	LIBRARY OFFICE, ROOM 103B	<1	3	P										13	1		4	<1	P	<1	1	P	P	None
119	B	FIRST FLOOR HALLWAY, OUTSIDE ROOM 103, LEFT	3	<1	P										1	<1	P	<1	<1	P	<1	<1	P	P	None
120	B	FIRST FLOOR HALLWAY, OUTSIDE ROOM 103, RIGHT	1	2	P										2	1	P	<1	<1	P	<1	<1	P	P	None
122	S	STAFF LOUNGE, ROOM 126	8	1	P										2	<1	P	<1	<1	P	<1	<1	P	P	None
123	S	ROOM 219	3	3	P										2	<1	P	<1	<1	P	2	<1	P	P	None
125	S	ROOM 218	4	2	P										2	<1	P	<1	<1	P	2	<1	P	P	None
127	S/B	ROOM 221	7	2	P										<1	<1	P	<1	<1	P	3	<1	P	P	None
128	S	TEACHER'S PREP ROOM 226	2	3	P										1	1	P	<1	<1	P	<1	<1	P	P	None
129	S/B	ROOM 227	6	3	P										<1	<1	P	<1	<1	P	<1	<1	P	P	None
130	S	FLEX SPACE 230	11	2		4	<1	P							8	1	P	2	<1	P	5	<1	P	P	None
131	B	FLEX SPACE 230, LEFT	2	2	P										<1	<1	P	<1	<1	P				P	None
132	B	FLEX SPACE 230, RIGHT	2	2	P													<1	<1	P	<1	<1	P	P	None
133	S	FLEX PSACE 204	2	2	P										<1	<1	P	<1	<1	P	<1	<1	P	P	None
134	B	FLEX PSACE 204, LEFT	3	1	P										2	<1	P	<1	<1	P	1	<1	P	P	None
135	B	FLEX PSACE 204, RIGHT	2	1	P										<1	<1	P	<1	<1	P	<1	<1	P	P	None
136	S/B	ROOM 206	7	2	P										2	<1	P	2	<1	P	2	<1	P	P	None
137	S	ROOM 212B	2	2	P										1	<1	P	<1	<1	P	<1	<1	P	P	None
140	S	ROOM 209	6	4	P										3	2	P	<1	<1	P	1	<1	P	P	None
142	S	ROOM 215	2	<1	P										<1	<1	P	1	<1	P	<1	<1	P	P	None
143	S	ROOM 214	2	<1	P										<1	<1	P	1	<1	P	<1	<1	P	P	None
144	S	FLEX SPACE 337	14	2		7	1	P							12	2		1	<1	P	7	<1	P	P	None
145	B	FLEX SPACE 337, LEFT	3	2	P										2	<1	P	<1	<1	P	<1	<1	P	P	None
146	B	FLEX SPACE 337, RIGHT	2	2	P										2	<1	P	<1	<1	P				P	None
147	S/B	ROOM 331	6	2	P										2	2	P	3	<1	P	2	<1	P	P	None
148	S	ROOM 330, TECHER'S PREP ROOM	12	8		10	3	P							8	2	P	2	<1	P	1	1	P	P	None
150	S	FLEX SPACE 326	2	<1	P										2	<1	P	<1	<1	P	2	<1	P	P	None
151	B	FLEX SPACE 326, LEFT	<1	<1	P										<1	<1	P	<1	<1	P	<1	<1	P	P	None
152	B	FLEX SPACE 326, RIGHT	1	<1	P										<1	<1	P	<1	<1	P	<1	<1	P	P	None
153	S	FLEX SPACE 316	3	2	P										1	<1	P	1	<1	P	<1	<1	P	P	None

154	B	FLEX SPACE 316, LEFT	2	<1	P											<1	<1	P	<1	<1	P	P	None		
155	B	FLEX SPACE 316, RIGHT	2	<1	P								<1	<1	P	<1	<1	P	<1	<1	P	P	None		
156	S	TEACHER'S PREP ROOM 309	2	3	P								2	1	P	<1	<1	P	<1	<1	P	P	None		
158	S/B	ROOM 306	5	<1	P								2	3	P	<1	<1	P	<1	<1	P	P	None		
159	S	FLEX SPACE 305	5	1	P								1	<1	P	<1	<1	P	1	<1	P	P	None		
160	B	FLEX SPACE 305, LEFT	2	<1	P											<1	<1	P	<1	<1	P	P	None		
161	B	FLEX SPACE 305, RIGHT	3	8	P								<1	<1	P	<1	<1	P	<1	<1	P	P	None		
162	S	GYM CONCESSION	8	5	P								14	2		5	<1	P	<1	<1	P	P	None		
163	B	GYM, LEFT	1	1	P								2	<1	P	<1	<1	P	<1	<1	P	P	None		
164	B	GYM, RIGHT	1	<1	P								2	<1	P	<1	<1	P				P	None		
200	B	FIRST FLOOR, COMMONS	2	31		11	34		4	6	P				2	2	P	<1	<1	P	<1	2	P	P	None
201	B	FIRST FLOOR, COMMONS	<1	1	P											<1	<1	P	<1	<1	P	<1	None		

Table 3. Cadmium Test Results

FIXTURE INFORMATION			7/13/2010			8/11/2010			7/19/2013			6/29/2016			6/4/2020			Summary Status	
Fixture ID	Type	Location	1st Draw	Flush 30s	Pass /Fail	1st Draw	Flush 30s	Pass /Fail	1st Draw	Flush 30s	Pass /Fail	1st Draw	Flush 30s	Pass /Fail	1st Draw	Flush 30s	Pass /Fail	Pass/Fail	Status
101	S	PTSA, room 104	<1	<1	P				<1	<1	P	<1	<1	P	<1	<1	P	P	None
102	S	main office, room 101A	<1	<1	P				<1	<1	P	<1	<1	P	<1	<1	P	P	None
103	S	Health center, room 106H	<1	<1	P				<1	<1	P	<1	<1	P	<1	<1	P	P	None
104	S	Health center, room 106H	<1	<1	P				<1	<1	P	<1	<1	P	<1	<1	P	P	None
105	S	HEALTH CENTER, EXAM ROOM 106I							<1	<1	P	<1	<1	P	<1	<1	P	P	None
106	S/B	WORK ROOM 107B	<1	<1	P				<1	<1	P	<1	<1	P	<1	<1	P	P	None
107	S	STAGE	<1	<1	P				<1	<1	P	<1	<1	P	<1	<1	P	P	None
108	S/B	BAND ROOM 111	<1	<1	P				<1	<1	P	<1	<1	P	<1	<1	P	P	None
109	S/B	BAND ROOM 112	<1	<1	P				<1	<1	P	<1	<1	P	<1	<1	P	P	None
110	S	GATEWAY SHOP, ROOM 113A	<1	<1	P				<1	<1	P	<1	<1	P	<1	<1	P	P	None
111	S	KITCHEN, LEFT	<1	<1	P				<1	<1	P	<1	<1	P	<1	<1	P	P	None
112	S	KITCHEN, RIGHT	7	<1		<1	1	P	2	<1	P	<1	<1	P	<1	<1	P	P	None
113	S	KITCHEN, MIDDLE ISLAND	<1	<1	P				<1	<1	P	<1	<1	P	<1	<1	P	P	None
114	S	KITCHEN	<1	<1	P				<1	<1	P	<1	<1	P	<1	<1	P	P	None
115	K	KITCHEN, KETTLE	<1	<1	P				<1	<1	P	<1	<1	P	<1	<1	P	P	None
116	B	FIRST FLOOR HALLWAY, OUTSIDE LOCKER ROOM, LEFT	<1	<1	P				<1	<1	P	<1	<1	P	<1	<1	P	P	None
117	B	FIRST FLOOR HALLWAY, OUTSIDE LOCKER ROOM, RIGHT	<1	<1	P				<1	<1	P	<1	<1	P	<1	<1	P	P	None
118	S	LIBRARY OFFICE, ROOM 103B	<1	<1	P				<1	<1	P	<1	<1	P	<1	<1	P	P	None
119	B	FIRST FLOOR HALLWAY, OUTSIDE ROOM 103, LEFT	<1	<1	P				<1	<1	P	<1	<1	P	<1	<1	P	P	None
120	B	FIRST FLOOR HALLWAY, OUTSIDE ROOM 103, RIGHT	<1	<1	P				<1	<1	P	<1	<1	P	<1	<1	P	P	None
122	S	STAFF LOUNGE, ROOM 126	<1	<1	P				<1	<1	P	<1	<1	P	<1	<1	P	P	None
123	S	ROOM 219	<1	<1	P				<1	<1	P	<1	<1	P	<1	<1	P	P	None
125	S	ROOM 218	<1	<1	P				<1	<1	P	<1	<1	P	<1	<1	P	P	None
127	S/B	ROOM 221	<1	<1	P				<1	<1	P	<1	<1	P	<1	<1	P	P	None
128	S	TEACHER'S PREP ROOM 226	<1	<1	P				<1	<1	P	<1	<1	P	<1	<1	P	P	None
129	S/B	ROOM 227	<1	<1	P				<1	<1	P	<1	<1	P	<1	<1	P	P	None
130	S	FLEX SPACE 230	<1	<1	P				<1	<1	P	<1	<1	P	<1	<1	P	P	None
131	B	FLEX SPACE 230, LEFT	<1	<1	P				<1	<1	P	<1	<1	P				P	None
132	B	FLEX SPACE 230, RIGHT	<1	<1	P				<1	<1	P	<1	<1	P	<1	<1	P	P	None
133	S	FLEX PSACE 204	<1	<1	P				<1	<1	P	<1	<1	P	<1	<1	P	P	None
134	B	FLEX PSACE 204, LEFT	<1	<1	P				<1	<1	P	<1	<1	P	<1	<1	P	P	None
135	B	FLEX PSACE 204, RIGHT	<1	<1	P				<1	<1	P	<1	<1	P	<1	<1	P	P	None
136	S/B	ROOM 206	<1	<1	P				<1	<1	P	<1	<1	P	<1	<1	P	P	None
137	S	ROOM 212B	<1	<1	P				<1	<1	P	<1	<1	P	<1	<1	P	P	None
140	S	ROOM 209	<1	<1	P				<1	<1	P	<1	<1	P	<1	<1	P	P	None
142	S	ROOM 215	<1	<1	P				<1	<1	P	<1	<1	P	<1	<1	P	P	None
143	S	ROOM 214	<1	<1	P				<1	<1	P	<1	<1	P	<1	<1	P	P	None
144	S	FLEX SPACE 337	<1	<1	P				<1	<1	P	<1	<1	P	<1	<1	P	P	None
145	B	FLEX SPACE 337, LEFT	<1	<1	P				<1	<1	P	<1	<1	P	<1	<1	P	P	None
146	B	FLEX SPACE 337, RIGHT	<1	<1	P				<1	<1	P	<1	<1	P				P	None
147	S/B	ROOM 331	<1	<1	P				<1	<1	P	<1	<1	P	<1	<1	P	P	None
148	S	ROOM 330, TECHER'S PREP ROOM	<1	<1	P	<1	<1	P	<1	<1	P	<1	<1	P	<1	<1	P	P	None
150	S	FLEX SPACE 326	<1	<1	P				<1	<1	P	<1	<1	P	<1	<1	P	P	None
151	B	FLEX SPACE 326, LEFT	<1	<1	P				<1	<1	P	<1	<1	P	<1	<1	P	P	None
152	B	FLEX SPACE 326, RIGHT	<1	<1	P				<1	<1	P	<1	<1	P	<1	<1	P	P	None
153	S	FLEX SPACE 316	<1	<1	P				<1	<1	P	<1	<1	P	<1	<1	P	P	None

154	B	FLEX SPACE 316, LEFT	<1	<1	P							<1	<1	P	<1	<1	P	P	None
155	B	FLEX SPACE 316, RIGHT	<1	<1	P				<1	<1	P	<1	<1	P	<1	<1	P	P	None
156	S	TEACHER'S PREP ROOM 309	<1	<1	P				<1	<1	P	<1	<1	P	<1	<1	P	P	None
158	S/B	ROOM 306	<1	<1	P				<1	<1	P	<1	<1	P	<1	<1	P	P	None
159	S	FLEX SPACE 305	<1	<1	P				<1	<1	P	<1	<1	P	<1	<1	P	P	None
160	B	FLEX SPACE 305, LEFT	<1	<1	P							<1	<1	P	<1	<1	P	P	None
161	B	FLEX SPACE 305, RIGHT	<1	<1	P				<1	<1	P	<1	<1	P	<1	<1	P	P	None
162	S	GYM CONCESSION	<1	<1	P				<1	<1	P	<1	<1	P	<1	<1	P	P	None
163	B	GYM, LEFT	<1	<1	P				<1	<1	P	<1	<1	P	<1	<1	P	P	None
164	B	GYM, RIGHT	<1	<1	P				<1	<1	P	<1	<1	P				P	None
200	B	FIRST FLOOR, COMMONS	<1	<1	P				<1	<1	P	<1	<1	P	<1	<1	P	P	None
201	B	FIRST FLOOR, COMMONS	<1	<1	P				<1	<1	P	<1	<1	P	<1	<1	P	P	None

Table 4. Copper Test Results

FIXTURE INFORMATION			7/13/2010			8/11/2010			7/19/2013			6/29/2016			6/4/2020			Summary Status	
Fixture ID	Type	Location	1st Draw	Flush 30s	Pass /Fail	1st Draw	Flush 30s	Pass /Fail	1st Draw	Flush 30s	Pass /Fail	1st Draw	Flush 30s	Pass /Fail	1st Draw	Flush 30s	Pass /Fail	Pass/Fail	Status
101	S	PTSA, room 104	0.387	0.56	P				0.612	0.762	P	0.188	0.21	P	0.211	0.249	P	P	None
102	S	main office, room 101A	0.351	0.326	P				0.265	0.249	P	0.167	0.171	P	0.28	0.238	P	P	None
103	S	Health center, room 106H	0.319	0.242	P				0.275	0.368	P	0.174	0.184	P	0.222	0.324	P	P	None
104	S	Health center, room 106H	0.494	0.516	P				0.147	0.167	P	0.163	0.16	P	0.31	0.413	P	P	None
105	S	HEALTH CENTER, EXAM ROOM 106I							0.152	0.118	P	0.202	0.208	P	0.293	0.415	P	P	None
106	S/B	WORK ROOM 107B	0.339	0.341	P				0.197	0.187	P	0.184	0.165	P	0.328	0.314	P	P	None
107	S	STAGE	0.4	0.157	P				0.124	0.126	P	0.175	0.089	P	0.236	0.155	P	P	None
108	S/B	BAND ROOM 111	0.382	0.651	P				0.218	0.223	P	0.192	0.197	P	0.312	0.343	P	P	None
109	S/B	BAND ROOM 112	0.418	0.576	P				0.224	0.222	P	0.358	0.318	P	0.306	0.294	P	P	None
110	S	GATEWAY SHOP, ROOM 113A	0.254	0.103	P				0.17	0.222	P	0.093	0.075	P	0.278	0.242	P	P	None
111	S	KITCHEN, LEFT	0.518	0.573	P				0.1	0.166	P	0.176	0.158	P	0.253	0.166	P	P	None
112	S	KITCHEN, RIGHT	0.153	0.601	P				0.107	0.155	P	0.184	0.123	P	0.284	0.182	P	P	None
113	S	KITCHEN, MIDDLE ISLAND	0.482	0.475	P				0.242	0.218	P	0.14	0.152	P	0.346	0.235	P	P	None
114	S	KITCHEN	0.337	0.611	P				0.198	0.212	P	0.203	0.111	P	0.316	0.256	P	P	None
115	K	KITCHEN, KETTLE	0.329	0.374	P				0.248	0.236	P	0.223	0.203	P	0.323	0.266	P	P	None
116	B	FIRST FLOOR HALLWAY, OUTSIDE LOCKER ROOM, LEFT	0.298	0.201	P				0.19	0.14	P	0.149	0.091	P	0.319	0.32	P	P	None
117	B	FIRST FLOOR HALLWAY, OUTSIDE LOCKER ROOM, RIGHT	0.282	0.177	P				0.163	0.125	P	0.162	0.101	P	0.294	0.311	P	P	None
118	S	LIBRARY OFFICE, ROOM 103B	0.253	0.252	P				0.285	0.403	P	0.204	0.225	P	0.276	0.278	P	P	None
119	B	FIRST FLOOR HALLWAY, OUTSIDE ROOM 103, LEFT	0.496	0.522	P				0.207	0.206	P	0.203	0.176	P	0.284	0.275	P	P	None
120	B	FIRST FLOOR HALLWAY, OUTSIDE ROOM 103, RIGHT	0.52	0.39	P				0.215	0.2	P	0.18	0.185	P	0.28	0.264	P	P	None
122	S	STAFF LOUNGE, ROOM 126	0.45	0.524	P				0.27	0.19	P	0.174	0.169	P	0.301	0.29	P	P	None
123	S	ROOM 219	0.325	0.351	P				0.196	0.171	P	0.187	0.174	P	0.394	0.298	P	P	None
125	S	ROOM 218	0.278	0.306	P				0.279	0.191	P	0.176	0.17	P	0.311	0.252	P	P	None
127	S/B	ROOM 221	0.512	0.34	P				0.182	0.066	P	0.192	0.13	P	0.387	0.192	P	P	None
128	S	TEACHER'S PREP ROOM 226	0.345	0.386	P				0.159	0.174	P	0.194	0.163	P	0.323	0.262	P	P	None
129	S/B	ROOM 227	0.45	0.425	P				0.165	0.121	P	0.173	0.115	P	0.283	0.217	P	P	None
130	S	FLEX SPACE 230	0.314	0.282	P				0.182	0.195	P	0.136	0.134	P	0.258	0.244	P	P	None
131	B	FLEX SPACE 230, LEFT	0.385	0.312	P				0.257	0.196	P	0.164	0.145	P				P	None
132	B	FLEX SPACE 230, RIGHT	0.309	0.28	P							0.136	0.12	P	0.272	0.245	P	P	None
133	S	FLEX PSACE 204	0.345	0.326	P				0.191	0.183	P	0.147	0.145	P	0.297	0.31	P	P	None
134	B	FLEX PSACE 204, LEFT	0.519	0.334	P				0.277	0.167	P	0.169	0.143	P	0.289	0.288	P	P	None
135	B	FLEX PSACE 204, RIGHT	0.343	0.329	P				0.114	0.076	P	0.216	0.17	P	0.333	0.336	P	P	None
136	S/B	ROOM 206	0.44	0.335	P				0.2	0.168	P	0.192	0.15	P	0.304	0.347	P	P	None
137	S	ROOM 212B	0.302	0.579	P				0.227	0.21	P	0.174	0.191	P	0.46	0.475	P	P	None
140	S	ROOM 209	0.404	0.431	P				0.222	0.329	P	0.253	0.183	P	0.374	0.368	P	P	None
142	S	ROOM 215	0.404	0.48	P				0.073	0.072	P	0.372	0.266	P	0.288	0.252	P	P	None
143	S	ROOM 214	0.347	0.5	P				0.073	0.073	P	0.295	0.224	P	0.269	0.3	P	P	None
144	S	FLEX SPACE 337	0.249	0.293	P				0.331	0.264	P	0.178	0.131	P	0.311	0.281	P	P	None
145	B	FLEX SPACE 337, LEFT	0.527	0.306	P				0.206	0.291	P	0.209	0.168	P	0.324	0.362	P	P	None
146	B	FLEX SPACE 337, RIGHT	0.282	0.272	P				0.108	0.084	P	0.13	0.116	P				P	None
147	S/B	ROOM 331	0.313	0.303	P				0.161	0.16	P	0.168	0.117	P	0.498	0.514	P	P	None
148	S	ROOM 330, TECHER'S PREP ROOM	0.257	0.453	P	0.571	0.663	P	0.218	0.242	P	0.179	0.228	P	0.394	0.362	P	P	None
150	S	FLEX SPACE 326	0.363	0.58	P				0.573	0.445	P	0.18	0.158	P	0.282	0.258	P	P	None
151	B	FLEX SPACE 326, LEFT	0.469	0.547	P				0.26	0.244	P	0.212	0.162	P	0.351	0.255	P	P	None
152	B	FLEX SPACE 326, RIGHT	0.426	0.547	P				0.165	0.096	P	0.176	0.167	P	0.299	0.272	P	P	None
153	S	FLEX SPACE 316	0.326	0.57	P				0.291	0.257	P	0.289	0.236	P	0.273	0.275	P	P	None

154	B	FLEX SPACE 316, LEFT	0.511	0.474	P						0.312	0.189	P	0.279	0.27	P	P	None
155	B	FLEX SPACE 316, RIGHT	0.49	0.582	P			0.287	0.258	P	0.276	0.192	P	0.349	0.334	P	P	None
156	S	TEACHER'S PREP ROOM 309	0.261	0.372	P			0.217	0.285	P	0.171	0.216	P	0.46	0.581	P	P	None
158	S/B	ROOM 306	0.411	0.312	P			0.171	0.148	P	0.191	0.133	P	0.248	0.351	P	P	None
159	S	FLEX SPACE 305	0.211	0.265	P			0.111	0.106	P	0.13	0.135	P	0.301	0.336	P	P	None
160	B	FLEX SPACE 305, LEFT	0.323	0.285	P						0.217	0.154	P	0.3	0.328	P	P	None
161	B	FLEX SPACE 305, RIGHT	0.516	0.393	P			0.279	0.198	P	0.193	0.142	P	0.288	0.302	P	P	None
162	S	GYM CONCESSION	0.403	0.414	P			0.169	0.426	P	0.172	0.183	P	0.262	0.146	P	P	None
163	B	GYM, LEFT	0.388	0.387	P			0.252	0.428	P	0.238	0.164	P	0.191	0.225	P	P	None
164	B	GYM, RIGHT	0.335	0.342	P			0.245	0.236	P	0.291	0.238	P				P	None
200	B	FIRST FLOOR, COMMONS	0.584	0.522	P			0.226	0.221	P	0.228	0.22	P	0.296	0.303	P	P	None

Table 5. Iron Test Results

FIXTURE INFORMATION			7/13/2010		7/19/2013		6/29/2016		6/4/2020		Summary Status	
Fixture ID	Type	Location	Flush 2m	Pass/Fail	Flush 2m	Pass/Fail	Flush 2m	Pass/Fail	Flush 2m	Pass/Fail	Pass/Fail	Status
101	S	PTSA, room 104										
102	S	main office, room 101A	0.067	P							P	None
103	S	Health center, room 106H			0.094	P					P	None
104	S	Health center, room 106H					<0.05	P			P	None
105	S	HEALTH CENTER, EXAM ROOM 106I							0.098	P	P	None
106	S/B	WORK ROOM 107B										
107	S	STAGE										
108	S/B	BAND ROOM 111										
109	S/B	BAND ROOM 112	0.052	P							P	None
110	S	GATEWAY SHOP, ROOM 113A			0.092	P					P	None
111	S	KITCHEN, LEFT					0.059	P			P	None
112	S	KITCHEN, RIGHT							0.114	P	P	None
113	S	KITCHEN, MIDDLE ISLAND										
114	S	KITCHEN										
115	K	KITCHEN, KETTLE										
116	B	FIRST FLOOR HALLWAY, OUTSIDE LOCKER ROOM, LEFT										
117	B	FIRST FLOOR HALLWAY, OUTSIDE LOCKER ROOM, RIGHT										
118	S	LIBRARY OFFICE, ROOM 103B										
119	B	FIRST FLOOR HALLWAY, OUTSIDE ROOM 103, LEFT										
120	B	FIRST FLOOR HALLWAY, OUTSIDE ROOM 103, RIGHT										
122	S	STAFF LOUNGE, ROOM 126	0.054	P							P	None
123	S	ROOM 219			0.069	P					P	None
125	S	ROOM 218					<0.05	P			P	None
127	S/B	ROOM 221							0.086	P	P	None
128	S	TEACHER'S PREP ROOM 226										
129	S/B	ROOM 227										
130	S	FLEX SPACE 230										
131	B	FLEX SPACE 230, LEFT	0.065	P							P	None
132	B	FLEX SPACE 230, RIGHT										
133	S	FLEX PSACE 204										
134	B	FLEX PSACE 204, LEFT										
135	B	FLEX PSACE 204, RIGHT										
136	S/B	ROOM 206										
137	S	ROOM 212B										
140	S	ROOM 209										
142	S	ROOM 215	0.053	P							P	None
143	S	ROOM 214			0.088	P					P	None
144	S	FLEX SPACE 337					<0.05	P			P	None
145	B	FLEX SPACE 337, LEFT							0.091	P	P	None
146	B	FLEX SPACE 337, RIGHT										
147	S/B	ROOM 331										
148	S	ROOM 330, TEACHER'S PREP ROOM										
150	S	FLEX SPACE 326										
151	B	FLEX SPACE 326, LEFT	0.059	P							P	None
152	B	FLEX SPACE 326, RIGHT			0.085	P					P	None
153	S	FLEX SPACE 316					<0.05	P			P	None
154	B	FLEX SPACE 316, LEFT							0.075	P	P	None
155	B	FLEX SPACE 316, RIGHT										

156	S	TEACHER'S PREP ROOM 309									
158	S/B	ROOM 306									
159	S	FLEX SPACE 305									
160	B	FLEX SPACE 305, LEFT									
161	B	FLEX SPACE 305, RIGHT	0.054	P						P	None
162	S	GYM CONCESSION			0.098	P				P	None
163	B	GYM, LEFT	0.056	P			<0.05	P		P	None
164	B	GYM, RIGHT									
200	B	FIRST FLOOR, COMMONS			0.086	P				P	None
201	B	FIRST FLOOR, COMMONS									

Table 6. Service Entry Test Results

Test Results (Service Entry/SE, Units as Shown)						
SOURCE INFORMATION			Most Recent Sampling			
Fixture ID	Type	Location	Item	Sampled	Max Value	Pass/Fail
100	SE	Custodial work room B002	Arsenic	04-Jun-20	2 ppb	P
100	SE	Custodial work room B002	Cadmium	04-Jun-20	1 ppb	P
100	SE	Custodial work room B002	Copper	04-Jun-20	0.309 ppm	P
100	SE	Custodial work room B002	Iron	04-Jun-20	0.088 ppm	P
100	SE	Custodial work room B002	Lead	04-Jun-20	1 ppb	P
100	SE	Custodial work room B002	Total Coliforms	13-Jul-10	<1 Colonies	P

"<" means: less than the value shown (below analytical detection limits).

"n/a" means: not applicable.

Table 7. Bacteriological Test Results

Bacteriological Characteristics

Bacteriological testing of selected samples indicated no (zero) coliform bacteria.