

**Seattle Public Schools
Drinking Water Quality Program**

**Results of Water Quality Testing
for
Lincoln High School**

Updated September 3, 2019

General Information:

Plumbing piping materials: mixed galvanized steel and copper

Remediation plan:

This remediation plan is based on a Water Quality policy approved by the School Board. The policy includes standards for the presence of lead, cadmium, copper, iron and other substances in drinking water.

Sinks (S in the report) are not considered drinking water sources. We recognize that there is the potential for students to want to drink from classroom hand-washing sinks, so we test all of those. Where a student's choice to drink from a sink could be a problem, we post a reminder sign, as we do at all restroom sinks.

Status:

Policy Criteria: All sources meet the policy criteria.

Drinking fountain by east side of the main gym (#56) will be tested after fixing the water pressure.

Follow-up monitoring: Will be performed in school year 2021-2022.

Service: The school will be flushed after any breaks longer than five days.

Water Quality Testing Results:

Legend

Symbol	Definition
SE	service entry (main)
B	bubbler
S	sink (faucet)
B/S	sink/bubbler combination
S/B	sink/bubbler combination
ppb	parts per billion
ppm	parts per million
NA	not applicable
None	no action required
Unk	unknown status or action
Sample	sample needs to be taken
Re-test	fixture needs to be resampled
Conf	resample to confirm measurement
No flush	not flushed before sampling
Sink	sampled faucet of S/B combo
Used	recently used; no 1st draw sample possible
PS	post sign
Disable(d)	fixture disabled in response to water quality testing
BDSS	Bubbler disabled, sign on sink
IF	install filter
RB	replace bubbler
RB/IF	replace bubbler and/or install filter
RF	replace faucet
RF/IF	replace faucet and/or install filter
BW	disable fixture and provide bottled water until remediated
Leaks	leaking fixture
NW	not working properly (sample S when B or S/B NW)
OS	out of service - disabled until fixed
RS	return to service - now passes testing
Rem	Removed from system - no longer exists

Table 1. Summary of Results

FIXTURE INFORMATION			LEAD		CADMIUM		COPPER		IRON		OK?
Fixture ID	Type	Location	Pass/Fail	Status	Pass/Fail	Status	Pass/Fail	Status	Pass/Fail	Status	Yes/No/Status
01	B	BASEMENT DRINKING FOUNTAIN, LEFT	P	None	P	None	P	None			Yes
02	B	BASEMENT DRINKING FOUNTAIN, RIGHT	P	None	P	None	P	None			Yes
03	BF	BASEMENT BOTTLE FILLER	P	None	P	None	P	None	P	None	Yes
04	B	FIRST FLOOR, DRINKING FOUNTAIN, SOUTH WING, LEFT	P	None	P	None	P	None			Yes
05	B	FIRST FLOOR, DRINKING FOUNTAIN, SOUTH WING, RIGHT	P	None	P	None	P	None			Yes
06	BF	FIRST FLOOR, BOTTLE FILLER, SOUTH WING	P	None	P	None	P	None			Yes
07	S	NURSE OFFICE	P	None	P	None	P	None			Yes
08	S	NURSE OFFICE, room C132J	P	None	P	None	P	None			Yes
09	S	OFFICE WORKROOM	P	None	P	None	P	None	P	None	Yes
10	S	KITCHEN	P	None	P	None	P	None			Yes
11	S	KITCHEN, LEFT	P	None	P	None	P	None			Yes
12	S	KITCHEN, RIGHT	P	None	P	None	P	None			Yes
14	K	KITCHEN, KETTLE	P	None	P	None	P	None			Yes
15	S	KITCHEN	P	None	P	None	P	None	P	None	Yes
16	S	KITCHEN, LEFT	P	None	P	None	P	None			Yes
17	S	KITCHEN, RIGHT	P	None	P	None	P	None			Yes
18	S	N121 CUSTODIAL BREAK ROOM	P	None	P	None	P	None			Yes
19	BF	FIRST FLOOR, BOTTLE FILLER, NORTH WING	P	None	P	None	P	None			Yes
20	B	FIRST FLOOR, NORTH WING, DRINKING FOUNTAIN, LEFT	P	None	P	None	P	None			Yes
21	B	FIRST FLOOR, NORTH WING, DRINKING FOUNTAIN, RIGHT	P	None	P	None	P	None	P	None	Yes
22	S	ROOM 113	P	None	P	None	P	None			Yes
23	S	ROOM 111	P	None	P	None	P	None			Yes
25	S	ROOM 243A	P	None	P	None	P	None			Yes
26	B	SECOND FLOOR, MIDDLE WING, DRINKING FOUNTAIN, LEFT	P	None	P	None	P	None			Yes
27	B	SECOND FLOOR, MIDDLE WING, DRINKING FOUNTAIN, RIGHT	P	None	P	None	P	None	P	None	Yes
28	BF	SECOND FLOOR, MIDDLE WING, BOTTLE FILLER	P	None	P	None	P	None			Yes
29	S	ROOM 268	P	None	P	None	P	None			Yes
30	B	SECOND FLOOR, SOUTH WING, DRINKING FOUNTAIN, LEFT	P	None	P	None	P	None			Yes
31	B	SECOND FLOOR, SOUTH WING, DRINKING FOUNTAIN, RIGHT	P	None	P	None	P	None			Yes
32	BF	SECOND FLOOR, SOUTH WING, BOTTLE FILLER	P	None	P	None	P	None			Yes
33	S	ROOM 345	P	None	P	None	P	None	P	None	Yes
34	B	THIRD FLOOR, MIDDLE WING, DRINKING FOUNTAIN, LEFT	P	None	P	None	P	None			Yes
35	B	THIRD FLOOR, MIDDLE WING, DRINKING FOUNTAIN, RIGHT	P	None	P	None	P	None			Yes
36	BF	THIRD FLOOR, MIDDLE WING, BOTTLE FILLER	P	None	P	None	P	None			Yes
37	S	ROOM 334	P	None	P	None	P	None			Yes
38	S	ROOM 361	P	None	P	None	P	None			Yes
39	S	ROOM 369	P	None	P	None	P	None			Yes
40	B	THIRD FLOOR, SOUTH WING, DRINKING FOUNTAIN, LEFT	P	None	P	None	P	None			Yes
41	B	THIRD FLOOR, SOUTH WING, DRINKING FOUNTAIN, RIGHT	P	None	P	None	P	None	P	None	Yes
42	BF	THIRD FLOOR, SOUTH WING, BOTTLE FILLER	P	None	P	None	P	None			Yes
43	S	ROOM 445	P	None	P	None	P	None			Yes
44	B	FOURTH FLOOR, DRINKING FOUNTAIN, LEFT	P	None	P	None	P	None			Yes
45	B	FOURTH FLOOR, DRINKING FOUNTAIN, RIGHT	P	None	P	None	P	None			Yes
46	BF	FOURTH FLOOR, BOTTLE FILLER	P	None	P	None	P	None			Yes
47	S	ROOM 452	P	None	P	None	P	None	P	None	Yes

48	S	ROOM 433	P	None	P	None	P	None			Yes
49	B	MAIN GYM, SOUTH, DRINKING FOUNTAIN, LEFT	P	None	P	None	P	None			Yes
50	B	MAIN GYM, SOUTH, DRINKING FOUNTAIN, RIGHT	P	None	P	None	P	None			Yes
51	BF	MAIN GYM, SOUTH, BOTTLE FILLER	P	None	P	None	P	None			Yes
52	B	MAIN GYM, NORTH, DRINKING FOUNTAIN, LEFT	P	None	P	None	P	None			Yes
53	B	MAIN GYM, NORTH, DRINKING FOUNTAIN, RIGHT	P	None	P	None	P	None			Yes
54	BF	MAIN GYM, NORTH, BOTTLE FILLER	P	None	P	None	P	None			Yes
55	B	MAIN GYM, EAST, DRINKING FOUNTAIN, LEFT	P	None	P	None	P	None			Yes
56	B	MAIN GYM, EAST, DRINKING FOUNTAIN, MIDDLE		Sample		Sample		Sample			Sample
57	B	MAIN GYM, EAST, DRINKING FOUNTAIN, RIGHT	P	None	P	None	P	None	P	None	Yes
59	B	DRINKING FOUNTAIN, OUTSIDE BOYS LOCKER ROOM	P	None	P	None	P	None			Yes
60	B	BOYS LOCKER ROOM	P	None	P	None	P	None			Yes
62	B	DRINKING FOUNTAIN OUTSIDE AUDITORIUM, LEFT	P	None	P	None					Yes
63	B	DRINKING FOUNTAIN OUTSIDE AUDITORIUM, MIDDLE	P	None	P	None	P	None			Yes
64	B	DRINKING FOUNTAIN OUTSIDE AUDITORIUM, RIGHT	P	None	P	None	P	None			Yes
65	S	STAGE	P	None	P	None	P	None			Yes
66	S	C111	P	None	P	None	P	None			Yes
67	B	PERFORMING ARTS CORRIDOR	P	None	P	None	P	None			Yes
68	B	DRINKING FOUNTAIN OUTSIDE c109	P	None	P	None	P	None	P	None	Yes
70	S	KITCHEN	P	None	P	None	P	None			Yes
71	S	ROOM C116	P	None	P	None	P	None			Yes
72	S	ROOM C116	P	None	P	None	P	None			Yes
73	S	ROOM C116	P	None	P	None	P	None			Yes
74	S	ROOM C116	P	None	P	None	P	None			Yes
75	S	ROOM C116	P	None	P	None	P	None			Yes
76	S	ROOM C116	P	None	P	None	P	None	P	None	Yes
77	S	ROOM C116	P	None	P	None	P	None			Yes
80	S	EXAM ROOM C132G	P	None	P	None	P	None			Yes
81	S	EXAM ROOM C132F	P	None	P	None	P	None			Yes
82	S	N101, STAFF PLANNING	P	None	P	None	P	None			Yes
83	S	ROOM C352	P	None	P	None	P	None			Yes
84	S	ROOM C116	P	None	P	None	P	None			Yes

Table 2. Lead Test Results

Test Results (Lead/Pb, ppb)										
FIXTURE INFORMATION			7/31/2019			8/20/2019			Summary Status	
Fixture ID	Type	Location	1st Draw	Flush 30s	Pass/Fail	1st Draw	Flush 30s	Pass/Fail	Pass/Fail	Status
01	B	BASEMENT DRINKING FOUNTAIN, LEFT	<1	<1	P				P	None
02	B	BASEMENT DRINKING FOUNTAIN, RIGHT	<1	1	P				P	None
03	BF	BASEMENT BOTTLE FILLER	<1	1	P				P	None
04	B	FIRST FLOOR, DRINKING FOUNTAIN, SOUTH WING, LEFT	<1	<1	P				P	None
05	B	FIRST FLOOR, DRINKING FOUNTAIN, SOUTH WING, RIGHT	<1	<1	P				P	None
06	BF	FIRST FLOOR, BOTTLE FILLER, SOUTH WING	<1	<1	P				P	None
07	S	NURSE OFFICE	<1	<1	P				P	None
08	S	NURSE OFFICE, room C132J	<1	<1	P				P	None
09	S	OFFICE WORKROOM	1	<1	P				P	None
10	S	KITCHEN	2	<1	P				P	None
11	S	KITCHEN, LEFT	<1	<1	P				P	None
12	S	KITCHEN, RIGHT	<1	<1	P				P	None
14	K	KITCHEN, KETTLE	<1	<1	P				P	None
15	S	KITCHEN	1	<1	P				P	None
16	S	KITCHEN, LEFT	<1	<1	P				P	None
17	S	KITCHEN, RIGHT	<1	<1	P				P	None
18	S	N121 CUSTODIAL BREAK ROOM	1	<1	P				P	None
19	BF	FIRST FLOOR, BOTTLE FILLER, NORTH WING	<1	<1	P				P	None
20	B	FIRST FLOOR, NORTH WING, DRINKING FOUNTAIN, LEFT	<1	<1	P				P	None
21	B	FIRST FLOOR, NORTH WING, DRINKING FOUNTAIN, RIGHT	<1	<1	P				P	None
22	S	ROOM 113	1	<1	P				P	None
23	S	ROOM 111	<1	<1	P				P	None
25	S	ROOM 243A	1	<1	P				P	None
26	B	SECOND FLOOR, MIDDLE WING, DRINKING FOUNTAIN, LEFT	<1	<1	P				P	None
27	B	SECOND FLOOR, MIDDLE WING, DRINKING FOUNTAIN, RIGHT	<1	<1	P				P	None
28	BF	SECOND FLOOR, MIDDLE WING, BOTTLE FILLER	<1	<1	P				P	None
29	S	ROOM 268	<1	<1	P				P	None
30	B	SECOND FLOOR, SOUTH WING, DRINKING FOUNTAIN, LEFT	<1	<1	P				P	None
31	B	SECOND FLOOR, SOUTH WING, DRINKING FOUNTAIN, RIGHT	<1	<1	P				P	None
32	BF	SECOND FLOOR, SOUTH WING, BOTTLE FILLER	<1	<1	P				P	None
33	S	ROOM 345	<1	<1	P				P	None
34	B	THIRD FLOOR, MIDDLE WING, DRINKING FOUNTAIN, LEFT	<1	<1	P				P	None
35	B	THIRD FLOOR, MIDDLE WING, DRINKING FOUNTAIN, RIGHT	<1	<1	P				P	None
36	BF	THIRD FLOOR, MIDDLE WING, BOTTLE FILLER	<1	<1	P				P	None
37	S	ROOM 334	<1	<1	P				P	None
38	S	ROOM 361	<1	<1	P				P	None
39	S	ROOM 369	<1	<1	P				P	None
40	B	THIRD FLOOR, SOUTH WING, DRINKING FOUNTAIN, LEFT	<1	<1	P				P	None
41	B	THIRD FLOOR, SOUTH WING, DRINKING FOUNTAIN, RIGHT	<1	<1	P				P	None
42	BF	THIRD FLOOR, SOUTH WING, BOTTLE FILLER	<1	<1	P				P	None
43	S	ROOM 445	1	<1	P				P	None
44	B	FOURTH FLOOR, DRINKING FOUNTAIN, LEFT	<1	<1	P				P	None
45	B	FOURTH FLOOR, DRINKING FOUNTAIN, RIGHT	<1	<1	P				P	None
46	BF	FOURTH FLOOR, BOTTLE FILLER	<1	<1	P				P	None
47	S	ROOM 452	1	<1	P				P	None
48	S	ROOM 433	1	<1	P				P	None
49	B	MAIN GYM, SOUTH, DRINKING FOUNTAIN, LEFT	<1	<1	P				P	None

50	B	MAIN GYM, SOUTH, DRINKING FOUNTAIN, RIGHT	<1	<1	P				P	None
51	BF	MAIN GYM, SOUTH, BOTTLE FILLER	<1	<1	P				P	None
52	B	MAIN GYM, NORTH, DRINKING FOUNTAIN, LEFT	<1	<1	P				P	None
53	B	MAIN GYM, NORTH, DRINKING FOUNTAIN, RIGHT	<1	<1	P				P	None
54	BF	MAIN GYM, NORTH, BOTTLE FILLER	<1	<1	P				P	None
55	B	MAIN GYM, EAST, DRINKING FOUNTAIN, LEFT	<1	<1	P				P	None
56	B	MAIN GYM, EAST, DRINKING FOUNTAIN, MIDDLE								Sanoke
57	B	MAIN GYM, EAST, DRINKING FOUNTAIN, RIGHT	<1	<1	P				P	None
59	B	DRINKING FOUNTAIN, OUTSIDE BOYS LOCKER ROOM	<1	<1	P				P	None
60	B	BOYS LOCKER ROOM	<1	<1	P				P	None
62	B	DRINKING FOUNTAIN OUTSIDE AUDITORIUM, LEFT				<1	8	P	P	None
63	B	DRINKING FOUNTAIN OUTSIDE AUDITORIUM, MIDDLE				2	<1	P	P	None
64	B	DRINKING FOUNTAIN OUTSIDE AUDITORIUM, RIGHT				3	<1	P	P	None
65	S	STAGE	<1	<1	P				P	None
66	S	C111	<1	<1	P				P	None
67	B	PERFORMING ARTS CORRIDOR	<1	<1	P				P	None
68	B	DRINKING FOUNTAIN OUTSIDE c109	<1	<1	P				P	None
70	S	KITCHEN	4	<1	P				P	None
71	S	ROOM C116	19	<1		10	<1	P	P	None
72	S	ROOM C116	5	<1	P				P	None
73	S	ROOM C116	7	<1	P				P	None
74	S	ROOM C116	5	<1	P				P	None
75	S	ROOM C116	4	<1	P				P	None
76	S	ROOM C116	1	<1	P				P	None
77	S	ROOM C116	5	<1	P				P	None
80	S	EXAM ROOM C132G	<1	<1	P				P	None
81	S	EXAM ROOM C132F	<1	<1	P				P	None
82	S	N101, STAFF PLANNING	2	<1	P				P	None
83	S	ROOM C352	2	<1	P				P	None
84	S	ROOM C116	3	<1	P				P	None

Table 3. Cadmium Test Results

FIXTURE INFORMATION			7/31/2019			8/20/2019			Summary Status	
Fixture ID	Type	Location	1st Draw	Flush 30s	Pass/Fail	1st Draw	Flush 30s	Pass/Fail	Pass/Fail	Status
01	B	BASEMENT DRINKING FOUNTAIN, LEFT	<1	<1	P				P	None
02	B	BASEMENT DRINKING FOUNTAIN, RIGHT	<1	<1	P				P	None
03	BF	BASEMENT BOTTLE FILLER	<1	<1	P				P	None
04	B	FIRST FLOOR, DRINKING FOUNTAIN, SOUTH WING, LEFT	<1	<1	P				P	None
05	B	FIRST FLOOR, DRINKING FOUNTAIN, SOUTH WING, RIGHT	<1	<1	P				P	None
06	BF	FIRST FLOOR, BOTTLE FILLER, SOUTH WING	<1	<1	P				P	None
07	S	NURSE OFFICE	<1	<1	P				P	None
08	S	NURSE OFFICE, room C132J	<1	<1	P				P	None
09	S	OFFICE WORKROOM	<1	<1	P				P	None
10	S	KITCHEN	<1	<1	P				P	None
11	S	KITCHEN, LEFT	<1	<1	P				P	None
12	S	KITCHEN, RIGHT	<1	<1	P				P	None
14	K	KITCHEN, KETTLE	<1	<1	P				P	None
15	S	KITCHEN	<1	<1	P				P	None
16	S	KITCHEN, LEFT	<1	<1	P				P	None
17	S	KITCHEN, RIGHT	<1	<1	P				P	None
18	S	N121 CUSTODIAL BREAK ROOM	<1	<1	P				P	None
19	BF	FIRST FLOOR, BOTTLE FILLER, NORTH WING	<1	<1	P				P	None
20	B	FIRST FLOOR, NORTH WING, DRINKING FOUNTAIN, LEFT	<1	<1	P				P	None
21	B	FIRST FLOOR, NORTH WING, DRINKING FOUNTAIN, RIGHT	<1	<1	P				P	None
22	S	ROOM 113	<1	<1	P				P	None
23	S	ROOM 111	<1	<1	P				P	None
25	S	ROOM 243A	<1	<1	P				P	None
26	B	SECOND FLOOR, MIDDLE WING, DRINKING FOUNTAIN, LEFT	<1	<1	P				P	None
27	B	SECOND FLOOR, MIDDLE WING, DRINKING FOUNTAIN, RIGHT	<1	<1	P				P	None
28	BF	SECOND FLOOR, MIDDLE WING, BOTTLE FILLER	<1	<1	P				P	None
29	S	ROOM 268	<1	<1	P				P	None
30	B	SECOND FLOOR, SOUTH WING, DRINKING FOUNTAIN, LEFT	<1	<1	P				P	None
31	B	SECOND FLOOR, SOUTH WING, DRINKING FOUNTAIN, RIGHT	<1	<1	P				P	None
32	BF	SECOND FLOOR, SOUTH WING, BOTTLE FILLER	<1	<1	P				P	None
33	S	ROOM 345	<1	<1	P				P	None
34	B	THIRD FLOOR, MIDDLE WING, DRINKING FOUNTAIN, LEFT	<1	<1	P				P	None
35	B	THIRD FLOOR, MIDDLE WING, DRINKING FOUNTAIN, RIGHT	<1	<1	P				P	None
36	BF	THIRD FLOOR, MIDDLE WING, BOTTLE FILLER	<1	<1	P				P	None
37	S	ROOM 334	<1	<1	P				P	None
38	S	ROOM 361	<1	<1	P				P	None
39	S	ROOM 369	<1	<1	P				P	None
40	B	THIRD FLOOR, SOUTH WING, DRINKING FOUNTAIN, LEFT	<1	<1	P				P	None
41	B	THIRD FLOOR, SOUTH WING, DRINKING FOUNTAIN, RIGHT	<1	<1	P				P	None
42	BF	THIRD FLOOR, SOUTH WING, BOTTLE FILLER	<1	<1	P				P	None
43	S	ROOM 445	<1	<1	P				P	None
44	B	FOURTH FLOOR, DRINKING FOUNTAIN, LEFT	<1	<1	P				P	None
45	B	FOURTH FLOOR, DRINKING FOUNTAIN, RIGHT	<1	<1	P				P	None
46	BF	FOURTH FLOOR, BOTTLE FILLER	<1	<1	P				P	None
47	S	ROOM 452	<1	<1	P				P	None
48	S	ROOM 433	<1	<1	P				P	None

49	B	MAIN GYM, SOUTH, DRINKING FOUNTAIN, LEFT	<1	<1	P				P	None
50	B	MAIN GYM, SOUTH, DRINKING FOUNTAIN, RIGHT	<1	<1	P				P	None
51	BF	MAIN GYM, SOUTH, BOTTLE FILLER	<1	<1	P				P	None
52	B	MAIN GYM, NORTH, DRINKING FOUNTAIN, LEFT	<1	<1	P				P	None
53	B	MAIN GYM, NORTH, DRINKING FOUNTAIN, RIGHT	<1	<1	P				P	None
54	BF	MAIN GYM, NORTH, BOTTLE FILLER	<1	<1	P				P	None
55	B	MAIN GYM, EAST, DRINKING FOUNTAIN, LEFT	<1	<1	P				P	None
56	B	MAIN GYM, EAST, DRINKING FOUNTAIN, MIDDLE								Sample
57	B	MAIN GYM, EAST, DRINKING FOUNTAIN, RIGHT	<1	<1	P				P	None
59	B	DRINKING FOUNTAIN, OUTSIDE BOYS LOCKER ROOM	<1	<1	P				P	None
60	B	BOYS LOCKER ROOM	<1	<1	P				P	None
62	B	DRINKING FOUNTAIN OUTSIDE AUDITORIUM, LEFT				<1	<1	P	P	None
63	B	DRINKING FOUNTAIN OUTSIDE AUDITORIUM, MIDDLE				<1	<1	P	P	None
64	B	DRINKING FOUNTAIN OUTSIDE AUDITORIUM, RIGHT				<1	<1	P	P	None
65	S	STAGE	<1	<1	P				P	None
66	S	C111	<1	<1	P				P	None
67	B	PERFORMING ARTS CORRIDOR	<1	<1	P				P	None
68	B	DRINKING FOUNTAIN OUTSIDE c109	<1	<1	P				P	None
70	S	KITCHEN	3	<1	P				P	None
71	S	ROOM C116	<1	<1	P	<1	<1	P	P	None
72	S	ROOM C116	<1	<1	P				P	None
73	S	ROOM C116	<1	<1	P				P	None
74	S	ROOM C116	<1	<1	P				P	None
75	S	ROOM C116	<1	<1	P				P	None
76	S	ROOM C116	<1	<1	P				P	None
77	S	ROOM C116	<1	<1	P				P	None
80	S	EXAM ROOM C132G	<1	<1	P				P	None
81	S	EXAM ROOM C132F	<1	<1	P				P	None
82	S	N101, STAFF PLANNING	<1	<1	P				P	None
83	S	ROOM C352	<1	<1	P				P	None
84	S	ROOM C116	<1	<1	P				P	None

Table 4. Copper Test Results

FIXTURE INFORMATION			7/31/2019			8/20/2019			Summary Status	
Fixture ID	Type	Location	1st Draw	Flush 30s	Pass/Fail	1st Draw	Flush 30s	Pass/Fail	Pass/Fail	Status
01	B	BASEMENT DRINKING FOUNTAIN, LEFT	0.637	0.353	P				P	None
02	B	BASEMENT DRINKING FOUNTAIN, RIGHT	0.446	0.47	P				P	None
03	BF	BASEMENT BOTTLE FILLER	0.351	0.505	P				P	None
04	B	FIRST FLOOR, DRINKING FOUNTAIN, SOUTH WING, LEFT	0.333	0.281	P				P	None
05	B	FIRST FLOOR, DRINKING FOUNTAIN, SOUTH WING, RIGHT	0.316	0.285	P				P	None
06	BF	FIRST FLOOR, BOTTLE FILLER, SOUTH WING	0.298	0.188	P				P	None
07	S	NURSE OFFICE	0.421	0.392	P				P	None
08	S	NURSE OFFICE, room C132J	0.207	0.277	P				P	None
09	S	OFFICE WORKROOM	0.249	0.237	P				P	None
10	S	KITCHEN	0.218	0.218	P				P	None
11	S	KITCHEN, LEFT	0.238	0.294	P				P	None
12	S	KITCHEN, RIGHT	0.149	0.291	P				P	None
14	K	KITCHEN, KETTLE	0.296	0.232	P				P	None
15	S	KITCHEN	0.129	0.193	P				P	None
16	S	KITCHEN, LEFT	0.146	0.207	P				P	None
17	S	KITCHEN, RIGHT	0.222	0.318	P				P	None
18	S	N121 CUSTODIAL BREAK ROOM	0.171	0.277	P				P	None
19	BF	FIRST FLOOR, BOTTLE FILLER, NORTH WING	0.225	0.191	P				P	None
20	B	FIRST FLOOR, NORTH WING, DRINKING FOUNTAIN, LEFT	0.252	0.401	P				P	None
21	B	FIRST FLOOR, NORTH WING, DRINKING FOUNTAIN, RIGHT	0.292	0.334	P				P	None
22	S	ROOM 113	0.141	0.237	P				P	None
23	S	ROOM 111	0.203	0.255	P				P	None
25	S	ROOM 243A	0.286	0.195	P				P	None
26	B	SECOND FLOOR, MIDDLE WING, DRINKING FOUNTAIN, LEFT	0.383	0.407	P				P	None
27	B	SECOND FLOOR, MIDDLE WING, DRINKING FOUNTAIN, RIGHT	0.331	0.411	P				P	None
28	BF	SECOND FLOOR, MIDDLE WING, BOTTLE FILLER	0.38	0.28	P				P	None
29	S	ROOM 268	0.155	0.271	P				P	None
30	B	SECOND FLOOR, SOUTH WING, DRINKING FOUNTAIN, LEFT	0.284	0.264	P				P	None
31	B	SECOND FLOOR, SOUTH WING, DRINKING FOUNTAIN, RIGHT	0.285	0.229	P				P	None
32	BF	SECOND FLOOR, SOUTH WING, BOTTLE FILLER	0.196	0.182	P				P	None
33	S	ROOM 345	0.267	0.513	P				P	None
34	B	THIRD FLOOR, MIDDLE WING, DRINKING FOUNTAIN, LEFT	0.465	0.438	P				P	None
35	B	THIRD FLOOR, MIDDLE WING, DRINKING FOUNTAIN, RIGHT	0.431	0.429	P				P	None
36	BF	THIRD FLOOR, MIDDLE WING, BOTTLE FILLER	0.468	0.418	P				P	None
37	S	ROOM 334	0.234	0.388	P				P	None
38	S	ROOM 361	0.271	0.46	P				P	None
39	S	ROOM 369	0.265	0.518	P				P	None
40	B	THIRD FLOOR, SOUTH WING, DRINKING FOUNTAIN, LEFT	0.407	0.454	P				P	None
41	B	THIRD FLOOR, SOUTH WING, DRINKING FOUNTAIN, RIGHT	0.486	0.481	P				P	None
42	BF	THIRD FLOOR, SOUTH WING, BOTTLE FILLER	0.646	0.535	P				P	None
43	S	ROOM 445	0.278	0.428	P				P	None
44	B	FOURTH FLOOR, DRINKING FOUNTAIN, LEFT	0.396	0.385	P				P	None
45	B	FOURTH FLOOR, DRINKING FOUNTAIN, RIGHT	0.402	0.388	P				P	None
46	BF	FOURTH FLOOR, BOTTLE FILLER	0.389	0.444	P				P	None
47	S	ROOM 452	0.247	0.373	P				P	None
48	S	ROOM 433	0.278	0.425	P				P	None
49	B	MAIN GYM, SOUTH, DRINKING FOUNTAIN, LEFT	0.011	0.008	P				P	None

50	B	MAIN GYM, SOUTH, DRINKING FOUNTAIN, RIGHT	0.024	0.013	P				P	None
51	BF	MAIN GYM, SOUTH, BOTTLE FILLER	0.028	0.017	P				P	None
52	B	MAIN GYM, NORTH, DRINKING FOUNTAIN, LEFT	0.004	<0.002	P				P	None
53	B	MAIN GYM, NORTH, DRINKING FOUNTAIN, RIGHT	<0.002	<0.002	P				P	None
54	BF	MAIN GYM, NORTH, BOTTLE FILLER	<0.002	<0.002	P				P	None
55	B	MAIN GYM, EAST, DRINKING FOUNTAIN, LEFT	<0.002	<0.002	P				P	None
56	B	MAIN GYM, EAST, DRINKING FOUNTAIN, MIDDLE								Sample
57	B	MAIN GYM, EAST, DRINKING FOUNTAIN, RIGHT	<0.002	<0.002	P				P	None
59	B	DRINKING FOUNTAIN, OUTSIDE BOYS LOCKER ROOM	0.006	<0.002	P				P	None
60	B	BOYS LOCKER ROOM	0.005	<0.002	P				P	None
62	B	DRINKING FOUNTAIN OUTSIDE AUDITORIUM, LEFT								None
63	B	DRINKING FOUNTAIN OUTSIDE AUDITORIUM, MIDDLE				0.171	0.015	P	P	None
64	B	DRINKING FOUNTAIN OUTSIDE AUDITORIUM, RIGHT				0.321	0.01	P	P	None
65	S	STAGE	0.005	<0.002	P				P	None
66	S	C111	0.003	<0.002	P				P	None
67	B	PERFORMING ARTS CORRIDOR	0.007	<0.002	P				P	None
68	B	DRINKING FOUNTAIN OUTSIDE c109	0.071	0.002	P				P	None
70	S	KITCHEN	0.014	0.002	P				P	None
71	S	ROOM C116	0.2	0.105	P	0.437	0.755	P	P	None
72	S	ROOM C116	0.095	0.013	P				P	None
73	S	ROOM C116	0.141	0.021	P				P	None
74	S	ROOM C116	0.166	0.055	P				P	None
75	S	ROOM C116	0.173	0.175	P				P	None
76	S	ROOM C116	0.133	0.143	P				P	None
77	S	ROOM C116	0.068	0.017	P				P	None
80	S	EXAM ROOM C132G	0.15	0.222	P				P	None
81	S	EXAM ROOM C132F	0.147	0.208	P				P	None
82	S	N101, STAFF PLANNING	0.248	0.302	P				P	None
83	S	ROOM C352	0.567	0.376	P				P	None
84	S	ROOM C116	0.084	0.011	P				P	None

Table 5. Iron Test Results

FIXTURE INFORMATION			7/31/2019		Summary Status	
Fixture ID	Type	Location	Flush 2m	Pass/Fail	Pass/Fail	Status
01	B	BASEMENT DRINKING FOUNTAIN, LEFT				
02	B	BASEMENT DRINKING FOUNTAIN, RIGHT				
03	BF	BASEMENT BOTTLE FILLER	0.16	P	P	None
04	B	FIRST FLOOR, DRINKING FOUNTAIN, SOUTH WING, LEFT				
05	B	FIRST FLOOR, DRINKING FOUNTAIN, SOUTH WING, RIGHT				
06	BF	FIRST FLOOR, BOTTLE FILLER, SOUTH WING				
07	S	NURSE OFFICE				
08	S	NURSE OFFICE, room C132J				
09	S	OFFICE WORKROOM	0.078	P	P	None
10	S	KITCHEN				
11	S	KITCHEN, LEFT				
12	S	KITCHEN, RIGHT				
14	K	KITCHEN, KETTLE				
15	S	KITCHEN	0.069	P	P	None
16	S	KITCHEN, LEFT				
17	S	KITCHEN, RIGHT				
18	S	N121 CUSTODIAL BREAK ROOM				
19	BF	FIRST FLOOR, BOTTLE FILLER, NORTH WING				
20	B	FIRST FLOOR, NORTH WING, DRINKING FOUNTAIN, LEFT				
21	B	FIRST FLOOR, NORTH WING, DRINKING FOUNTAIN, RIGHT	0.081	P	P	None
22	S	ROOM 113				
23	S	ROOM 111				
25	S	ROOM 243A				
26	B	SECOND FLOOR, MIDDLE WING, DRINKING FOUNTAIN, LEFT				
27	B	SECOND FLOOR, MIDDLE WING, DRINKING FOUNTAIN, RIGHT	0.078	P	P	None
28	BF	SECOND FLOOR, MIDDLE WING, BOTTLE FILLER				
29	S	ROOM 268				
30	B	SECOND FLOOR, SOUTH WING, DRINKING FOUNTAIN, LEFT				
31	B	SECOND FLOOR, SOUTH WING, DRINKING FOUNTAIN, RIGHT				
32	BF	SECOND FLOOR, SOUTH WING, BOTTLE FILLER				
33	S	ROOM 345	0.073	P	P	None
34	B	THIRD FLOOR, MIDDLE WING, DRINKING FOUNTAIN, LEFT				
35	B	THIRD FLOOR, MIDDLE WING, DRINKING FOUNTAIN, RIGHT				
36	BF	THIRD FLOOR, MIDDLE WING, BOTTLE FILLER				
37	S	ROOM 334				
38	S	ROOM 361				
39	S	ROOM 369				
40	B	THIRD FLOOR, SOUTH WING, DRINKING FOUNTAIN, LEFT				
41	B	THIRD FLOOR, SOUTH WING, DRINKING FOUNTAIN, RIGHT	0.064	P	P	None
42	BF	THIRD FLOOR, SOUTH WING, BOTTLE FILLER				
43	S	ROOM 445				
44	B	FOURTH FLOOR, DRINKING FOUNTAIN, LEFT				
45	B	FOURTH FLOOR, DRINKING FOUNTAIN, RIGHT				
46	BF	FOURTH FLOOR, BOTTLE FILLER				
47	S	ROOM 452	0.062	P	P	None

48	S	ROOM 433				
49	B	MAIN GYM, SOUTH, DRINKING FOUNTAIN, LEFT				
50	B	MAIN GYM, SOUTH, DRINKING FOUNTAIN, RIGHT				
51	BF	MAIN GYM, SOUTH, BOTTLE FILLER				
52	B	MAIN GYM, NORTH, DRINKING FOUNTAIN, LEFT				
53	B	MAIN GYM, NORTH, DRINKING FOUNTAIN, RIGHT				
54	BF	MAIN GYM, NORTH, BOTTLE FILLER				
55	B	MAIN GYM, EAST, DRINKING FOUNTAIN, LEFT				
56	B	MAIN GYM, EAST, DRINKING FOUNTAIN, MIDDLE				
57	B	MAIN GYM, EAST, DRINKING FOUNTAIN, RIGHT	<0.05	P	P	None
59	B	DRINKING FOUNTAIN, OUTSIDE BOYS LOCKER ROOM				
60	B	BOYS LOCKER ROOM				
62	B	DRINKING FOUNTAIN OUTSIDE AUDITORIUM, LEFT				
63	B	DRINKING FOUNTAIN OUTSIDE AUDITORIUM, MIDDLE				
64	B	DRINKING FOUNTAIN OUTSIDE AUDITORIUM, RIGHT				
65	S	STAGE				
66	S	C111				
67	B	PERFORMING ARTS CORRIDOR				
68	B	DRINKING FOUNTAIN OUTSIDE c109	0.053	P	P	None
70	S	KITCHEN				
71	S	ROOM C116				
72	S	ROOM C116				
73	S	ROOM C116				
74	S	ROOM C116				
75	S	ROOM C116				
76	S	ROOM C116	0.266	P	P	None
77	S	ROOM C116				
80	S	EXAM ROOM C132G				
81	S	EXAM ROOM C132F				
82	S	N101, STAFF PLANNING				
83	S	ROOM C352				
84	S	ROOM C116				

Table 6. Service Entry Test Results
Not tested yet.

"<" means: less than the value shown (below analytical detection limits).
"n/a" means: not applicable.

Table 7. Bacteriological Test Results

Bacteriological Characteristics

Bacteriological testing of selected samples indicated no (zero) coliform bacteria.