

**Seattle Public Schools
Drinking Water Quality Program**

**Summary Status
for
Lincoln High School**

Updated September 3, 2019

Status:

All sources meet the policy criteria

Drinking fountain by east side of the main gym (#56) will be tested after fixing the water pressure.

The school will be flushed after any break longer than five days.

Follow-up monitoring: Will be performed in 2021-2022

.