

**\]Seattle Public Schools
Drinking Water Quality Program**

**Results of Water Quality Testing
for
South Shore**

Revised January 13, 2020

General Information:

Plumbing piping materials: mainly copper

Remediation plan:

This remediation plan is based on a Water Quality policy approved by the School Board. The policy includes standards for the presence of lead, cadmium, copper, iron and other substances in drinking water.

Sinks (S in the report) are not considered drinking water sources. We recognize that there is the potential for students to want to drink from classroom hand-washing sinks, so we test all of those. Where a student's choice to drink from a sink could be a problem, we post a reminder sign, as we do at all restroom sinks.

Status:

Policy Criteria:

All sources meet the policy criteria.

Follow-up monitoring: Will be performed in school year 2022-2023.

Service: The school will be flushed after any breaks longer than five days.

Water Quality Testing Results:

Legend

Symbol	Definition
SE	service entry (main)
B	bubbler
S	sink (faucet)
B/S	sink/bubbler combination
S/B	sink/bubbler combination
ppb	parts per billion
ppm	parts per million
NA	not applicable
None	no action required
Unk	unknown status or action
Sample	sample needs to be taken
Re-test	fixture needs to be resampled
Conf	resample to confirm measurement
No flush	not flushed before sampling
Sink	sampled faucet of S/B combo
Used	recently used; no 1st draw sample possible
PS	post sign
Disable(d)	fixture disabled in response to water quality testing
BDSS	Bubbler disabled, sign on sink
IF	install filter
RB	replace bubbler
RB/IF	replace bubbler and/or install filter
RF	replace faucet
RF/IF	replace faucet and/or install filter
BW	disable fixture and provide bottled water until remediated
Leaks	leaking fixture
NW	not working properly (sample S when B of S/B NW)
OS	out of service - disabled until fixed
RS	return to service - now passes testing
Rem	Removed from system - no longer exists

Table 1. Summary of Results

FIXTURE INFORMATION			LEAD		CADMIUM		COPPER		IRON		OK?
Fixture ID	Type	Location	Pass/Fail	Status	Pass/Fail	Status	Pass/Fail	Status	Pass/Fail	Status	Yes/No/Status
07	BF	COMMONS AREA 4	P	None	P	None	P	None			Yes
08	B	COMMONS AREA 4	P	None	P	None	P	None			Yes
09	S	ROOM 123, STUDENT STORE	P	None	P	None	P	None			Yes
10	S	ROOM 121, PTA	P	None	P	None	P	None			Yes
11	S	ROOM 132, PRE-K LEFT	P	None	P	None	P	None	P	None	Yes
12	S	ROOM 132, PRE-K RIGHT	P	None	P	None	P	None	P	None	Yes
13	S	ROOM 133 PRE-K, LEFT	P	None	P	None	P	None			Yes
14	S	ROOM 133 PRE-K, RIGHT	P	None	P	None	P	None			Yes
15	S	ROOM 131D, PRE-K KITCHEN	P	None	P	None	P	None			Yes
16	S	ROOM 131D, PRE-K KITCHEN	P	None	P	None	P	None	P	None	Yes
17	S	ROOM 134 PRE-K, LEFT	P	None	P	None	P	None			Yes
18	S	ROOM 134 PRE-K, RIGHT	P	None	P	None	P	None	P	None	Yes
19	B	PRE-K COMMONS, LEFT	P	None	P	None	P	None	P	None	Yes
20	B	PRE-K COMMONS, RIGHT	P	None	P	None	P	None	P	None	Yes
21	B	1ST GRADE COMMONS, LEFT	P	None	P	None	P	None			Yes
22	B	1ST GRADE COMMONS, RIGHT	P	None	P	None	P	None			Yes
23	S/B	ROOM 137, LEFT	P	None	P	None	P	None			Yes
24	S/B	ROOM 137, MIDDLE	P	None	P	None	P	None			Yes
25	S/B	ROOM 137, RIGHT	P	None	P	None	P	None			Yes
26	S/B	ROOM 138, LEFT	P	None	P	None	P	None			Yes
27	S/B	ROOM 138, MIDDLE	P	None	P	None	P	None			Yes
28	S/B	ROOM 138, RIGHT	P	None	P	None	P	None			Yes
29	S/B	ROOM 139, LEFT	P	None	P	None	P	None			Yes
30	S/B	ROOM 139, MIDDLE	P	None	P	None	P	None			Yes
31	S/B	ROOM 139, RIGHT	P	None	P	None	P	None			Yes
32	B	1ST GRADE COMMON 140, LEFT	P	None	P	None	P	None			Yes
33	B	1ST GRADE COMMON 140, RIGHT	P	None	P	None	P	None			Yes
34	S/B	ROOM 142	P	None	P	None	P	None			Yes
35	S/B	ROOM 143	P	None	P	None	P	None			Yes
36	S/B	ROOM 140	P	None	P	None	P	None			Yes
37	S/B	ROOM 144	P	None	P	None	P	None			Yes
38	S/B	ROOM 147, SPEC. ED.	P	None	P	None	P	None	P	None	Yes
39	S	ROOM 148A, SPEC ED. KITCHEN	P	None	P	None	P	None	P	None	Yes
40	S/B	ROOM 148, SPEC ED.	P	None	P	None	P	None	P	None	Yes
41	S/B	ROOM 149, RESOURCE	P	None	P	None	P	None			Yes
42	S	KITCHEN	P	None	P	None	P	None			Yes
43	S	KITCHEN, LEFT	P	None	P	None	P	None			Yes
44	S	KITCHEN, RIGHT	P	None	P	None	P	None	P	None	Yes
45	S	KITCHEN	P	None	P	None	P	None			Yes
46	S	KITCHEN	P	None	P	None	P	None			Yes
47	K	KITCHEN	P	None	P	None	P	None			Yes
48	S	162B, CUSTODIAN LUNCH ROOM	P	None	P	None	P	None			Yes
49	B	BY SECURITY, LEFT	P	None	P	None	P	None			Yes
50	B	BY SECURITY, RIGHT	P	None	P	None	P	None			Yes
51	S/B	FITNESS ROOM 185	P	None	P	None	P	None			Yes
52	B	BY ROOM 199, LEFT	P	None	P	None	P	None			Yes
53	B	BY ROOM 199, RIGHT	P	None	P	None	P	None			Yes

54	S/B	ROOM 199	P	None	P	None	P	None			Yes
55	S/B	190, SIX GRADE COMMON	P	None	P	None	P	None			Yes
56	S	101E, STAFF LOUNGE	P	None	P	None	P	None	P	None	Yes
57	B	OFFICE AREA, LEFT	P	None	P	None	P	None			Yes
58	B	OFFICE AREA, RIGHT	P	None	P	None	P	None			Yes
59	S	CLINIC 102	P	None	P	None	P	None			Yes
60	S	EXAM ROOM, 102E	P	None	P	None	P	None	P	None	Yes
61	S	HEALTH LAB, 102C	P	None	P	None	P	None			Yes
62	S/B	LIBRARY OFFICE, 210A	P	None	P	None	P	None			Yes
63	B	2ND FLOOR, HALL, LEFT	P	None	P	None	P	None			Yes
64	B	2ND FLOOR, HALL, RIGHT	P	None	P	None	P	None			Yes
65	S	COMPUTER ROOM, 202, LEFT	P	None	P	None	P	None			Yes
66	S	COMPUTER ROOM, 202, RIGHT	P	None	P	None	P	None			Yes
67	S/B	MUSIC ROOM, 200	P	None	P	None	P	None			Yes
69	S	2ND FLOOR, STAFF LUNCH ROOM, 281A	P	None	P	None	P	None	P	None	Yes
70	S/B	2ND FLOOR, 290	P	None	P	None	P	None	P	None	Yes
71	B	2ND FLOOR HALL, LEFT	P	None	P	None	P	None	P	None	Yes
72	B	2ND FLOOR HALL, RIGHT	P	None	P	None	P	None	P	None	Yes
73	S	ROOM 299	P	None	P	None	P	None			Yes
74	S	STAFF WORK ROOM, 263	P	None	P	None	P	None			Yes
75	S/B	ROOM 260	P	None	P	None	P	None			Yes
76	B	240, LEFT	P	None	P	None	P	None			Yes
77	B	240, RIGHT	P	None	P	None	P	None			Yes
78	S/B	ROOM 242	P	None	P	None	P	None			Yes
79	S/B	ROOM 243	P	None	P	None	P	None			Yes
80	S/B	240	P	None	P	None	P	None			Yes
81	S/B	ROOM 244	P	None	P	None	P	None			Yes
82	S/B	ROOM 247	P	None	P	None	P	None	P	None	Yes
83	S/B	ROOM 248	P	None	P	None	P	None	P	None	Yes
84	S/B	ROOM 249	P	None	P	None	P	None	P	None	Yes
85	B	230, LEFT	P	None	P	None	P	None			Yes
86	B	230, RIGHT	P	None	P	None	P	None			Yes
87	S/B	230	P	None	P	None	P	None			Yes
88	S/B	ROOM 239	P	None	P	None	P	None			Yes
89	S/B	ROOM 238	P	None	P	None	P	None			Yes
90	S/B	ROOM 237	P	None	P	None	P	None			Yes
91	S/B	ROOM 234	P	None	P	None	P	None	P	None	Yes
92	S/B	ROOM 233	P	None	P	None	P	None	P	None	Yes
93	S/B	ROOM 232	P	None	P	None	P	None	P	None	Yes
94	B	390, LEFT	P	None	P	None	P	None			Yes
95	B	390, RIGHT	P	None	P	None	P	None			Yes
96	S/B	ROOM 399	P	None	P	None	P	None			Yes
97	S/B	390	P	None	P	None	P	None	P	None	Yes

Table 2. Lead Test Results

FIXTURE INFORMATION			8/19/2009			9/10/2009			7/20/2012			7/10/2015			3/5/2019			8/21/2019			11/2/2019			Summary Status	
Fixture ID	Type	Location	1st Draw	Flush 30s	Pass /Fail	1st Draw	Flush 30s	Pass /Fail	1st Draw	Flush 30s	Pass /Fail	1st Draw	Flush 30s	Pass /Fail	1st Draw	Flush 30s	Pass /Fail	1st Draw	Flush 30s	Pass /Fail	1st Draw	Flush 30s	Pass /Fail	Pass/Fail	Status
07	BF	COMMONS AREA 4	5	<1	P				<1	<1	P	<1	<1	P							<1	<1	P	P	None
08	B	COMMONS AREA 4	2	2	P				<1	<1	P	<1	<1	P							<1	<1	P	P	None
09	S	ROOM 123, STUDENT STORE	4	<1	P				7	1	P	14	2					<1	<1	P				P	None
10	S	ROOM 121, PTA	2	<1	P				3	<1	P	<1	<1	P							<1	<1	P	P	None
11	S	ROOM 132, PRE-K LEFT	4	1	P				1	<1	P	<1	<1	P							<1	<1	P	P	None
12	S	ROOM 132, PRE-K RIGHT	3	1	P				1	<1	P	<1	<1	P							<1	<1	P	P	None
13	S	ROOM 133 PRE-K, LEFT	4	2	P				3	<1	P	1	<1	P							<1	<1	P	P	None
14	S	ROOM 133 PRE-K, RIGHT	3	1	P				6	2	P	<1	4	P							<1	<1	P	P	None
15	S	ROOM 131D, PRE-K KITCHEN	4	1	P				7	<1	P	5	<1	P							1	<1	P	P	None
16	S	ROOM 131D, PRE-K KITCHEN	6	1	P				8	1	P	5	<1	P							<1	<1	P	P	None
17	S	ROOM 134 PRE-K, LEFT	3	2	P				3	<1	P	2	<1	P							<1	<1	P	P	None
18	S	ROOM 134 PRE-K, RIGHT	3	3	P				3	<1	P	2	<1	P							2	<1	P	P	None
19	B	PRE-K COMMONS, LEFT	1	<1	P				<1	1	P	1	<1	P							<1	<1	P	P	None
20	B	PRE-K COMMONS, RIGHT	1	<1	P				2	<1	P	1	<1	P							1	<1	P	P	None
21	B	1ST GRADE COMMONS, LEFT	1	<1	P				1	<1	P	2	<1	P							<1	<1	P	P	None
22	B	1ST GRADE COMMONS, RIGHT							<1	<1	P	<1	<1	P							<1	<1	P	P	None
23	S/B	ROOM 137, LEFT	1	1	P				<1	<1	P	<1	<1	P							<1	<1	P	P	None
24	S/B	ROOM 137, MIDDLE	2	1	P				1	<1	P	1	<1	P							<1	<1	P	P	None
25	S/B	ROOM 137, RIGHT	1	1	P				<1	<1	P	2	<1	P							<1	<1	P	P	None
26	S/B	ROOM 138, LEFT	1	1	P				<1	<1	P	<1	<1	P							<1	<1	P	P	None
27	S/B	ROOM 138, MIDDLE	1	1	P				<1	<1	P	<1	<1	P							<1	<1	P	P	None
28	S/B	ROOM 138, RIGHT	1	<1	P				1	<1	P	1	<1	P							<1	<1	P	P	None
29	S/B	ROOM 139, LEFT	1	<1	P				1	<1	P	1	<1	P							<1	<1	P	P	None
30	S/B	ROOM 139, MIDDLE	1	1	P				1	<1	P	2	<1	P							<1	<1	P	P	None
31	S/B	ROOM 139, RIGHT	1	1	P				1	<1	P	1	<1	P							<1	<1	P	P	None
32	B	1ST GRADE COMMON 140, LEFT	1	<1	P				<1	<1	P	2	<1	P							<1	<1	P	P	None
33	B	1ST GRADE COMMON 140, RIGHT	1	<1	P				<1	<1	P	1	<1	P							<1	<1	P	P	None
34	S/B	ROOM 142	1	<1	P				1	2	P	1	<1	P							<1	<1	P	P	None
35	S/B	ROOM 143	1	<1	P				1	1	P	<1	<1	P							<1	<1	P	P	None
36	S/B	ROOM 140	1	<1	P				1	<1	P	4	<1	P							1	<1	P	P	None
37	S/B	ROOM 144	1	<1	P				1	<1	P	2	<1	P							<1	<1	P	P	None
38	S/B	ROOM 147, SPEC. ED.	2	3	P				1	<1	P	1	<1	P							<1	<1	P	P	None
39	S	ROOM 148A, SPEC ED. KITCHEN	4	<1	P				3	<1	P	2	<1	P							<1	<1	P	P	None
40	S/B	ROOM 148, SPEC ED.	23	2		2	2	P	<1	<1	P	<1	1	P							<1	<1	P	P	None
41	S/B	ROOM 149, RESOURCE	<1	<1	P				<1	<1	P	<1	<1	P							<1	<1	P	P	None
42	S	KITCHEN	22	1		5	<1	P	5	<1	P	2	<1	P							<1	<1	P	P	None
43	S	KITCHEN, LEFT	12	1		3	1	P	3	<1	P	3	<1	P							2	<1	P	P	None
44	S	KITCHEN, RIGHT	42	2		11	1		4	<1	P	3	<1	P							1	<1	P	P	None
45	S	KITCHEN	66	1		10	2	P	2	<1	P	1	<1	P							6	<1	P	P	None
46	S	KITCHEN	10	1	P				1	<1	P	<1	<1	P							<1	<1	P	P	None
47	K	KITCHEN	28	2		4	<1	P				2	1	P							2	<1	P	P	None
48	S	162B, CUSTODIAN LUNCH ROOM	3	1	P				3	2	P	5	3	P							<1	1	P	P	None
49	B	BY SECURITY, LEFT	2	2	P				<1	<1	P	<1	<1	P							<1	<1	P	P	None
50	B	BY SECURITY, RIGHT	3	3	P				<1	<1	P	<1	<1	P							<1	<1	P	P	None
51	S/B	FITNESS ROOM 185							4	<1	P	9	1	P							<1	<1	P	P	None
52	B	BY ROOM 199, LEFT	1	1	P				2	2	P	6	3	P							1	<1	P	P	None
53	B	BY ROOM 199, RIGHT	1	1	P				2	2	P	3	2	P							1	<1	P	P	None

54	S/B	ROOM 199	1	<1	P				10	10	P	12	14				4	5	P				P	None
55	S/B	190, SIX GRADE COMMON	1	1	P				<1	<1	P	2	<1	P						<1	<1	P	P	None
56	S	101E, STAFF LOUNGE	6	5	P				4	1	P	3	1	P						<1	<1	P	P	None
57	B	OFFICE AREA, LEFT	2	1	P				1	<1	P	1	<1	P						<1	<1	P	P	None
58	B	OFFICE AREA, RIGHT	1	2	P				<1	<1	P	1	<1	P						<1	<1	P	P	None
59	S	CLINIC 102	4	<1	P				3	<1	P	2	<1	P						<1	<1	P	P	None
60	S	EXAM ROOM, 102E	4	<1	P				17	2		4	<1	P						1	<1	P	P	None
61	S	HEALTH LAB, 102C	3	<1	P				6	<1	P	9	1	P									P	None
62	S/B	LIBRARY OFFICE, 210A	4	1	P				2	<1	P	2	<1	P						<1	<1	P	P	None
63	B	2ND FLOOR, HALL, LEFT	2	1	P				<1	<1	P	1	<1	P						<1	<1	P	P	None
64	B	2ND FLOOR, HALL, RIGHT	2	1	P				1	<1	P	2	<1	P						<1	<1	P	P	None
65	S	COMPUTER ROOM, 202, LEFT	11	5		1	1	P	9	1	P	6	2	P						1	1	P	P	None
66	S	COMPUTER ROOM, 202, RIGHT	10	3	P				3	1	P	5	<1	P						1	<1	P	P	None
67	S/B	MUSIC ROOM, 200	2	3	P				2	<1	P	2	<1	P						<1	<1	P	P	None
69	S	2ND FLOOR, STAFF LUNCH ROOM, 281A	11	1		<1	<1	P	2	2	P	1	<1	P						<1	<1	P	P	None
70	S/B	2ND FLOOR, 290	1	<1	P				2	<1	P	1	<1	P						<1	<1	P	P	None
71	B	2ND FLOOR HALL, LEFT	3	<1	P				2	2	P	3	1	P									P	None
72	B	2ND FLOOR HALL, RIGHT	2	<1	P				3	2	P	3	2	P						<1	<1	P	P	None
73	S	ROOM 299	2	<1	P				8	11		13	13				5	6	P				P	None
74	S	STAFF WORK ROOM, 263	10	1	P				<1	<1	P	5	2	P						2	<1	P	P	None
75	S/B	ROOM 260	4	47		1	3	P	<1	<1	P	3	2	P						5	4	P	P	None
76	B	240, LEFT	1	1	P															<1	<1	P	P	None
77	B	240, RIGHT	2	1	P															<1	<1	P	P	None
78	S/B	ROOM 242	1	1	P				2	<1	P	1	<1	P						<1	<1	P	P	None
79	S/B	ROOM 243	2	<1	P				1	<1	P	<1	<1	P						<1	<1	P	P	None
80	S/B	240	1	<1	P				1	<1	P	2	<1	P						<1	<1	P	P	None
81	S/B	ROOM 244	1	<1	P				<1	<1	P	1	<1	P	<1	<1	P			<1	<1	P	P	None
82	S/B	ROOM 247	1	<1	P				<1	<1	P	<1	<1	P						<1	<1	P	P	None
83	S/B	ROOM 248	2	<1	P				2	<1	P	<1	<1	P						<1	<1	P	P	None
84	S/B	ROOM 249	1	<1	P				<1	<1	P	2	<1	P						<1	<1	P	P	None
85	B	230, LEFT	2	1	P																		P	None
86	B	230, RIGHT	2	<1	P				1	<1	P	4	3	P						<1	<1	P	P	None
87	S/B	230	7	<1	P				2	<1	P	<1	<1	P						<1	<1	P	P	None
88	S/B	ROOM 239	2	<1	P				2	<1	P	<1	<1	P						<1	<1	P	P	None
89	S/B	ROOM 238	1	<1	P				2	<1	P	1	<1	P						<1	<1	P	P	None
90	S/B	ROOM 237	1	1	P				2	<1	P	1	<1	P						<1	<1	P	P	None
91	S/B	ROOM 234	1	1	P				2	<1	P	1	<1	P						<1	<1	P	P	None
92	S/B	ROOM 233	1	2	P				2	<1	P	1	<1	P						<1	<1	P	P	None
93	S/B	ROOM 232	1	<1	P				2	<1	P	2	<1	P						<1	<1	P	P	None
94	B	390, LEFT	1	<1	P				4	2	P	3	2	P									P	None
95	B	390, RIGHT	1	<1	P				3	3	P												P	None
96	S/B	ROOM 399	1	<1	P				8	10	P	12	12				4	4	P				P	None
97	S/B	390	2	<1	P				3	<1	P	<1	<1	P						<1	<1	P	P	None

Table 3. Cadmium Test Results

FIXTURE INFORMATION			8/19/2009			9/10/2009			7/20/2012			7/10/2015			3/5/2019			11/2/2019			Summary Status		
Fixture ID	Type	Location	1st Draw	Flush 30s	Pass/Fail	1st Draw	Flush 30s	Pass/Fail	1st Draw	Flush 30s	Pass/Fail	1st Draw	Flush 30s	Pass/Fail	1st Draw	Flush 30s	Pass/Fail	1st Draw	Flush 30s	Pass/Fail	Pass/Fail	Status	
07	BF	COMMONS AREA 4	<1	<1	P				<1	<1	P	<1	<1	P				<1	<1	P	P	None	
08	B	COMMONS AREA 4	<1	<1	P				<1	<1	P	<1	<1	P				<1	<1	P	P	None	
09	S	ROOM 123, STUDENT STORE	<1	<1	P				<1	<1	P	<1	<1	P								P	None
10	S	ROOM 121, PTA	<1	<1	P				<1	<1	P	<1	<1	P				<1	<1	P	P	None	
11	S	ROOM 132, PRE-K LEFT	<1	<1	P				<1	<1	P	<1	<1	P				<1	<1	P	P	None	
12	S	ROOM 132, PRE-K RIGHT	<1	<1	P				<1	<1	P	<1	<1	P				<1	<1	P	P	None	
13	S	ROOM 133 PRE-K, LEFT	<1	<1	P				<1	<1	P	<1	<1	P				<1	<1	P	P	None	
14	S	ROOM 133 PRE-K, RIGHT	1	<1	P				<1	<1	P	<1	<1	P				<1	<1	P	P	None	
15	S	ROOM 131D, PRE-K KITCHEN	<1	<1	P				<1	<1	P	<1	<1	P				<1	<1	P	P	None	
16	S	ROOM 131D, PRE-K KITCHEN	<1	<1	P				<1	<1	P	<1	<1	P				<1	<1	P	P	None	
17	S	ROOM 134 PRE-K, LEFT	<1	<1	P				<1	<1	P	<1	<1	P				<1	<1	P	P	None	
18	S	ROOM 134 PRE-K, RIGHT	<1	<1	P				<1	<1	P	<1	<1	P				<1	<1	P	P	None	
19	B	PRE-K COMMONS, LEFT	<1	<1	P				<1	<1	P	<1	<1	P				<1	<1	P	P	None	
20	B	PRE-K COMMONS, RIGHT	<1	<1	P				<1	<1	P	<1	<1	P				<1	<1	P	P	None	
21	B	1ST GRADE COMMONS, LEFT	<1	<1	P				<1	<1	P	<1	<1	P				<1	<1	P	P	None	
22	B	1ST GRADE COMMONS, RIGHT							<1	<1	P	<1	<1	P				<1	<1	P	P	None	
23	S/B	ROOM 137, LEFT	<1	<1	P				<1	<1	P	<1	<1	P				<1	<1	P	P	None	
24	S/B	ROOM 137, MIDDLE	<1	<1	P				<1	<1	P	<1	<1	P				<1	<1	P	P	None	
25	S/B	ROOM 137, RIGHT	<1	<1	P				<1	<1	P	<1	<1	P				<1	<1	P	P	None	
26	S/B	ROOM 138, LEFT	<1	<1	P				<1	<1	P	<1	<1	P				<1	<1	P	P	None	
27	S/B	ROOM 138, MIDDLE	<1	<1	P				<1	<1	P	<1	<1	P				<1	<1	P	P	None	
28	S/B	ROOM 138, RIGHT	<1	<1	P				<1	<1	P	<1	<1	P				<1	<1	P	P	None	
29	S/B	ROOM 139, LEFT	<1	<1	P				<1	<1	P	<1	<1	P				<1	<1	P	P	None	
30	S/B	ROOM 139, MIDDLE	<1	<1	P				<1	<1	P	<1	<1	P				<1	<1	P	P	None	
31	S/B	ROOM 139, RIGHT	<1	<1	P				<1	<1	P	<1	<1	P				<1	<1	P	P	None	
32	B	1ST GRADE COMMON 140, LEFT	<1	<1	P				<1	<1	P	<1	<1	P				<1	<1	P	P	None	
33	B	1ST GRADE COMMON 140, RIGHT	<1	<1	P				<1	<1	P	<1	<1	P				<1	<1	P	P	None	
34	S/B	ROOM 142	<1	<1	P				<1	<1	P	<1	<1	P				<1	<1	P	P	None	
35	S/B	ROOM 143	<1	<1	P				<1	<1	P	<1	<1	P				<1	<1	P	P	None	
36	S/B	ROOM 140	<1	<1	P				<1	<1	P	<1	<1	P				<1	<1	P	P	None	
37	S/B	ROOM 144	<1	<1	P				<1	<1	P	<1	<1	P				<1	<1	P	P	None	
38	S/B	ROOM 147, SPEC. ED.	<1	<1	P				<1	<1	P	<1	<1	P				<1	<1	P	P	None	
39	S	ROOM 148A, SPEC ED. KITCHEN	<1	<1	P				<1	<1	P	<1	<1	P				<1	<1	P	P	None	
40	S/B	ROOM 148, SPEC ED.	<1	<1	P	<1	<1	P	<1	<1	P	<1	<1	P				<1	<1	P	P	None	
41	S/B	ROOM 149, RESOURCE	<1	<1	P				<1	<1	P	<1	<1	P				<1	<1	P	P	None	
42	S	KITCHEN	<1	<1	P	<1	<1	P	<1	<1	P	<1	<1	P				<1	<1	P	P	None	
43	S	KITCHEN, LEFT	2	<1	P	<1	<1	P	<1	<1	P	<1	<1	P				<1	<1	P	P	None	
44	S	KITCHEN, RIGHT	6	<1	P	<1	<1	P	<1	<1	P	<1	<1	P				<1	<1	P	P	None	
45	S	KITCHEN	<1	<1	P	<1	<1	P	<1	<1	P	<1	<1	P				<1	<1	P	P	None	
46	S	KITCHEN	<1	<1	P				<1	<1	P	<1	<1	P				<1	<1	P	P	None	
47	K	KITCHEN	<1	<1	P	<1	<1	P				<1	<1	P				<1	<1	P	P	None	
48	S	162B, CUSTODIAN LUNCH ROOM	<1	<1	P				<1	<1	P	<1	<1	P				<1	<1	P	P	None	
49	B	BY SECURITY, LEFT	<1	<1	P				<1	<1	P	<1	<1	P				<1	<1	P	P	None	
50	B	BY SECURITY, RIGHT	<1	<1	P				<1	<1	P	<1	<1	P				<1	<1	P	P	None	
51	S/B	FITNESS ROOM 185							<1	<1	P	<1	<1	P				<1	<1	P	P	None	
52	B	BY ROOM 199, LEFT	<1	<1	P				<1	<1	P	<1	<1	P				<1	<1	P	P	None	
53	B	BY ROOM 199, RIGHT	<1	<1	P				<1	<1	P	<1	<1	P				<1	<1	P	P	None	

54	S/B	ROOM 199	<1	<1	P				<1	<1	P	<1	<1	P					P	None		
55	S/B	190, SIX GRADE COMMON	<1	<1	P				<1	<1	P	<1	<1	P			<1	<1	P	P	None	
56	S	101E, STAFF LOUNGE	<1	<1	P				<1	<1	P	<1	<1	P			<1	<1	P	P	None	
57	B	OFFICE AREA, LEFT	<1	<1	P				<1	<1	P	<1	<1	P			<1	<1	P	P	None	
58	B	OFFICE AREA, RIGHT	<1	<1	P				<1	<1	P	<1	<1	P			<1	<1	P	P	None	
59	S	CLINIC 102	<1	<1	P				<1	<1	P	<1	<1	P			<1	<1	P	P	None	
60	S	EXAM ROOM, 102E	<1	<1	P				<1	<1	P	<1	<1	P			<1	<1	P	P	None	
61	S	HEALTH LAB, 102C	<1	<1	P				<1	<1	P	<1	<1	P						P	None	
62	S/B	LIBRARY OFFICE, 210A	<1	<1	P				<1	<1	P	<1	<1	P			<1	<1	P	P	None	
63	B	2ND FLOOR, HALL, LEFT	<1	<1	P				<1	<1	P	<1	<1	P			<1	<1	P	P	None	
64	B	2ND FLOOR, HALL, RIGHT	<1	<1	P				<1	<1	P	<1	<1	P			<1	<1	P	P	None	
65	S	COMPUTER ROOM, 202, LEFT	<1	<1	P	<1	<1	P	<1	<1	P	<1	<1	P			<1	<1	P	P	None	
66	S	COMPUTER ROOM, 202, RIGHT	<1	<1	P				<1	<1	P	<1	<1	P			<1	<1	P	P	None	
67	S/B	MUSIC ROOM, 200	<1	<1	P				<1	<1	P	<1	<1	P			<1	<1	P	P	None	
69	S	2ND FLOOR, STAFF LUNCH ROOM, 281A	<1	<1	P	<1	<1	P	<1	<1	P	<1	<1	P			<1	<1	P	P	None	
70	S/B	2ND FLOOR, 290	<1	<1	P				<1	<1	P	<1	<1	P			<1	<1	P	P	None	
71	B	2ND FLOOR HALL, LEFT	<1	<1	P				<1	<1	P	<1	<1	P						P	None	
72	B	2ND FLOOR HALL, RIGHT	<1	<1	P				<1	<1	P	<1	<1	P			<1	<1	P	P	None	
73	S	ROOM 299	<1	<1	P				<1	<1	P	<1	<1	P						P	None	
74	S	STAFF WORK ROOM, 263	<1	<1	P				<1	<1	P	<1	<1	P			<1	<1	P	P	None	
75	S/B	ROOM 260	<1	<1	P	<1	<1	P	<1	<1	P	<1	<1	P			<1	<1	P	P	None	
76	B	240, LEFT	<1	<1	P												<1	<1	P	P	None	
77	B	240, RIGHT	<1	<1	P												<1	<1	P	P	None	
78	S/B	ROOM 242	<1	<1	P				<1	<1	P	<1	<1	P			<1	<1	P	P	None	
79	S/B	ROOM 243	<1	<1	P				<1	<1	P	<1	<1	P			<1	<1	P	P	None	
80	S/B	240	<1	<1	P				<1	<1	P	<1	<1	P			<1	<1	P	P	None	
81	S/B	ROOM 244	<1	<1	P				<1	<1	P	<1	<1	P	<1	<1	P	<1	<1	P	P	None
82	S/B	ROOM 247	<1	<1	P				<1	<1	P	<1	<1	P			<1	<1	P	P	None	
83	S/B	ROOM 248	<1	<1	P				<1	<1	P	<1	<1	P			<1	<1	P	P	None	
84	S/B	ROOM 249	<1	<1	P				<1	<1	P	<1	<1	P			<1	<1	P	P	None	
85	B	230, LEFT	<1	<1	P															P	None	
86	B	230, RIGHT	<1	<1	P				<1	<1	P	<1	<1	P			<1	<1	P	P	None	
87	S/B	230	<1	<1	P				<1	<1	P	<1	<1	P			<1	<1	P	P	None	
88	S/B	ROOM 239	<1	<1	P				<1	<1	P	<1	<1	P			<1	<1	P	P	None	
89	S/B	ROOM 238	<1	<1	P				<1	<1	P	<1	<1	P			<1	<1	P	P	None	
90	S/B	ROOM 237	<1	<1	P				<1	<1	P	<1	<1	P			<1	<1	P	P	None	
91	S/B	ROOM 234	<1	<1	P				<1	<1	P	<1	<1	P			<1	<1	P	P	None	
92	S/B	ROOM 233	<1	<1	P				<1	<1	P	<1	<1	P			<1	<1	P	P	None	
93	S/B	ROOM 232	<1	<1	P				<1	<1	P	<1	<1	P			<1	<1	P	P	None	
94	B	390, LEFT	<1	<1	P				<1	<1	P	<1	<1	P						P	None	
95	B	390, RIGHT	<1	<1	P				<1	<1	P									P	None	
96	S/B	ROOM 399	<1	<1	P				<1	<1	P	<1	<1	P						P	None	
97	S/B	390	<1	<1	P				<1	<1	P	<1	<1	P			<1	<1	P	P	None	

Table 4. Copper Test Results

FIXTURE INFORMATION			8/19/2009			9/10/2009			7/20/2012			7/10/2015			3/5/2019			11/2/2019			Summary Status		
Fixture ID	Type	Location	1st Draw	Flush 30s	Pass/Fail	1st Draw	Flush 30s	Pass/Fail	1st Draw	Flush 30s	Pass/Fail	1st Draw	Flush 30s	Pass/Fail	1st Draw	Flush 30s	Pass/Fail	1st Draw	Flush 30s	Pass/Fail	Pass/Fail	Status	
07	BF	COMMONS AREA 4	0.222	0.211	P				0.206	0.182	P	0.206	0.216	P				0.264	0.208	P	P	None	
08	B	COMMONS AREA 4	0.193	0.165	P				0.187	0.187	P	0.224	0.204	P				0.275	0.19	P	P	None	
09	S	ROOM 123, STUDENT STORE	0.161	0.058	P				0.183	0.291	P	0.207	0.252	P								P	None
10	S	ROOM 121, PTA	0.084	0.057	P				0.141	0.137	P	0.076	0.08	P				0.321	0.218	P	P	None	
11	S	ROOM 132, PRE-K LEFT	0.252	0.095	P				0.176	0.171	P	0.222	0.237	P				0.325	0.248	P	P	None	
12	S	ROOM 132, PRE-K RIGHT	0.175	0.079	P				0.172	0.185	P	0.238	0.232	P				0.305	0.244	P	P	None	
13	S	ROOM 133 PRE-K, LEFT	0.231	0.124	P				0.258	0.257	P	0.229	0.254	P				0.291	0.196	P	P	None	
14	S	ROOM 133 PRE-K, RIGHT	0.213	0.115	P				0.27	0.249	P	0.289	0.275	P				0.235	0.213	P	P	None	
15	S	ROOM 131D, PRE-K KITCHEN	0.188	0.185	P				0.155	0.187	P	0.268	0.23	P				0.491	0.263	P	P	None	
16	S	ROOM 131D, PRE-K KITCHEN	0.178	0.104	P				0.274	0.223	P	0.215	0.227	P				0.285	0.2	P	P	None	
17	S	ROOM 134 PRE-K, LEFT	0.19	0.185	P				0.176	0.203	P	0.225	0.26	P				0.294	0.292	P	P	None	
18	S	ROOM 134 PRE-K, RIGHT	0.173	0.189	P				0.172	0.166	P	0.222	0.224	P				0.287	0.238	P	P	None	
19	B	PRE-K COMMONS, LEFT	0.21	0.078	P				0.19	0.167	P	0.281	0.273	P				0.413	0.183	P	P	None	
20	B	PRE-K COMMONS, RIGHT	0.205	0.074	P				0.182	0.141	P	0.225	0.226	P				0.249	0.19	P	P	None	
21	B	1ST GRADE COMMONS, LEFT	0.214	0.08	P				0.221	0.147	P	0.312	0.199	P				0.448	0.164	P	P	None	
22	B	1ST GRADE COMMONS, RIGHT							0.219	0.158	P	0.25	0.205	P				0.287	0.184	P	P	None	
23	S/B	ROOM 137, LEFT	0.153	0.09	P				0.193	0.173	P	0.242	0.224	P				0.244	0.195	P	P	None	
24	S/B	ROOM 137, MIDDLE	0.163	0.09	P				0.19	0.156	P	0.223	0.189	P				0.243	0.2	P	P	None	
25	S/B	ROOM 137, RIGHT	0.155	0.083	P				0.182	0.151	P	0.228	0.2	P				0.223	0.198	P	P	None	
26	S/B	ROOM 138, LEFT	0.174	0.088	P				0.183	0.143	P	0.235	0.238	P				0.353	0.206	P	P	None	
27	S/B	ROOM 138, MIDDLE	0.2	0.086	P				0.207	0.194	P	0.226	0.202	P				0.372	0.212	P	P	None	
28	S/B	ROOM 138, RIGHT	0.192	0.094	P				0.207	0.195	P	0.254	0.247	P				0.359	0.176	P	P	None	
29	S/B	ROOM 139, LEFT	0.191	0.212	P				0.194	0.186	P	0.255	0.249	P				0.37	0.213	P	P	None	
30	S/B	ROOM 139, MIDDLE	0.208	0.208	P				0.149	0.159	P	0.223	0.18	P				0.238	0.19	P	P	None	
31	S/B	ROOM 139, RIGHT	0.213	0.214	P				0.182	0.174	P	0.255	0.196	P				0.296	0.214	P	P	None	
32	B	1ST GRADE COMMON 140, LEFT	0.238	0.068	P				0.143	0.126	P	0.258	0.236	P				0.289	0.147	P	P	None	
33	B	1ST GRADE COMMON 140, RIGHT	0.119	0.067	P				0.195	0.135	P	0.226	0.173	P				0.267	0.148	P	P	None	
34	S/B	ROOM 142	0.227	0.173	P				0.151	0.165	P	0.226	0.255	P				0.306	0.292	P	P	None	
35	S/B	ROOM 143	0.218	0.201	P				0.204	0.17	P	0.222	0.2	P				0.338	0.291	P	P	None	
36	S/B	ROOM 140	0.173	0.084	P				0.157	0.177	P	0.185	0.223	P				0.221	0.238	P	P	None	
37	S/B	ROOM 144	0.215	0.233	P				0.174	0.176	P	0.313	0.326	P				0.362	0.386	P	P	None	
38	S/B	ROOM 147, SPEC. ED.	0.203	0.156	P				0.185	0.191	P	0.432	0.419	P				0.405	0.242	P	P	None	
39	S	ROOM 148A, SPEC ED. KITCHEN	0.158	0.122	P				0.175	0.184	P	0.256	0.243	P				0.382	0.228	P	P	None	
40	S/B	ROOM 148, SPEC ED.	0.206	0.096	P	0.159	0.146	P	0.196	0.174	P	0.619	0.289	P				0.456	0.212	P	P	None	
41	S/B	ROOM 149, RESOURCE	0.227	0.097	P				0.164	0.173	P	0.236	0.229	P				0.392	0.201	P	P	None	
42	S	KITCHEN	0.132	0.064	P	0.172	0.059	P	0.159	0.113	P	0.148	0.222	P				0.168	0.07	P	P	None	
43	S	KITCHEN, LEFT	0.198	0.062	P	0.157	0.068	P	0.17	0.101	P	0.216	0.149	P				0.305	0.138	P	P	None	
44	S	KITCHEN, RIGHT	0.109	0.15	P	0.123	0.076	P	0.167	0.107	P	0.203	0.145	P				0.315	0.102	P	P	None	
45	S	KITCHEN	0.183	0.056	P	0.222	0.127	P	0.104	0.103	P	0.243	0.153	P				0.433	0.146	P	P	None	
46	S	KITCHEN	0.221	0.059	P				0.157	0.106	P	0.226	0.17	P				0.418	0.07	P	P	None	
47	K	KITCHEN	0.246	0.046	P	0.223	0.043	P				0.199	0.286	P				0.432	0.454	P	P	None	
48	S	162B, CUSTODIAN LUNCH ROOM	0.163	0.149	P				0.266	0.235	P	0.358	0.334	P				0.359	0.28	P	P	None	
49	B	BY SECURITY, LEFT	0.165	0.145	P				0.168	0.154	P	0.247	0.228	P				0.271	0.218	P	P	None	
50	B	BY SECURITY, RIGHT	0.154	0.157	P				0.154	0.156	P	0.223	0.219	P				0.205	0.203	P	P	None	
51	S/B	FITNESS ROOM 185							0.281	0.168	P	0.323	0.226	P				0.125	0.124	P	P	None	
52	B	BY ROOM 199, LEFT	0.192	0.103	P				0.166	0.172	P	0.306	0.267	P				0.359	0.235	P	P	None	
53	B	BY ROOM 199, RIGHT	0.199	0.099	P				0.148	0.161	P	0.254	0.223	P				0.364	0.151	P	P	None	

54	S/B	ROOM 199	0.229	0.172	P				0.311	0.304	P	0.412	0.336	P					P	None		
55	S/B	190, SIX GRADE COMMON	0.229	0.175	P				0.309	0.238	P	0.237	0.228	P			0.365	0.387	P	P	None	
56	S	101E, STAFF LOUNGE	0.31	0.278	P				0.211	0.247	P	0.22	0.267	P			0.398	0.293	P	P	None	
57	B	OFFICE AREA, LEFT	0.182	0.199	P				0.213	0.164	P	0.254	0.299	P			0.425	0.404	P	P	None	
58	B	OFFICE AREA, RIGHT	0.179	0.172	P				0.221	0.193	P	0.349	0.294	P			0.411	0.27	P	P	None	
59	S	CLINIC 102	0.241	0.146	P				0.204	0.185	P	0.211	0.208	P			0.279	0.187	P	P	None	
60	S	EXAM ROOM, 102E	0.197	0.194	P				0.251	0.562	P	0.216	0.316	P			0.366	0.346	P	P	None	
61	S	HEALTH LAB, 102C	0.171	0.085	P				0.173	0.278	P	0.155	0.214	P						P	None	
62	S/B	LIBRARY OFFICE, 210A	0.137	0.099	P				0.154	0.151	P	0.193	0.171	P			0.195	0.217	P	P	None	
63	B	2ND FLOOR, HALL, LEFT	0.14	0.159	P				0.147	0.131	P	0.228	0.182	P			0.25	0.204	P	P	None	
64	B	2ND FLOOR, HALL, RIGHT	0.152	0.147	P				0.189	0.136	P	0.218	0.169	P			0.366	0.211	P	P	None	
65	S	COMPUTER ROOM, 202, LEFT	0.23	0.259	P	0.169	0.229	P	0.165	0.198	P	0.191	0.224	P			0.311	0.469	P	P	None	
66	S	COMPUTER ROOM, 202, RIGHT	0.181	0.252	P				0.157	0.168	P	0.225	0.275	P			0.457	0.418	P	P	None	
67	S/B	MUSIC ROOM, 200	0.19	0.164	P				0.188	0.142	P	0.226	0.211	P			0.419	0.313	P	P	None	
69	S	2ND FLOOR, STAFF LUNCH ROOM, 281A	0.263	0.162	P	0.236	0.163	P	0.338	0.298	P	0.22	0.208	P			0.232	0.211	P	P	None	
70	S/B	2ND FLOOR, 290	0.21	0.196	P				0.233	0.22	P	0.252	0.266	P			0.357	0.458	P	P	None	
71	B	2ND FLOOR HALL, LEFT	0.128	0.103	P				0.18	0.161	P	0.338	0.235	P						P	None	
72	B	2ND FLOOR HALL, RIGHT	0.11	0.092	P				0.179	0.158	P	0.228	0.22	P			0.219	0.167	P	P	None	
73	S	ROOM 299	0.192	0.188	P				0.311	0.311	P	0.36	0.318	P						P	None	
74	S	STAFF WORK ROOM, 263	0.2	0.121	P				0.122	0.113	P	0.265	0.247	P			0.212	0.141	P	P	None	
75	S/B	ROOM 260	0.164	0.399	P	0.178	0.224	P	0.144	0.127	P	0.367	0.312	P			0.519	0.458	P	P	None	
76	B	240, LEFT	0.144	0.067	P												0.23	0.102	P	P	None	
77	B	240, RIGHT	0.092	0.064	P												0.344	0.109	P	P	None	
78	S/B	ROOM 242	0.145	0.098	P				0.195	0.187	P	0.247	0.218	P			0.363	0.189	P	P	None	
79	S/B	ROOM 243	0.162	0.101	P				0.156	0.182	P	0.211	0.231	P			0.231	0.137	P	P	None	
80	S/B	240	0.118	0.08	P				0.172	0.17	P	0.213	0.216	P			0.152	0.134	P	P	None	
81	S/B	ROOM 244	0.174	0.135	P				0.163	0.167	P	0.22	0.282	P	0.493	0.51	P	0.329	0.286	P	P	None
82	S/B	ROOM 247	0.169	0.137	P				0.174	0.196	P	0.229	0.242	P			0.422	0.286	P	P	None	
83	S/B	ROOM 248	0.173	0.076	P				0.207	0.151	P	0.202	0.223	P			0.321	0.175	P	P	None	
84	S/B	ROOM 249	0.153	0.078	P				0.118	0.116	P	0.208	0.2	P			0.299	0.168	P	P	None	
85	B	230, LEFT	0.249	0.2	P															P	None	
86	B	230, RIGHT	0.279	0.091	P				0.402	0.214	P	0.376	0.247	P			0.401	0.31	P	P	None	
87	S/B	230	0.17	0.222	P				0.214	0.248	P	0.192	0.198	P			0.439	0.333	P	P	None	
88	S/B	ROOM 239	0.157	0.178	P				0.21	0.199	P	0.209	0.206	P			0.374	0.393	P	P	None	
89	S/B	ROOM 238	0.192	0.16	P				0.196	0.228	P	0.201	0.241	P			0.441	0.399	P	P	None	
90	S/B	ROOM 237	0.219	0.075	P				0.182	0.185	P	0.218	0.232	P			0.395	0.34	P	P	None	
91	S/B	ROOM 234	0.188	0.163	P				0.191	0.195	P	0.249	0.237	P			0.364	0.247	P	P	None	
92	S/B	ROOM 233	0.196	0.143	P				0.207	0.204	P	0.229	0.227	P			0.444	0.348	P	P	None	
93	S/B	ROOM 232	0.198	0.058	P				0.161	0.146	P	0.219	0.235	P			0.364	0.174	P	P	None	
94	B	390, LEFT	0.161	0.17	P				0.213	0.158	P	0.337	0.262	P						P	None	
95	B	390, RIGHT	0.163	0.097	P				0.251	0.199	P									P	None	
96	S/B	ROOM 399	0.196	0.189	P				0.286	0.335	P	0.465	0.416	P						P	None	
97	S/B	390	0.212	0.19	P				0.244	0.2	P	0.267	0.225	P			0.371	0.425	P	P	None	

Table 5. Iron Test Results

FIXTURE INFORMATION			8/19/2009		7/20/2012		7/10/2015		11/2/2019		Summary Status	
Fixture ID	Type	Location	Flush 2m	Pass/Fail	Flush 2m	Pass/Fail	Flush 2m	Pass/Fail	Flush 2m	Pass/Fail	Pass/Fail	Status
07	BF	COMMONS AREA 4										
08	B	COMMONS AREA 4										
09	S	ROOM 123, STUDENT STORE										
10	S	ROOM 121, PTA										
11	S	ROOM 132, PRE-K LEFT			<0.05	P					P	None
12	S	ROOM 132, PRE-K RIGHT					<0.05	P			P	None
13	S	ROOM 133 PRE-K, LEFT										
14	S	ROOM 133 PRE-K, RIGHT										
15	S	ROOM 131D, PRE-K KITCHEN										
16	S	ROOM 131D, PRE-K KITCHEN							<0.05	P	P	None
17	S	ROOM 134 PRE-K, LEFT										
18	S	ROOM 134 PRE-K, RIGHT	<0.05	P							P	None
19	B	PRE-K COMMONS, LEFT			<0.05	P					P	None
20	B	PRE-K COMMONS, RIGHT					<0.05	P			P	None
21	B	1ST GRADE COMMONS, LEFT										
22	B	1ST GRADE COMMONS, RIGHT										
23	S/B	ROOM 137, LEFT										
24	S/B	ROOM 137, MIDDLE										
25	S/B	ROOM 137, RIGHT										
26	S/B	ROOM 138, LEFT										
27	S/B	ROOM 138, MIDDLE										
28	S/B	ROOM 138, RIGHT										
29	S/B	ROOM 139, LEFT										
30	S/B	ROOM 139, MIDDLE										
31	S/B	ROOM 139, RIGHT										
32	B	1ST GRADE COMMON 140, LEFT										
33	B	1ST GRADE COMMON 140, RIGHT										
34	S/B	ROOM 142										
35	S/B	ROOM 143										
36	S/B	ROOM 140										
37	S/B	ROOM 144										
38	S/B	ROOM 147, SPEC. ED.	<0.05	P							P	None
39	S	ROOM 148A, SPEC ED. KITCHEN			<0.05	P					P	None
40	S/B	ROOM 148, SPEC ED.					<0.05	P			P	None
41	S/B	ROOM 149, RESOURCE										
42	S	KITCHEN										
43	S	KITCHEN, LEFT										
44	S	KITCHEN, RIGHT							<0.05	P	P	None
45	S	KITCHEN										
46	S	KITCHEN										
47	K	KITCHEN										
48	S	162B, CUSTODIAN LUNCH ROOM										
49	B	BY SECURITY, LEFT										
50	B	BY SECURITY, RIGHT										
51	S/B	FITNESS ROOM 185										
52	B	BY ROOM 199, LEFT										
53	B	BY ROOM 199, RIGHT										
54	S/B	ROOM 199										

55	S/B	190, SIX GRADE COMMON										
56	S	101E, STAFF LOUNGE							<0.05	P	P	None
57	B	OFFICE AREA, LEFT										
58	B	OFFICE AREA, RIGHT										
59	S	CLINIC 102										
60	S	EXAM ROOM, 102E	<0.05	P							P	None
61	S	HEALTH LAB, 102C										
62	S/B	LIBRARY OFFICE, 210A										
63	B	2ND FLOOR, HALL, LEFT										
64	B	2ND FLOOR, HALL, RIGHT										
65	S	COMPUTER ROOM, 202, LEFT										
66	S	COMPUTER ROOM, 202, RIGHT										
67	S/B	MUSIC ROOM, 200										
69	S	2ND FLOOR, STAFF LUNCH ROOM, 281A							<0.05	P	P	None
70	S/B	2ND FLOOR, 290	<0.05	P							P	None
71	B	2ND FLOOR HALL, LEFT			<0.05	P					P	None
72	B	2ND FLOOR HALL, RIGHT					<0.05	P			P	None
73	S	ROOM 299										
74	S	STAFF WORK ROOM, 263										
75	S/B	ROOM 260										
76	B	240, LEFT										
77	B	240, RIGHT										
78	S/B	ROOM 242										
79	S/B	ROOM 243										
80	S/B	240										
81	S/B	ROOM 244										
82	S/B	ROOM 247	<0.05	P							P	None
83	S/B	ROOM 248			<0.05	P					P	None
84	S/B	ROOM 249					<0.05	P	<0.05	P	P	None
85	B	230, LEFT										
86	B	230, RIGHT										
87	S/B	230										
88	S/B	ROOM 239										
89	S/B	ROOM 238										
90	S/B	ROOM 237										
91	S/B	ROOM 234	<0.05	P							P	None
92	S/B	ROOM 233			<0.05	P					P	None
93	S/B	ROOM 232					<0.05	P	<0.05	P	P	None
94	B	390, LEFT										
95	B	390, RIGHT										
96	S/B	ROOM 399										
97	S/B	390	<0.05	P							P	None

Table 6. Service Entry Test Results

Test Results (Service Entry/SE, Units as Shown)						
SOURCE INFORMATION			Most Recent Sampling			
Fixture ID	Type	Location	Item	Sampled	Max Value	Pass/Fail
00	SE	kitchen fixture 46	Arsenic	10-Jul-15	2 ppb	P
00	SE	kitchen fixture 46	Cadmium	10-Jul-15	1 ppb	P
00	SE	kitchen fixture 46	Copper	10-Jul-15	0.092 ppm	P
00	SE	kitchen fixture 46	Iron	10-Jul-15	<0.05 ppm	P
00	SE	kitchen fixture 46	Lead	10-Jul-15	1 ppb	P
00	SE	kitchen fixture 46	Total Coliforms	10-Sep-09	<1 Colonies	P

"<" means: less than the value shown (below analytical detection limits).
 "n/a" means: not applicable.

Table 7. Bacteriological Test Results

Bacteriological Characteristics

Bacteriological testing of selected samples indicated no (zero) coliform bacteria.