

**Seattle Public Schools
Drinking Water Quality Program**

**Results of Water Quality Testing
for
Wing Luke Elementary School**

Updated May 28, 2021

General Information:

Plumbing piping materials: mainly copper

Remediation plan:

This remediation plan is based on a Water Quality policy approved by the School Board. The policy includes standards for the presence of lead, cadmium, copper, iron and other substances in drinking water.

Sinks (S in the report) are not considered drinking water sources. We recognize that there is the potential for students to want to drink from classroom hand-washing sinks, so we test all of those. Where a student's choice to drink from a sink could be a problem, we post a reminder sign, as we do at all restroom sinks.

Status:

Policy Criteria:

All sources meet the policy criteria.

Two sinks in the nurse office (#1, #2) will be tested when they are connected.

Follow-up monitoring: Will be performed in 2023-2024.

Service: The school will be flushed after any breaks longer than five days.

Water Quality Testing Results:

Legend

| Symbol | Definition |
|------------|--|
| SE | service entry (main) |
| B | bubbler |
| S | sink (faucet) |
| B/S | sink/bubbler combination |
| S/B | sink/bubbler combination |
| ppb | parts per billion |
| ppm | parts per million |
| NA | not applicable |
| None | no action required |
| Unk | unknown status or action |
| Sample | sample needs to be taken |
| Re-test | fixture needs to be resampled |
| Conf | resample to confirm measurement |
| No flush | not flushed before sampling |
| Sink | sampled faucet of S/B combo |
| Used | recently used; no 1st draw sample possible |
| PS | post sign |
| Disable(d) | fixture disabled in response to water quality testing |
| BDSS | Bubbler disabled, sign on sink |
| IF | install filter |
| RB | replace bubbler |
| RB/IF | replace bubbler and/or install filter |
| RF | replace faucet |
| RF/IF | replace faucet and/or install filter |
| BW | disable fixture and provide bottled water until remediated |
| Leaks | leaking fixture |
| NW | not working properly (sample S when B of S/B NW) |
| OS | out of service - disabled until fixed |
| RS | return to service - now passes testing |
| Rem | Removed from system - no longer exists |

Table 1. Summary of Results

| FIXTURE INFORMATION | | | LEAD | | CADMIUM | | COPPER | | IRON | | OK? |
|---------------------|------|--------------------------------------|-----------|--------|-----------|--------|-----------|--------|-----------|--------|---------------|
| Fixture ID | Type | Location | Pass/Fail | Status | Pass/Fail | Status | Pass/Fail | Status | Pass/Fail | Status | Yes/No/Status |
| 01 | S | NURSE OFFICE | | Sample | | Sample | | Sample | | | Sample |
| 02 | S | NURSE OFFICE, ROOM 14B | | Sample | | Sample | | Sample | | | Sample |
| 03 | S | STAFF LOUGE | P | None | P | None | P | None | | | Yes |
| 04 | S/B | SPECIAL ED. 102 | P | None | P | None | P | None | | | Yes |
| 05 | S/B | SPECIAL ED. 101 | P | None | P | None | P | None | P | None | Yes |
| 06 | S | ART ROOM 101 | P | None | P | None | P | None | | | Yes |
| 07 | S | ART ROOM 101 | P | None | P | None | P | None | | | Yes |
| 08 | S | ART ROOM 101, LEFT | P | None | P | None | P | None | | | Yes |
| 09 | S | ART ROOM 101, MIDDLE | P | None | P | None | P | None | | | Yes |
| 10 | S | ART ROOM 101, RIGHT | P | None | P | None | P | None | P | None | Yes |
| 11 | S/B | ROOM 106 | P | None | P | None | P | None | | | Yes |
| 12 | S/B | ROOM 110 | P | None | P | None | P | None | | | Yes |
| 13 | S/B | ROOM 107 | P | None | P | None | P | None | | | Yes |
| 14 | S/B | ROOM 108 | P | None | P | None | P | None | | | Yes |
| 15 | S/B | ROOM 109 | P | None | P | None | P | None | P | None | Yes |
| 16 | S/B | ROOM 104 | P | None | P | None | P | None | | | Yes |
| 17 | B | FIRST FLOOR HALLWAY, NEAR 111, LEFT | P | None | P | None | P | None | | | Yes |
| 18 | B | FIRST FLOOR HALLWAY, NEAR 111, RIGHT | P | None | P | None | P | None | | | Yes |
| 19 | BF | FIRST FLOOR HALLWAY, NEAR 111 | P | None | P | None | P | None | | | Yes |
| 20 | S | COMMONS | P | None | P | None | P | None | P | None | Yes |
| 21 | S | KITCHEN | P | None | P | None | P | None | | | Yes |
| 22 | S | KITCHEN | P | None | P | None | P | None | | | Yes |
| 23 | S | KITCHEN | P | None | P | None | P | None | | | Yes |
| 24 | S | KITCHEN, DOUBLE, LEFT | P | None | P | None | P | None | | | Yes |
| 25 | S | KITCHEN, DOUBLE, RIGHT | P | None | P | None | P | None | P | None | Yes |
| 26 | S/B | STAGE | P | None | P | None | P | None | | | Yes |
| 27 | B | COMMONS, LEFT | P | None | P | None | P | None | | | Yes |
| 28 | B | COMMONS, RIGHT | P | None | P | None | P | None | | | Yes |
| 29 | BF | COMMONS | P | None | P | None | P | None | | | Yes |
| 30 | B | GYM, LEFT | P | None | P | None | P | None | P | None | Yes |
| 31 | B | GYM, RIGHT | P | None | P | None | P | None | | | Yes |
| 32 | BF | GYM | P | None | P | None | P | None | | | Yes |
| 33 | S | CUSTODIAL OFFICE, 170 | P | None | P | None | P | None | | | Yes |
| 34 | B | GYM, LEFT | P | None | P | None | P | None | | | Yes |
| 35 | B | GYM, RIGHT | P | None | P | None | P | None | P | None | Yes |
| 36 | BF | GYM | P | None | P | None | P | None | | | Yes |
| 37 | S | CHILDCARE, 113, LEFT | P | None | P | None | P | None | | | Yes |
| 38 | S | CHILDCARE, 113, RIGHT | P | None | P | None | P | None | | | Yes |
| 39 | S | CHILDCARE, 113 | P | None | P | None | P | None | | | Yes |
| 40 | S | CHILDCARE, 114 | P | None | P | None | P | None | P | None | Yes |
| 41 | S | CHILDCARE, 114, LEFT | P | None | P | None | P | None | | | Yes |
| 42 | S | CHILDCARE, 114, RIGHT | P | None | P | None | P | None | | | Yes |
| 43 | S | CHILDCARE, KITCHEN | P | None | P | None | P | None | | | Yes |
| 44 | S | CHILDCARE, KITCHEN | P | None | P | None | P | None | | | Yes |
| 45 | S | CHILDCARE, KITCHEN | P | None | P | None | P | None | P | None | Yes |
| 46 | S/B | ROOM 201 | P | None | P | None | P | None | | | Yes |

| | | | | | | | | | | | |
|----|-----|--------------------------|---|------|---|------|---|------|---|------|-----|
| 47 | S/B | ROOM 202 | P | None | P | None | P | None | | | Yes |
| 48 | S/B | ROOM 203 | P | None | P | None | P | None | | | Yes |
| 49 | S/B | ROOM 204 | P | None | P | None | P | None | | | Yes |
| 50 | S/B | ROOM 206 | P | None | P | None | P | None | P | None | Yes |
| 51 | S/B | ROOM 207 | P | None | P | None | P | None | | | Yes |
| 52 | S/B | ROOM 208 | P | None | P | None | P | None | | | Yes |
| 53 | S/B | ROOM 209 | P | None | P | None | P | None | | | Yes |
| 54 | S/B | ROOM 210 | P | None | P | None | P | None | | | Yes |
| 55 | S/B | ROOM 211 | P | None | P | None | P | None | P | None | Yes |
| 56 | S/B | WORK ROOM 238 | P | None | P | None | P | None | | | Yes |
| 57 | S/B | ROOM 214 | P | None | P | None | P | None | | | Yes |
| 58 | S/B | ROOM 215 | P | None | P | None | P | None | | | Yes |
| 59 | S/B | ROOM 216 | P | None | P | None | P | None | | | Yes |
| 60 | S/B | ROOM 217 | P | None | P | None | P | None | P | None | Yes |
| 61 | S/B | ROOM 218 | P | None | P | None | P | None | | | Yes |
| 62 | S/B | ROOM 219 | P | None | P | None | P | None | | | Yes |
| 63 | B | SECOND FLOOR HALL, LEFT | P | None | P | None | P | None | | | Yes |
| 64 | B | SECOND FLOOR HALL, RIGHT | P | None | P | None | P | None | | | Yes |
| 65 | BF | SECOND FLOOR HALL | P | None | P | None | P | None | P | None | Yes |
| 66 | S | ROOM 221 | P | None | P | None | P | None | | | Yes |
| 67 | S | LIBRARY OFFICE, 222A | P | None | P | None | P | None | | | Yes |
| 68 | S/B | ROOM 105 | P | None | P | None | P | None | | | Yes |
| 69 | B | SECOND FLOOR HALL, LEFT | P | None | P | None | P | None | | | Yes |
| 70 | B | SECOND FLOOR HALL, RIGHT | P | None | P | None | P | None | P | None | Yes |
| 71 | BF | SECOND FLOOR HALL | P | None | P | None | P | None | | | Yes |
| 90 | Ice | NURSE OFFICE, ICE MAKER | P | None | P | None | P | None | P | None | Yes |

Table 2. Lead Test Results

| FIXTURE INFORMATION | | | 3/16/2021 | | | 5/7/2021 | | | Summary Status | |
|---------------------|------|--------------------------------------|-----------|-----------|-----------|----------|-----------|-----------|----------------|--------|
| Fixture ID | Type | Location | 1st Draw | Flush 30s | Pass/Fail | 1st Draw | Flush 30s | Pass/Fail | Pass/Fail | Status |
| 01 | S | NURSE OFFICE | | | | | | | | Sample |
| 02 | S | NURSE OFFICE, ROOM 14B | | | | | | | | Sample |
| 03 | S | STAFF LOUGE | <1 | <1 | P | | | | P | None |
| 04 | S/B | SPECIAL ED. 102 | <1 | <1 | P | | | | P | None |
| 05 | S/B | SPECIAL ED. 101 | <1 | <1 | P | | | | P | None |
| 06 | S | ART ROOM 101 | <1 | <1 | P | | | | P | None |
| 07 | S | ART ROOM 101 | <1 | <1 | P | | | | P | None |
| 08 | S | ART ROOM 101, LEFT | <1 | <1 | P | | | | P | None |
| 09 | S | ART ROOM 101, MIDDLE | <1 | <1 | P | | | | P | None |
| 10 | S | ART ROOM 101, RIGHT | <1 | <1 | P | | | | P | None |
| 11 | S/B | ROOM 106 | <1 | <1 | P | | | | P | None |
| 12 | S/B | ROOM 110 | <1 | <1 | P | | | | P | None |
| 13 | S/B | ROOM 107 | <1 | <1 | P | | | | P | None |
| 14 | S/B | ROOM 108 | <1 | <1 | P | | | | P | None |
| 15 | S/B | ROOM 109 | <1 | <1 | P | | | | P | None |
| 16 | S/B | ROOM 104 | <1 | <1 | P | | | | P | None |
| 17 | B | FIRST FLOOR HALLWAY, NEAR 111, LEFT | <1 | <1 | P | | | | P | None |
| 18 | B | FIRST FLOOR HALLWAY, NEAR 111, RIGHT | <1 | <1 | P | | | | P | None |
| 19 | BF | FIRST FLOOR HALLWAY, NEAR 111 | <1 | <1 | P | | | | P | None |
| 20 | S | COMMONS | <1 | <1 | P | | | | P | None |
| 21 | S | KITCHEN | <1 | <1 | P | | | | P | None |
| 22 | S | KITCHEN | <1 | <1 | P | | | | P | None |
| 23 | S | KITCHEN | <1 | <1 | P | | | | P | None |
| 24 | S | KITCHEN, DOUBLE, LEFT | 1 | <1 | P | | | | P | None |
| 25 | S | KITCHEN, DOUBLE, RIGHT | <1 | <1 | P | | | | P | None |
| 26 | S/B | STAGE | <1 | <1 | P | | | | P | None |
| 27 | B | COMMONS, LEFT | <1 | <1 | P | | | | P | None |
| 28 | B | COMMONS, RIGHT | <1 | <1 | P | | | | P | None |
| 29 | BF | COMMONS | <1 | <1 | P | | | | P | None |
| 30 | B | GYM, LEFT | <1 | <1 | P | | | | P | None |
| 31 | B | GYM, RIGHT | <1 | <1 | P | | | | P | None |
| 32 | BF | GYM | <1 | <1 | P | | | | P | None |
| 33 | S | CUSTODIAL OFFICE, 170 | <1 | <1 | P | | | | P | None |
| 34 | B | GYM, LEFT | <1 | <1 | P | | | | P | None |
| 35 | B | GYM, RIGHT | <1 | <1 | P | | | | P | None |
| 36 | BF | GYM | <1 | <1 | P | | | | P | None |
| 37 | S | CHILDCARE, 113, LEFT | <1 | <1 | P | | | | P | None |
| 38 | S | CHILDCARE, 113, RIGHT | <1 | <1 | P | | | | P | None |
| 39 | S | CHILDCARE, 113 | <1 | <1 | P | | | | P | None |
| 40 | S | CHILDCARE, 114 | <1 | <1 | P | | | | P | None |
| 41 | S | CHILDCARE, 114, LEFT | <1 | <1 | P | | | | P | None |
| 42 | S | CHILDCARE, 114, RIGHT | <1 | <1 | P | | | | P | None |
| 43 | S | CHILDCARE, KITCHEN | 3 | <1 | P | | | | P | None |
| 44 | S | CHILDCARE, KITCHEN | <1 | <1 | P | | | | P | None |
| 45 | S | CHILDCARE, KITCHEN | <1 | <1 | P | | | | P | None |
| 46 | S/B | ROOM 201 | <1 | <1 | P | | | | P | None |
| 47 | S/B | ROOM 202 | <1 | <1 | P | | | | P | None |
| 48 | S/B | ROOM 203 | <1 | <1 | P | | | | P | None |

| | | | | | | | | | | |
|----|-----|--------------------------|----|----|---|----|----|---|---|------|
| 49 | S/B | ROOM 204 | <1 | <1 | P | | | | P | None |
| 50 | S/B | ROOM 206 | <1 | <1 | P | | | | P | None |
| 51 | S/B | ROOM 207 | <1 | <1 | P | | | | P | None |
| 52 | S/B | ROOM 208 | <1 | <1 | P | | | | P | None |
| 53 | S/B | ROOM 209 | <1 | <1 | P | | | | P | None |
| 54 | S/B | ROOM 210 | <1 | <1 | P | | | | P | None |
| 55 | S/B | ROOM 211 | <1 | <1 | P | | | | P | None |
| 56 | S/B | WORK ROOM 238 | <1 | <1 | P | | | | P | None |
| 57 | S/B | ROOM 214 | <1 | <1 | P | | | | P | None |
| 58 | S/B | ROOM 215 | <1 | <1 | P | | | | P | None |
| 59 | S/B | ROOM 216 | <1 | <1 | P | | | | P | None |
| 60 | S/B | ROOM 217 | <1 | <1 | P | | | | P | None |
| 61 | S/B | ROOM 218 | <1 | <1 | P | | | | P | None |
| 62 | S/B | ROOM 219 | <1 | <1 | P | | | | P | None |
| 63 | B | SECOND FLOOR HALL, LEFT | <1 | <1 | P | | | | P | None |
| 64 | B | SECOND FLOOR HALL, RIGHT | <1 | <1 | P | | | | P | None |
| 65 | BF | SECOND FLOOR HALL | <1 | <1 | P | | | | P | None |
| 66 | S | ROOM 221 | <1 | <1 | P | | | | P | None |
| 67 | S | LIBRARY OFFICE, 222A | <1 | <1 | P | | | | P | None |
| 68 | S/B | ROOM 105 | <1 | <1 | P | | | | P | None |
| 69 | B | SECOND FLOOR HALL, LEFT | <1 | <1 | P | | | | P | None |
| 70 | B | SECOND FLOOR HALL, RIGHT | <1 | <1 | P | | | | P | None |
| 71 | BF | SECOND FLOOR HALL | <1 | <1 | P | | | | P | None |
| 90 | Ice | NURSE OFFICE, ICE MAKER | 39 | 13 | | <1 | <1 | P | P | None |

Table 3. Cadmium Test Results

| FIXTURE INFORMATION | | | 3/16/2021 | | | 5/7/2021 | | | Summary Status | |
|---------------------|------|--------------------------------------|-----------|-----------|-----------|----------|-----------|-----------|----------------|--------|
| Fixture ID | Type | Location | 1st Draw | Flush 30s | Pass/Fail | 1st Draw | Flush 30s | Pass/Fail | Pass/Fail | Status |
| 01 | S | NURSE OFFICE | | | | | | | | sanple |
| 02 | S | NURSE OFFICE, ROOM 14B | | | | | | | | Sample |
| 03 | S | STAFF LOUGE | <1 | <1 | P | | | | P | None |
| 04 | S/B | SPECIAL ED. 102 | <1 | <1 | P | | | | P | None |
| 05 | S/B | SPECIAL ED. 101 | <1 | <1 | P | | | | P | None |
| 06 | S | ART ROOM 101 | <1 | <1 | P | | | | P | None |
| 07 | S | ART ROOM 101 | <1 | <1 | P | | | | P | None |
| 08 | S | ART ROOM 101, LEFT | <1 | <1 | P | | | | P | None |
| 09 | S | ART ROOM 101, MIDDLE | <1 | <1 | P | | | | P | None |
| 10 | S | ART ROOM 101, RIGHT | <1 | <1 | P | | | | P | None |
| 11 | S/B | ROOM 106 | <1 | <1 | P | | | | P | None |
| 12 | S/B | ROOM 110 | <1 | <1 | P | | | | P | None |
| 13 | S/B | ROOM 107 | <1 | <1 | P | | | | P | None |
| 14 | S/B | ROOM 108 | <1 | <1 | P | | | | P | None |
| 15 | S/B | ROOM 109 | <1 | <1 | P | | | | P | None |
| 16 | S/B | ROOM 104 | <1 | <1 | P | | | | P | None |
| 17 | B | FIRST FLOOR HALLWAY, NEAR 111, LEFT | <1 | <1 | P | | | | P | None |
| 18 | B | FIRST FLOOR HALLWAY, NEAR 111, RIGHT | <1 | <1 | P | | | | P | None |
| 19 | BF | FIRST FLOOR HALLWAY, NEAR 111 | <1 | <1 | P | | | | P | None |
| 20 | S | COMMONS | <1 | <1 | P | | | | P | None |
| 21 | S | KITCHEN | <1 | <1 | P | | | | P | None |
| 22 | S | KITCHEN | <1 | <1 | P | | | | P | None |
| 23 | S | KITCHEN | <1 | <1 | P | | | | P | None |
| 24 | S | KITCHEN, DOUBLE, LEFT | <1 | <1 | P | | | | P | None |
| 25 | S | KITCHEN, DOUBLE, RIGHT | <1 | <1 | P | | | | P | None |
| 26 | S/B | STAGE | <1 | <1 | P | | | | P | None |
| 27 | B | COMMONS, LEFT | <1 | <1 | P | | | | P | None |
| 28 | B | COMMONS, RIGHT | <1 | <1 | P | | | | P | None |
| 29 | BF | COMMONS | <1 | <1 | P | | | | P | None |
| 30 | B | GYM, LEFT | <1 | <1 | P | | | | P | None |
| 31 | B | GYM, RIGHT | <1 | <1 | P | | | | P | None |
| 32 | BF | GYM | <1 | <1 | P | | | | P | None |
| 33 | S | CUSTODIAL OFFICE, 170 | <1 | <1 | P | | | | P | None |
| 34 | B | GYM, LEFT | <1 | <1 | P | | | | P | None |
| 35 | B | GYM, RIGHT | <1 | <1 | P | | | | P | None |
| 36 | BF | GYM | <1 | <1 | P | | | | P | None |
| 37 | S | CHILDCARE, 113, LEFT | <1 | <1 | P | | | | P | None |
| 38 | S | CHILDCARE, 113, RIGHT | <1 | <1 | P | | | | P | None |
| 39 | S | CHILDCARE, 113 | <1 | <1 | P | | | | P | None |
| 40 | S | CHILDCARE, 114 | <1 | <1 | P | | | | P | None |
| 41 | S | CHILDCARE, 114, LEFT | <1 | <1 | P | | | | P | None |
| 42 | S | CHILDCARE, 114, RIGHT | <1 | <1 | P | | | | P | None |
| 43 | S | CHILDCARE, KITCHEN | <1 | <1 | P | | | | P | None |
| 44 | S | CHILDCARE, KITCHEN | <1 | <1 | P | | | | P | None |
| 45 | S | CHILDCARE, KITCHEN | <1 | <1 | P | | | | P | None |
| 46 | S/B | ROOM 201 | <1 | <1 | P | | | | P | None |
| 47 | S/B | ROOM 202 | <1 | <1 | P | | | | P | None |

| | | | | | | | | | | |
|----|-----|--------------------------|----|----|---|----|----|---|---|------|
| 48 | S/B | ROOM 203 | <1 | <1 | P | | | | P | None |
| 49 | S/B | ROOM 204 | <1 | <1 | P | | | | P | None |
| 50 | S/B | ROOM 206 | <1 | <1 | P | | | | P | None |
| 51 | S/B | ROOM 207 | <1 | <1 | P | | | | P | None |
| 52 | S/B | ROOM 208 | <1 | <1 | P | | | | P | None |
| 53 | S/B | ROOM 209 | <1 | <1 | P | | | | P | None |
| 54 | S/B | ROOM 210 | <1 | <1 | P | | | | P | None |
| 55 | S/B | ROOM 211 | <1 | <1 | P | | | | P | None |
| 56 | S/B | WORK ROOM 238 | <1 | <1 | P | | | | P | None |
| 57 | S/B | ROOM 214 | <1 | <1 | P | | | | P | None |
| 58 | S/B | ROOM 215 | <1 | <1 | P | | | | P | None |
| 59 | S/B | ROOM 216 | <1 | <1 | P | | | | P | None |
| 60 | S/B | ROOM 217 | <1 | <1 | P | | | | P | None |
| 61 | S/B | ROOM 218 | <1 | <1 | P | | | | P | None |
| 62 | S/B | ROOM 219 | <1 | <1 | P | | | | P | None |
| 63 | B | SECOND FLOOR HALL, LEFT | <1 | <1 | P | | | | P | None |
| 64 | B | SECOND FLOOR HALL, RIGHT | <1 | <1 | P | | | | P | None |
| 65 | BF | SECOND FLOOR HALL | <1 | <1 | P | | | | P | None |
| 66 | S | ROOM 221 | <1 | <1 | P | | | | P | None |
| 67 | S | LIBRARY OFFICE, 222A | <1 | <1 | P | | | | P | None |
| 68 | S/B | ROOM 105 | <1 | <1 | P | | | | P | None |
| 69 | B | SECOND FLOOR HALL, LEFT | <1 | <1 | P | | | | P | None |
| 70 | B | SECOND FLOOR HALL, RIGHT | <1 | <1 | P | | | | P | None |
| 71 | BF | SECOND FLOOR HALL | <1 | <1 | P | | | | P | None |
| 90 | Ice | NURSE OFFICE, ICE MAKER | <1 | <1 | P | <1 | <1 | P | P | None |

Table 4. Copper Test Results

| FIXTURE INFORMATION | | | 3/16/2021 | | | 5/7/2021 | | | Summary Status | |
|---------------------|------|--------------------------------------|-----------|-----------|-----------|----------|-----------|-----------|----------------|--------|
| Fixture ID | Type | Location | 1st Draw | Flush 30s | Pass/Fail | 1st Draw | Flush 30s | Pass/Fail | Pass/Fail | Status |
| 01 | S | NURSE OFFICE | | | | | | | | Sample |
| 02 | S | NURSE OFFICE, ROOM 14B | | | | | | | | Sample |
| 03 | S | STAFF LOUGE | 0.198 | 0.199 | P | | | | P | None |
| 04 | S/B | SPECIAL ED. 102 | 0.302 | 0.207 | P | | | | P | None |
| 05 | S/B | SPECIAL ED. 101 | 0.208 | 0.213 | P | | | | P | None |
| 06 | S | ART ROOM 101 | 0.198 | 0.235 | P | | | | P | None |
| 07 | S | ART ROOM 101 | 0.281 | 0.241 | P | | | | P | None |
| 08 | S | ART ROOM 101, LEFT | 0.412 | 0.404 | P | | | | P | None |
| 09 | S | ART ROOM 101, MIDDLE | 0.229 | 0.178 | P | | | | P | None |
| 10 | S | ART ROOM 101, RIGHT | 0.374 | 0.163 | P | | | | P | None |
| 11 | S/B | ROOM 106 | 0.31 | 0.342 | P | | | | P | None |
| 12 | S/B | ROOM 110 | 0.27 | 0.418 | P | | | | P | None |
| 13 | S/B | ROOM 107 | 0.392 | 0.344 | P | | | | P | None |
| 14 | S/B | ROOM 108 | 0.284 | 0.226 | P | | | | P | None |
| 15 | S/B | ROOM 109 | 0.281 | 0.204 | P | | | | P | None |
| 16 | S/B | ROOM 104 | 0.195 | 0.178 | P | | | | P | None |
| 17 | B | FIRST FLOOR HALLWAY, NEAR 111, LEFT | 0.451 | 0.203 | P | | | | P | None |
| 18 | B | FIRST FLOOR HALLWAY, NEAR 111, RIGHT | 0.183 | 0.182 | P | | | | P | None |
| 19 | BF | FIRST FLOOR HALLWAY, NEAR 111 | 0.272 | 0.172 | P | | | | P | None |
| 20 | S | COMMONS | 0.17 | 0.174 | P | | | | P | None |
| 21 | S | KITCHEN | 0.127 | 0.302 | P | | | | P | None |
| 22 | S | KITCHEN | 0.236 | 0.182 | P | | | | P | None |
| 23 | S | KITCHEN | 0.145 | 0.18 | P | | | | P | None |
| 24 | S | KITCHEN, DOUBLE, LEFT | 0.651 | 0.176 | P | | | | P | None |
| 25 | S | KITCHEN, DOUBLE, RIGHT | 0.133 | 0.209 | P | | | | P | None |
| 26 | S/B | STAGE | 0.173 | 0.136 | P | | | | P | None |
| 27 | B | COMMONS, LEFT | 0.141 | 0.093 | P | | | | P | None |
| 28 | B | COMMONS, RIGHT | 0.076 | 0.077 | P | | | | P | None |
| 29 | BF | COMMONS | 0.125 | 0.078 | P | | | | P | None |
| 30 | B | GYM, LEFT | 0.242 | 0.09 | P | | | | P | None |
| 31 | B | GYM, RIGHT | 0.081 | 0.068 | P | | | | P | None |
| 32 | BF | GYM | 0.128 | 0.088 | P | | | | P | None |
| 33 | S | CUSTODIAL OFFICE, 170 | 0.143 | 0.041 | P | | | | P | None |
| 34 | B | GYM, LEFT | 0.453 | 0.452 | P | | | | P | None |
| 35 | B | GYM, RIGHT | 0.49 | 0.218 | P | | | | P | None |
| 36 | BF | GYM | 0.475 | 0.218 | P | | | | P | None |
| 37 | S | CHILDCARE, 113, LEFT | 0.228 | 0.291 | P | | | | P | None |
| 38 | S | CHILDCARE, 113, RIGHT | 0.294 | 0.338 | P | | | | P | None |
| 39 | S | CHILDCARE, 113 | 0.175 | 0.359 | P | | | | P | None |
| 40 | S | CHILDCARE, 114 | 0.194 | 0.262 | P | | | | P | None |
| 41 | S | CHILDCARE, 114, LEFT | 0.202 | 0.241 | P | | | | P | None |
| 42 | S | CHILDCARE, 114, RIGHT | 0.216 | 0.188 | P | | | | P | None |
| 43 | S | CHILDCARE, KITCHEN | 0.45 | 0.308 | P | | | | P | None |
| 44 | S | CHILDCARE, KITCHEN | 0.169 | 0.298 | P | | | | P | None |
| 45 | S | CHILDCARE, KITCHEN | 0.183 | 0.247 | P | | | | P | None |
| 46 | S/B | ROOM 201 | 0.286 | 0.216 | P | | | | P | None |
| 47 | S/B | ROOM 202 | 0.381 | 0.224 | P | | | | P | None |
| 48 | S/B | ROOM 203 | 0.21 | 0.242 | P | | | | P | None |

| | | | | | | | | | | |
|----|-----|--------------------------|-------|-------|---|-------|-------|---|---|------|
| 49 | S/B | ROOM 204 | 0.212 | 0.227 | P | | | | P | None |
| 50 | S/B | ROOM 206 | 0.161 | 0.2 | P | | | | P | None |
| 51 | S/B | ROOM 207 | 0.164 | 0.168 | P | | | | P | None |
| 52 | S/B | ROOM 208 | 0.249 | 0.213 | P | | | | P | None |
| 53 | S/B | ROOM 209 | 0.388 | 0.194 | P | | | | P | None |
| 54 | S/B | ROOM 210 | 0.255 | 0.205 | P | | | | P | None |
| 55 | S/B | ROOM 211 | 0.517 | 0.261 | P | | | | P | None |
| 56 | S/B | WORK ROOM 238 | 0.286 | 0.214 | P | | | | P | None |
| 57 | S/B | ROOM 214 | 0.283 | 0.322 | P | | | | P | None |
| 58 | S/B | ROOM 215 | 0.295 | 0.28 | P | | | | P | None |
| 59 | S/B | ROOM 216 | 0.386 | 0.32 | P | | | | P | None |
| 60 | S/B | ROOM 217 | 0.272 | 0.347 | P | | | | P | None |
| 61 | S/B | ROOM 218 | 0.326 | 0.255 | P | | | | P | None |
| 62 | S/B | ROOM 219 | 0.208 | 0.196 | P | | | | P | None |
| 63 | B | SECOND FLOOR HALL, LEFT | 0.34 | 0.282 | P | | | | P | None |
| 64 | B | SECOND FLOOR HALL, RIGHT | 0.387 | 0.236 | P | | | | P | None |
| 65 | BF | SECOND FLOOR HALL | 0.196 | 0.17 | P | | | | P | None |
| 66 | S | ROOM 221 | 0.431 | 0.258 | P | | | | P | None |
| 67 | S | LIBRARY OFFICE, 222A | 0.46 | 0.242 | P | | | | P | None |
| 68 | S/B | ROOM 105 | 0.446 | 0.394 | P | | | | P | None |
| 69 | B | SECOND FLOOR HALL, LEFT | 0.244 | 0.241 | P | | | | P | None |
| 70 | B | SECOND FLOOR HALL, RIGHT | 0.222 | 0.161 | P | | | | P | None |
| 71 | BF | SECOND FLOOR HALL | 0.166 | 0.146 | P | | | | P | None |
| 90 | Ice | NURSE OFFICE, ICE MAKER | | | | 0.228 | 0.231 | P | P | None |

Table 5. Iron Test Results

| FIXTURE INFORMATION | | | 3/16/2021 | | Summary Status | |
|---------------------|------|--------------------------------------|-----------|-----------|----------------|--------|
| Fixture ID | Type | Location | Flush 2m | Pass/Fail | Pass/Fail | Status |
| 01 | S | NURSE OFFICE | | | | |
| 02 | S | NURSE OFFICE, ROOM 14B | | | | |
| 03 | S | STAFF LOUGE | | | | |
| 04 | S/B | SPECIAL ED. 102 | | | | |
| 05 | S/B | SPECIAL ED. 101 | <0.05 | P | P | None |
| 06 | S | ART ROOM 101 | | | | |
| 07 | S | ART ROOM 101 | | | | |
| 08 | S | ART ROOM 101, LEFT | | | | |
| 09 | S | ART ROOM 101, MIDDLE | | | | |
| 10 | S | ART ROOM 101, RIGHT | <0.05 | P | P | None |
| 11 | S/B | ROOM 106 | | | | |
| 12 | S/B | ROOM 110 | | | | |
| 13 | S/B | ROOM 107 | | | | |
| 14 | S/B | ROOM 108 | | | | |
| 15 | S/B | ROOM 109 | <0.05 | P | P | None |
| 16 | S/B | ROOM 104 | | | | |
| 17 | B | FIRST FLOOR HALLWAY, NEAR 111, LEFT | | | | |
| 18 | B | FIRST FLOOR HALLWAY, NEAR 111, RIGHT | | | | |
| 19 | BF | FIRST FLOOR HALLWAY, NEAR 111 | | | | |
| 20 | S | COMMONS | <0.05 | P | P | None |
| 21 | S | KITCHEN | | | | |
| 22 | S | KITCHEN | | | | |
| 23 | S | KITCHEN | | | | |
| 24 | S | KITCHEN, DOUBLE, LEFT | | | | |
| 25 | S | KITCHEN, DOUBLE, RIGHT | <0.05 | P | P | None |
| 26 | S/B | STAGE | | | | |
| 27 | B | COMMONS, LEFT | | | | |
| 28 | B | COMMONS, RIGHT | | | | |
| 29 | BF | COMMONS | | | | |
| 30 | B | GYM, LEFT | <0.05 | P | P | None |
| 31 | B | GYM, RIGHT | | | | |
| 32 | BF | GYM | | | | |
| 33 | S | CUSTODIAL OFFICE, 170 | | | | |
| 34 | B | GYM, LEFT | | | | |
| 35 | B | GYM, RIGHT | <0.05 | P | P | None |
| 36 | BF | GYM | | | | |
| 37 | S | CHILDCARE, 113, LEFT | | | | |
| 38 | S | CHILDCARE, 113, RIGHT | | | | |
| 39 | S | CHILDCARE, 113 | | | | |
| 40 | S | CHILDCARE, 114 | <0.05 | P | P | None |
| 41 | S | CHILDCARE, 114, LEFT | | | | |
| 42 | S | CHILDCARE, 114, RIGHT | | | | |
| 43 | S | CHILDCARE, KITCHEN | | | | |
| 44 | S | CHILDCARE, KITCHEN | | | | |
| 45 | S | CHILDCARE, KITCHEN | <0.05 | P | P | None |
| 46 | S/B | ROOM 201 | | | | |
| 47 | S/B | ROOM 202 | | | | |

| | | | | | | | |
|----|-----|--------------------------|-------|---|---|------|--|
| 48 | S/B | ROOM 203 | | | | | |
| 49 | S/B | ROOM 204 | | | | | |
| 50 | S/B | ROOM 206 | <0.05 | P | P | None | |
| 51 | S/B | ROOM 207 | | | | | |
| 52 | S/B | ROOM 208 | | | | | |
| 53 | S/B | ROOM 209 | | | | | |
| 54 | S/B | ROOM 210 | | | | | |
| 55 | S/B | ROOM 211 | <0.05 | P | P | None | |
| 56 | S/B | WORK ROOM 238 | | | | | |
| 57 | S/B | ROOM 214 | | | | | |
| 58 | S/B | ROOM 215 | | | | | |
| 59 | S/B | ROOM 216 | | | | | |
| 60 | S/B | ROOM 217 | <0.05 | P | P | None | |
| 61 | S/B | ROOM 218 | | | | | |
| 62 | S/B | ROOM 219 | | | | | |
| 63 | B | SECOND FLOOR HALL, LEFT | | | | | |
| 64 | B | SECOND FLOOR HALL, RIGHT | | | | | |
| 65 | BF | SECOND FLOOR HALL | <0.05 | P | P | None | |
| 66 | S | ROOM 221 | | | | | |
| 67 | S | LIBRARY OFFICE, 222A | | | | | |
| 68 | S/B | ROOM 105 | | | | | |
| 69 | B | SECOND FLOOR HALL, LEFT | | | | | |
| 70 | B | SECOND FLOOR HALL, RIGHT | <0.05 | P | P | None | |
| 71 | BF | SECOND FLOOR HALL | | | | | |
| 90 | Ice | NURSE OFFICE, ICE MAKER | <0.05 | P | P | None | |

Table 6. Service Entry Test Results

"<" means: less than the value shown (below analytical detection limits).
"n/a" means: not applicable.

Table 7. Bacteriological Test Results

Bacteriological Characteristics

Bacteriological testing will be tested in the next round.