

Lead in School Drinking Water Report

View Ridge Elementary School



EXPLANATION OF TESTING AND RESULTS

Results in this report represent sampling conducted by Washington State Department of Health (DOH). Per [RCW 28A.210.410](#) sampling and testing protocols, samples were collected as first-draw. Depending on size of the school(s) and number of drinking water fixtures, multiple dates for collecting samples may have been necessary to meet sampling and testing protocols.

[RCW 28A.210.410](#) does not require remediation for fixtures testing at 5 ppb and under. DOH offers post-remediation testing only for outlets that initially tested above 5 ppb. After a school completes remediation, DOH will provide up to two post-remediation sampling visits. If after the second post-remediation sampling, outlets test above 5 ppb, the district will be responsible for finding a contractor to conduct additional sampling and testing. For questions regarding sampling, testing, and results, please email: leadfreekids@doh.wa.gov.

DEFINITIONS

Fixture Housing
Location

Room/space where
fixture is located
(i.e. room number,
gym, playground)

Fixture Housing Type

Structure that contains
the individual fixtures
where water samples
were collected from.
Fixture housing may
contain one or more
individual fixture for
sampling.

Fixture Location
Details

Location within a
room or space where
fixture housing is
located, starting to the
left of the entrance and
rotating clockwise, of
the total number of
fixture housings in a
room or space
(e.g. 1/5, 2/5)

Fixture Type

Tap, Sprayer, Water
Fountain, Water Bottle
Filler, Ice maker

Fixture Position

Left, Center, Right

Date(s) collected: 2025-09-17

Date(s) analyzed: 2025-09-23, 2025-09-25

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
1	409839	Main Building	Sink	Rm4	2 of 2 right	Tap	center	28
2	409826	Main Building	Sink	Library Office	1 of 1	Tap	center	26
3	409845	Main Building	Sink	Rm6	1 of 1	Tap	center	21
4	409813	Main Building	Sink	Rm16	1 of 1	Tap	center	7
5	409808	Main Building	Sink - Multi-Compartment	Kitchen	2 of 2 right	Tap	center	5
6	409810	Main Building	Sink	Rm17	1 of 1	Tap	center	4
7	409857	Main Building	Fountain/Tap Combo	Rm23	1 of 1	Tap	left	4
8	409814	Main Building	Sink	Rm13	1 of 1	Tap	center	2
9	409822	Main Building	Sink	Rm11	1 of 1	Tap	center	2
10	409840	Main Building	Sink	Rm5	1 of 1	Tap	center	2
11	409812	Main Building	Sink	Rm15	1 of 1	Tap	center	1
12	409817	Main Building	Sink	Rm12	1 of 1	Tap	center	1
13	409821	Main Building	Fountain	Right Of Rm11	1 of 1	Water Fountain	center	1
14	409831	Main Building	Sink	Office	1 of 1	Tap	center	1

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
15	409832	Main Building	Sink	Rm8	1 of 1	Tap	center	1
16	409833	Main Building	Sink	Rm1	1 of 1	Tap	center	1
17	409834	Main Building	Sink	Rm2	1 of 3 Main classroom	Tap	center	1
18	409850	Main Building	Fountain/Tap Combo	Rm26	1 of 1	Tap	left	1
19	409863	Main Building	Fountain/Tap Combo	Rm20	1 of 1	Tap	left	1
20	409806	Main Building	Sink - Multi-Compartment	Kitchen	1 of 2 left	Tap	center	<1
21	409807	Main Building	Sink - Multi-Compartment	Kitchen	1 of 2 left	Sprayer	center	<1
22	409809	Main Building	Fountain	Outside 17	1 of 1	Water Fountain	center	<1
23	409811	Main Building	Sink	Rm18	1 of 1	Tap	center	<1
24	409815	Main Building	Fountain	Outside Rm13	1 of 1	Water Fountain	center	<1
25	409816	Main Building	Sink	Rm14	1 of 1	Tap	center	<1
26	409818	Main Building	Fountain	Boys Restroom Across Rm11	1 of 3	Water Fountain	left	<1

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
27	409819	Main Building	Fountain	Boys Restroom Across Rm11	2 of 3	Water Fountain	center	<1
28	409820	Main Building	Fountain	Boys Restroom Across Rm11	3 of 3	Water Fountain	right	<1
29	409823	Main Building	Fountain	Girls Restroom Across Library	1 of 3	Water Fountain	left	<1
30	409824	Main Building	Fountain	Girls Restroom Across Library	2 of 3	Water Fountain	center	<1
31	409825	Main Building	Fountain	Girls Restroom Across Library	3 of 3	Water Fountain	right	<1
32	409827	Main Building	Fountain	Right Of Stage Door	1 of 1	Water Fountain	center	<1
33	409828	Main Building	Sink	Staff Lounge	1 of 1	Tap	center	<1
34	409829	Main Building	Fountain	Across Staff Lounge	1 of 1	Water Fountain	center	<1
35	409830	Main Building	Sink	Rm10 Nurse	1 of 1	Tap	center	<1
36	409835	Main Building	Sink	Rm2	2 of 3 classroom entry	Tap	center	<1
37	409836	Main Building	Fountain	Rm2	3 of 3 classroom entry	Water Fountain	center	<1

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
38	409837	Main Building	Sink	Rm3	1 of 1	Tap	center	<1
39	409838	Main Building	Sink	Rm4	1 of 2 left	Tap	center	<1
40	409841	Main Building	Fountain	Right Of Rm4	1 of 1	Water Fountain	center	<1
41	409842	Main Building	Fountain	Boys Restroom Across Rm6	1 of 3	Water Fountain	left	<1
42	409843	Main Building	Fountain	Boys Restroom Across Rm6	2 of 3	Water Fountain	center	<1
43	409844	Main Building	Fountain	Boys Restroom Across Rm6	3 of 3	Water Fountain	right	<1
44	409846	Main Building	Fountain	Girls Restroom Across Rm7	1 of 3	Water Fountain	left	<1
45	409847	Main Building	Fountain	Girls Restroom Across Rm7	2 of 3	Water Fountain	center	<1
46	409848	Main Building	Fountain	Girls Restroom Across Rm7	3 of 3	Water Fountain	right	<1
47	409849	Main Building	Fountain	Across Book Room	1 of 1	Water Fountain	center	<1
48	409851	Main Building	Fountain/Tap Combo	Rm26	1 of 1	Water Fountain	right	<1
49	409852	Main Building	Fountain/Tap Combo	Rm25	1 of 1	Tap	left	<1

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
50	409853	Main Building	Fountain/Tap Combo	Rm25	1 of 1	Water Fountain	right	<1
51	409854	Main Building	Fountain	Left Of Rm25	1 of 1	Water Fountain	center	<1
52	409855	Main Building	Fountain/Tap Combo	Rm24	1 of 1	Tap	left	<1
53	409856	Main Building	Fountain/Tap Combo	Rm24	1 of 1	Water Fountain	right	<1
54	409858	Main Building	Fountain/Tap Combo	Rm23	1 of 1	Water Fountain	right	<1
55	409859	Main Building	Fountain/Tap Combo	Rm22	1 of 1	Tap	left	<1
56	409860	Main Building	Fountain/Tap Combo	Rm22	1 of 1	Water Fountain	right	<1
57	409861	Main Building	Fountain/Tap Combo	Rm21	1 of 1	Tap	left	<1
58	409862	Main Building	Fountain/Tap Combo	Rm21	1 of 1	Water Fountain	right	<1
59	409864	Main Building	Fountain/Tap Combo	Rm20	1 of 1	Water Fountain	right	<1
60	409865	Main Building	Fountain/Tap Combo	Rm19	1 of 1	Tap	left	<1

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
61	409866	Main Building	Fountain/Tap Combo	Rm19	1 of 1	Water Fountain	right	<1
