

Lead in School Drinking Water Report

Nathan Hale High School



EXPLANATION OF TESTING AND RESULTS

Results in this report represent sampling conducted by Washington State Department of Health (DOH). Per [RCW 28A.210.410](#) sampling and testing protocols, samples were collected as first-draw. Depending on size of the school(s) and number of drinking water fixtures, multiple dates for collecting samples may have been necessary to meet sampling and testing protocols.

[RCW 28A.210.410](#) does not require remediation for fixtures testing at 5 ppb and under. DOH offers post-remediation testing only for outlets that initially tested above 5 ppb. After a school completes remediation, DOH will provide up to two post-remediation sampling visits. If after the second post-remediation sampling, outlets test above 5 ppb, the district will be responsible for finding a contractor to conduct additional sampling and testing. For questions regarding sampling, testing, and results, please email: leadfreekids@doh.wa.gov.

DEFINITIONS

Fixture Housing
Location

Room/space where
fixture is located
(i.e. room number,
gym, playground)

Fixture Housing Type

Structure that contains
the individual fixtures
where water samples
were collected from.
Fixture housing may
contain one or more
individual fixture for
sampling.

Fixture Location
Details

Location within a
room or space where
fixture housing is
located, starting to the
left of the entrance and
rotating clockwise, of
the total number of
fixture housings in a
room or space
(e.g. 1/5, 2/5)

Fixture Type

Tap, Sprayer, Water
Fountain, Water Bottle
Filler, Ice maker

Fixture Position

Left, Center, Right

Date(s) collected: 2025-09-10

Date(s) analyzed: 2025-09-16, 2025-09-19

.	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
1	409494	Main Building	Pot Filler	Kitchen	3 of 4 center	Tap	center	44
2	409492	Main Building	Sink	Kitchen	1 of 4 across wash/rinse	Sprayer	center	15
3	409491	Main Building	Sink	Kitchen	1 of 4 across wash/rinse	Tap	center	10
4	409505	Main Building	Fountain/Tap Combo	Rm1137	1 of 1	Water Fountain	right	7
5	409493	Main Building	Pot Filler	Kitchen	2 of 4 left	Tap	center	3
6	409486	Main Building	Fountain - Multi-Level	Across Main Office	1 of 1	Water Fountain	right	1
7	409490	Main Building	Fountain - Multi-Level	Across Rm1125	1 of 1	Water Fountain	right	1
8	409479	Main Building	Fountain - Multi-Level	Outside Rm1301 Gym Across Weight Room	1 of 1	Water Bottle Filler	left	<1

.	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
9	409480	Main Building	Fountain - Multi-Level	Outside Rm1301 Gym Across Weight Room	1 of 1	Water Fountain	right	<1
10	409481	Main Building	Fountain - Multi-Level	Outside Rm1301 Gym Furthest From Weight Room	1 of 1	Water Fountain	left	<1
11	409482	Main Building	Fountain - Multi-Level	Outside Rm1301 Gym Furthest From Weight Room	1 of 1	Water Fountain	right	<1
12	409483	Main Building	Fountain - Multi-Level	Across Rm1109 Student Services	1 of 1	Water Fountain	left	<1
13	409484	Main Building	Fountain - Multi-Level	Across Rm1109 Student Services	1 of 1	Water Fountain	right	<1
14	409485	Main Building	Fountain - Multi-Level	Across Main Office	1 of 1	Water Fountain	left	<1
15	409487	Main Building	Fountain - Multi-Level	Right Of 1403-1412 Hallway	1 of 1	Water Fountain	left	<1
16	409488	Main Building	Fountain - Multi-Level	Right Of 1403-1412 Hallway	1 of 1	Water Fountain	right	<1
17	409489	Main Building	Fountain - Multi-Level	Across Rm1125	1 of 1	Water Fountain	left	<1
18	409495	Main Building	Sink	Kitchen	4 of 4 back wall	Tap	center	<1

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
19	409496	Main Building	Sink	Kitchen	4 of 4 back wall	Sprayer	center	<1
20	409497	Main Building	Sink	Nurse's Office	1 of 1	Tap	center	<1
21	409498	Main Building	Fountain	Boys Regular Locker Room	1 of 1	Water Fountain	center	<1
22	409499	Main Building	Sink - Multi-Compartment	Rm1312	1 of 1	Tap	center	<1
23	409500	Main Building	Fountain	Girls Varsity Locker Room	1 of 1	Water Fountain	center	<1
24	409501	Main Building	Sink	Rm1204	1 of 1	Tap	center	<1
25	409502	Main Building	Fountain/Tap Combo	Rm1207a	1 of 1 fountain off	Tap	center	<1
26	409503	Main Building	Sink - Multi-Compartment	Rm1122	1 of 1	Tap	center	<1
27	409504	Main Building	Fountain/Tap Combo	Rm1137	1 of 1	Tap	center	<1
28	409506	Main Building	Sink	Rm1138	1 of 1	Tap	center	<1
29	409507	Main Building	Sink	Rm1140 A	1 of 1	Tap	center	<1
30	409508	Main Building	Sink	Rm1102a	1 of 1	Tap	center	<1

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
31	409509	Main Building	Sink	Rm1101a	1 of 1	Tap	center	<1
32	409510	Main Building	Fountain - Multi-Level with Bottle Filler	Across Rm2127	1 of 1	Water Fountain	left	<1
33	409511	Main Building	Fountain - Multi-Level with Bottle Filler	Across Rm2127	1 of 1	Water Fountain	right	<1
34	409512	Main Building	Fountain - Multi-Level with Bottle Filler	Across Rm2127	1 of 1	Water Bottle Filler	right	<1
35	409513	Main Building	Fountain - Multi-Level	Across Rm2149	1 of 1	Water Fountain	left	<1
36	409514	Main Building	Fountain - Multi-Level	Across Rm2149	1 of 1	Water Fountain	right	<1