

Lead in School Drinking Water Report

John Muir Elementary School



EXPLANATION OF TESTING AND RESULTS

Results in this report represent sampling conducted by Washington State Department of Health (DOH). Per [RCW 28A.210.410](#) sampling and testing protocols, samples were collected as first-draw. Depending on size of the school(s) and number of drinking water fixtures, multiple dates for collecting samples may have been necessary to meet sampling and testing protocols.

[RCW 28A.210.410](#) does not require remediation for fixtures testing at 5 ppb and under. DOH offers post-remediation testing only for outlets that initially tested above 5 ppb. After a school completes remediation, DOH will provide up to two post-remediation sampling visits. If after the second post-remediation sampling, outlets test above 5 ppb, the district will be responsible for finding a contractor to conduct additional sampling and testing. For questions regarding sampling, testing, and results, please email: leadfreekids@doh.wa.gov.

DEFINITIONS

Fixture Housing
Location

Room/space where
fixture is located
(i.e. room number,
gym, playground)

Fixture Housing Type

Structure that contains
the individual fixtures
where water samples
were collected from.
Fixture housing may
contain one or more
individual fixture for
sampling.

Fixture Location
Details

Location within a
room or space where
fixture housing is
located, starting to the
left of the entrance and
rotating clockwise, of
the total number of
fixture housings in a
room or space
(e.g. 1/5, 2/5)

Fixture Type

Tap, Sprayer, Water
Fountain, Water Bottle
Filler, Ice maker

Fixture Position

Left, Center, Right

Date(s) collected: 2025-10-02

Date(s) analyzed: 2025-10-08, 2025-10-13

.	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
1	401489	Main Building	Fountain/Tap Combo	Work Room	1 of 1	Tap	center	47
2	401656	Main Building	Fountain/Tap Combo	Room 20	1 of 1	Water Fountain	left	12
3	401662	Main Building	Fountain/Tap Combo	Room 21	1 of 1	Water Fountain	left	8
4	401643	Main Building	Fountain/Tap Combo	Room 14	1 of 2. SE sink	Tap	center	7
5	401639	Main Building	Fountain/Tap Combo	Room 13	1 of 1	Water Fountain	left	3
6	401646	Main Building	Fountain/Tap Combo	Room 15	1 of 1	Tap	center	3
7	401653	Main Building	Fountain/Tap Combo	Room 19	1 of 1	Tap	center	3
8	401492	Main Building	Sink	Kitchen	1 of 1	Sprayer	center	2
9	401632	Main Building	Fountain/Tap Combo	Room 8	1 of 1	Tap	center	2
10	401645	Main Building	Fountain/Tap Combo	Room 14	2 of 2. NE sink	Water Fountain	left	2

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
11	401664	Main Building	Fountain/Tap Combo	Room 23	1 of 1	Water Fountain	left	2
12	401495	Main Building	Fountain/Tap Combo	Library Office	1 of 1	Tap	center	1
13	401496	Main Building	Fountain/Tap Combo	Library Office	1 of 1	Water Fountain	left	1
14	401636	Main Building	Fountain/Tap Combo	Room 12	1 of 1	Tap	center	1
15	401640	Main Building	Fountain/Tap Combo	Room 11	1 of 1	Tap	center	1
16	401661	Main Building	Fountain/Tap Combo	Room 21	1 of 1	Tap	center	1
17	401488	Main Building	Sink	Staff Lounge	1 of 1	Tap	center	<1
18	401490	Main Building	Sink	Nurses Office	1 of 1	Tap	center	<1
19	401491	Main Building	Sink	Kitchen	1 of 1	Tap	center	<1
20	401493	Main Building	Fountain with Bottle Filler	Hallway Across From Offices	1 of 1	Water Bottle Filler	center	<1
21	401494	Main Building	Fountain with Bottle Filler	Hallway Across From Offices	1 of 1	Water Fountain	right	<1
22	401497	Main Building	Fountain/Tap Combo	Room 3	1 of 1	Tap	center	<1

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
23	401498	Main Building	Fountain/Tap Combo	Room 3	1 of 1	Water Fountain	left	<1
24	401499	Main Building	Fountain/Tap Combo	Room 4	1 of 1	Tap	center	<1
25	401620	Main Building	Fountain/Tap Combo	Room 4	1 of 1	Water Fountain	left	<1
26	401621	Main Building	Fountain	Hallway Next To Room 4	1 of 1	Water Fountain	right	<1
27	401622	Main Building	Fountain/Tap Combo	Room 1	1 of 1	Tap	center	<1
28	401623	Main Building	Fountain/Tap Combo	Room 1	1 of 1	Water Fountain	left	<1
29	401624	Main Building	Fountain/Tap Combo	Room 2	1 of 1	Tap	center	<1
30	401625	Main Building	Fountain/Tap Combo	Room 2	1 of 1	Water Fountain	left	<1
31	401626	Main Building	Fountain/Tap Combo	Room 5	1 of 1	Tap	center	<1
32	401627	Main Building	Fountain/Tap Combo	Room 5	1 of 1	Sprayer	left	<1
33	401628	Main Building	Fountain/Tap Combo	Room 6	1 of 1	Tap	center	<1

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
34	401629	Main Building	Fountain/Tap Combo	Room 6	1 of 1	Water Fountain	left	<1
35	401630	Main Building	Fountain/Tap Combo	Room 7	1 of 1	Tap	center	<1
36	401631	Main Building	Fountain/Tap Combo	Room 7	1 of 1	Water Fountain	left	<1
37	401633	Main Building	Fountain/Tap Combo	Room 8	1 of 1	Water Fountain	left	<1
38	401634	Main Building	Fountain/Tap Combo	Room 9	1 of 1	Tap	center	<1
39	401635	Main Building	Fountain/Tap Combo	Room 9	1 of 1	Water Fountain	left	<1
40	401637	Main Building	Fountain/Tap Combo	Room 12	1 of 1	Water Fountain	left	<1
41	401638	Main Building	Fountain/Tap Combo	Room 13	1 of 1	Tap	center	<1
42	401641	Main Building	Fountain/Tap Combo	Room 11	1 of 1	Water Fountain	left	<1
43	401642	Main Building	Fountain/Tap Combo	Room 204 (Room J)	1 of 1	Tap	center	<1
44	401644	Main Building	Fountain/Tap Combo	Room 14	2 of 2. NE sink	Tap	center	<1

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
45	401647	Main Building	Fountain/Tap Combo	Room 15	1 of 1	Water Fountain	left	<1
46	401648	Main Building	Fountain/Tap Combo	Room 16	1 of 1	Tap	center	<1
47	401649	Main Building	Fountain/Tap Combo	Room 16	1 of 1	Water Fountain	left	<1
48	401650	Main Building	Fountain/Tap Combo	Room 17	1 of 1	Tap	center	<1
49	401651	Main Building	Fountain/Tap Combo	Room 17	1 of 1	Water Fountain	left	<1
50	401652	Main Building	Fountain/Tap Combo	Room 18	1 of 1	Tap	center	<1
51	401654	Main Building	Fountain/Tap Combo	Room 19	1 of 1	Water Fountain	left	<1
52	401655	Main Building	Fountain/Tap Combo	Room 20	1 of 1	Tap	center	<1
53	401657	Main Building	Fountain with Bottle Filler	Hallway Next To Room 20	1 of 1	Water Bottle Filler	center	<1
54	401658	Main Building	Fountain with Bottle Filler	Hallway Next To Room 20	1 of 1	Water Fountain	right	<1
55	401659	Main Building	Fountain/Tap Combo	Room 22	1 of 1	Tap	center	<1

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
56	401660	Main Building	Fountain/Tap Combo	Room 22	1 of 1	Water Fountain	left	<1
57	401663	Main Building	Fountain/Tap Combo	Room 23	1 of 1	Tap	center	<1