

Lead in School Drinking Water Report

Rising Star Elementary School



EXPLANATION OF TESTING AND RESULTS

Results in this report represent sampling conducted by Washington State Department of Health (DOH). Per [RCW 28A.210.410](#) sampling and testing protocols, samples were collected as first-draw. Depending on size of the school(s) and number of drinking water fixtures, multiple dates for collecting samples may have been necessary to meet sampling and testing protocols.

[RCW 28A.210.410](#) does not require remediation for fixtures testing at 5 ppb and under. DOH offers post-remediation testing only for outlets that initially tested above 5 ppb. After a school completes remediation, DOH will provide up to two post-remediation sampling visits. If after the second post-remediation sampling, outlets test above 5 ppb, the district will be responsible for finding a contractor to conduct additional sampling and testing. For questions regarding sampling, testing, and results, please email: leadfreekids@doh.wa.gov.

DEFINITIONS

Fixture Housing
Location

Room/space where
fixture is located
(i.e. room number,
gym, playground)

Fixture Housing Type

Structure that contains
the individual fixtures
where water samples
were collected from.
Fixture housing may
contain one or more
individual fixture for
sampling.

Fixture Location
Details

Location within a
room or space where
fixture housing is
located, starting to the
left of the entrance and
rotating clockwise, of
the total number of
fixture housings in a
room or space
(e.g. 1/5, 2/5)

Fixture Type

Tap, Sprayer, Water
Fountain, Water Bottle
Filler, Ice maker

Fixture Position

Left, Center, Right

Date(s) collected: 2025-10-03

Date(s) analyzed: 2025-10-13, 2025-10-14

.	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
1	401667	Main Building	Sink - Multi-Compartment	Kitchen	3 of 3	Sprayer	left	19
2	401730	Main Building	Sink	Home And Family Life	1 of 5	Tap	left	6
3	401732	Main Building	Sink	Home And Family Life	3 of 5	Tap	center	6
4	401685	Main Building	Fountain/Tap Combo	Room 115	1 of 1	Tap	center	5
5	401700	Main Building	Fountain/Tap Combo	Room 144	1 of 1	Tap	center	5
6	401733	Main Building	Sink	Home And Family Life	4 of 5	Tap	center	5
7	401739	Main Building	Sink	Art Room	3 of 3	Tap	right	5
8	401674	Main Building	Fountain/Tap Combo	Room 112	1 of 1	Tap	center	4
9	401702	Main Building	Fountain/Tap Combo	Room 134	1 of 1	Tap	center	4
10	401676	Main Building	Fountain/Tap Combo	Room 111	1 of 1	Tap	center	3

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
11	401677	Main Building	Fountain/Tap Combo	Room 108	1 of 1	Tap	center	3
12	401678	Main Building	Fountain/Tap Combo	Room 113	1 of 1	Tap	center	3
13	401686	Main Building	Fountain/Tap Combo	Room 115	1 of 1	Water Fountain	right	3
14	401694	Main Building	Fountain/Tap Combo	Room 138	1 of 1	Tap	center	3
15	401696	Main Building	Fountain/Tap Combo	Room 137	1 of 1	Tap	center	3
16	401706	Main Building	Fountain/Tap Combo	Room 133	1 of 1	Tap	center	3
17	401708	Main Building	Fountain/Tap Combo	Room 132	1 of 1	Tap	center	3
18	401709	Main Building	Fountain/Tap Combo	Room 132	1 of 1	Water Fountain	right	3
19	401720	Main Building	Sink	Room 208	1 of 1	Tap	center	3
20	401726	Main Building	Fountain/Tap Combo	Room 204	1 of 1	Tap	center	3
21	401727	Main Building	Fountain/Tap Combo	Room 204	1 of 1	Water Fountain	right	3

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
22	401734	Main Building	Sink	Home And Family Life	5 of 5	Tap	right	3
23	401735	Main Building	Sink - Multi-Compartment	Instruction Support Room.	1 of 1	Tap	center	3
24	401666	Main Building	Pot Filler	Kitchen	2 of 3	Tap	center	2
25	401679	Main Building	Fountain/Tap Combo	Room 114	1 of 1	Tap	center	2
26	401681	Main Building	Fountain/Tap Combo	Room 107	1 of 1	Tap	center	2
27	401683	Main Building	Fountain/Tap Combo	Room 105	1 of 1	Tap	center	2
28	401689	Main Building	Fountain/Tap Combo	Room 104	1 of 1	Water Fountain	right	2
29	401693	Main Building	Fountain/Tap Combo	Room 139	1 of 1	Water Fountain	right	2
30	401699	Main Building	Fountain/Tap Combo	Room 143	1 of 1	Water Fountain	right	2
31	401703	Main Building	Fountain/Tap Combo	Room 134	1 of 1	Water Fountain	right	2
32	401705	Main Building	Fountain/Tap Combo	Room 145	1 of 1	Water Fountain	right	2

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
33	401707	Main Building	Fountain/Tap Combo	Room 133	1 of 1	Water Fountain	right	2
34	401715	Main Building	Sink	Pre School Room	4 of 5	Tap	right	2
35	401718	Main Building	Sink	Room 211	1 of 1	Tap	center	2
36	401719	Main Building	Sink	Room 213	1 of 1	Tap	center	2
37	401724	Main Building	Fountain/Tap Combo	Room 215	1 of 1	Tap	center	2
38	401725	Main Building	Fountain/Tap Combo	Room 215	1 of 1	Water Fountain	right	2
39	401731	Main Building	Sink	Home And Family Life	2 of 5	Tap	center	2
40	401665	Main Building	Sink	Kitchen	1 of 3	Tap	center	1
41	401668	Main Building	Sink - Multi-Compartment	Kitchen	3 of 3	Tap	right	1
42	401672	Main Building	Sink	Room 27	1 of 1	Tap	center	1
43	401675	Main Building	Fountain/Tap Combo	Room 112	1 of 1	Water Fountain	right	1
44	401680	Main Building	Fountain/Tap Combo	Room 114	1 of 1	Water Fountain	right	1
45	401684	Main Building	Fountain/Tap Combo	Room 105	1 of 1	Water Fountain	right	1

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
46	401688	Main Building	Fountain/Tap Combo	Room 104	1 of 1	Tap	center	1
47	401692	Main Building	Fountain/Tap Combo	Room 139	1 of 1	Tap	center	1
48	401697	Main Building	Fountain/Tap Combo	Room 137	1 of 1	Water Fountain	right	1
49	401698	Main Building	Fountain/Tap Combo	Room 143	1 of 1	Tap	center	1
50	401701	Main Building	Fountain/Tap Combo	Room 144	1 of 1	Water Fountain	right	1
51	401704	Main Building	Fountain/Tap Combo	Room 145	1 of 1	Tap	center	1
52	401714	Main Building	Sink	Pre School Room	3 of 5. Kitchen	Tap	center	1
53	401721	Main Building	Sink	Room 207	1 of 1	Tap	center	1
54	401669	Main Building	Fountain with Bottle Filler	Cafeteria Fountain	1 of 1	Water Bottle Filler	center	<1
55	401670	Main Building	Fountain with Bottle Filler	Cafeteria	1 of 1	Water Fountain	right	<1
56	401671	Main Building	Sink	Staff Room	1 of 1	Tap	center	<1
57	401673	Main Building	Fountain	Gym	1 of 1	Water Fountain	right	<1

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
58	401682	Main Building	Fountain/Tap Combo	Room 107	1 of 1	Water Fountain	right	<1
59	401690	Main Building	Fountain with Bottle Filler	Hallway Next To Lecture Hall	1 of 1	Water Bottle Filler	center	<1
60	401691	Main Building	Fountain with Bottle Filler	Hallway Next To Lecture Hall	1 of 1	Water Fountain	right	<1
61	401695	Main Building	Fountain/Tap Combo	Room 138	1 of 1	Water Fountain	right	<1
62	401710	Main Building	Sink	Nurses Office	1 of 1	Tap	center	<1
63	401711	Main Building	Sink	Office Work Room	1 of 1	Tap	center	<1
64	401712	Main Building	Sink	Pre School Room	1 of 5. North side	Tap	left	<1
65	401713	Main Building	Sink	Pre School Room	2 of 5. North side	Tap	right	<1
66	401716	Main Building	Sink	Pre School Room	5 of 5	Tap	left	<1
67	401717	Main Building	Sink	Room 212	1 of 1	Tap	center	<1
68	401722	Main Building	Sink	Room 214	1 of 1	Tap	center	<1
69	401723	Main Building	Sink	Room 205	1 of 1	Tap	center	<1

.	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
70	401728	Main Building	Fountain - Multi-Level	Upper Level Fountain. By Elevator	1 of 1	Water Fountain	left	<1
71	401729	Main Building	Fountain - Multi-Level	Upper Level Fountain By Elevator	1 of 1	Water Fountain	right	<1
72	401736	Main Building	Sink	Parent Work Room	1 of 1	Tap	center	<1
73	401737	Main Building	Sink	Art Room	1 of 3	Tap	left	<1
74	401738	Main Building	Sink	Art Room	2 of 3	Tap	center	<1