

# Lead in School Drinking Water Report

## Leschi Elementary School



### EXPLANATION OF TESTING AND RESULTS

Results in this report represent sampling conducted by Washington State Department of Health (DOH). Per [RCW 28A.210.410](#) sampling and testing protocols, samples were collected as first-draw. Depending on size of the school(s) and number of drinking water fixtures, multiple dates for collecting samples may have been necessary to meet sampling and testing protocols.

[RCW 28A.210.410](#) does not require remediation for fixtures testing at 5 ppb and under. DOH offers post-remediation testing only for outlets that initially tested above 5 ppb. After a school completes remediation, DOH will provide up to two post-remediation sampling visits. If after the second post-remediation sampling, outlets test above 5 ppb, the district will be responsible for finding a contractor to conduct additional sampling and testing. For questions regarding sampling, testing, and results, please email: [leadfreekids@doh.wa.gov](mailto:leadfreekids@doh.wa.gov).

## DEFINITIONS

Fixture Housing  
Location

Room/space where  
fixture is located  
(i.e. room number,  
gym, playground)

Fixture Housing Type

Structure that contains  
the individual fixtures  
where water samples  
were collected from.  
Fixture housing may  
contain one or more  
individual fixture for  
sampling.

Fixture Location  
Details

Location within a  
room or space where  
fixture housing is  
located, starting to the  
left of the entrance and  
rotating clockwise, of  
the total number of  
fixture housings in a  
room or space  
(e.g. 1/5, 2/5)

Fixture Type

Tap, Sprayer, Water  
Fountain, Water Bottle  
Filler, Ice maker

Fixture Position

Left, Center, Right

Date(s) collected: 2025-11-15

Date(s) analyzed: 2025-11-20, 2025-11-21

.	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
1	417765	Main Building	Fountain/Tap Combo	Library Office	1 of 1	Water Fountain	right	38
2	417777	Main Building	Fountain/Tap Combo	Rm206	1 of 1	Water Fountain	right	6
3	416280	Main Building	Fountain/Tap Combo	Rm217	1 of 1	Water Fountain	right	5
4	416317	Main Building	Sink	Rm109	1 of 1	Tap	left	4
5	416520	Main Building	Sink	Kitchen	1 of 1	Sprayer	center	4
6	417792	Main Building	Sink	Front Office	1 of 1	Tap	center	4
7	416304	Main Building	Fountain/Tap Combo	Rm307	1 of 1	Water Fountain	right	3
8	416306	Main Building	Fountain/Tap Combo	Rm306	1 of 1	Tap	left	3
9	416315	Main Building	Fountain/Tap Combo	Rm111	1 of 1	Water Fountain	right	3
10	416311	Main Building	Sink	Rm113	1 of 1	Tap	center	2
11	416318	Main Building	Fountain/Tap Combo	Rm304	1 of 1	Water Fountain	right	2

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
12	417785	Main Building	Fountain/Tap Combo	Rm211	1 of 1	Tap	left	2
13	417794	Main Building	Fountain/Tap Combo	Nurses Office	1 of 1	Tap	left	2
14	416287	Main Building	Fountain/Tap Combo	Rm301	1 of 1	Water Fountain	right	1
15	416290	Main Building	Fountain/Tap Combo	Rm309	1 of 1	Tap	left	1
16	416294	Main Building	Fountain/Tap Combo	Rm310	1 of 1	Tap	left	1
17	417796	Main Building	Fountain/Tap Combo	Nurses Office	1 of 1	Water Fountain	right	1
18	416281	Main Building	Fountain/Tap Combo	Rm303	1 of 1	Tap	left	<1
19	416282	Main Building	Fountain/Tap Combo	Rm251	1 of 1	Tap	left	<1
20	416283	Main Building	Fountain/Tap Combo	Rm303	1 of 1	Water Fountain	right	<1
21	416284	Main Building	Fountain/Tap Combo	Rm251	1 of 1	Water Fountain	right	<1
22	416285	Main Building	Fountain/Tap Combo	Rm301	1 of 1	Tap	left	<1

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
23	416286	Main Building	Fountain/Tap Combo	Rm250	1 of 1	Tap	left	<1
24	416288	Main Building	Fountain/Tap Combo	Rm250	1 of 1	Water Fountain	right	<1
25	416289	Main Building	Fountain/Tap Combo	Rm302	1 of 1	Tap	left	<1
26	416291	Main Building	Fountain/Tap Combo	Rm302	1 of 1	Water Fountain	right	<1
27	416292	Main Building	Fountain/Tap Combo	Rm309	1 of 1	Water Fountain	right	<1
28	416293	Main Building	Fountain/Tap Combo	Rm150	1 of 1	Tap	left	<1
29	416295	Main Building	Fountain/Tap Combo	Rm150	1 of 1	Water Fountain	right	<1
30	416296	Main Building	Fountain/Tap Combo	Rm310	1 of 1	Water Fountain	right	<1
31	416297	Main Building	Fountain/Tap Combo	Rm151	1 of 2	Tap	left	<1
32	416298	Main Building	Fountain/Tap Combo	Rm308	1 of 1	Tap	left	<1
33	416299	Main Building	Fountain/Tap Combo	Rm151	1 of 2	Water Fountain	right	<1

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
34	416300	Main Building	Fountain/Tap Combo	Rm308	1 of 1	Water Fountain	right	<1
35	416301	Main Building	Sink	Rm151	2 of 2	Tap	center	<1
36	416302	Main Building	Fountain/Tap Combo	Rm307	1 of 1	Tap	left	<1
37	416303	Main Building	Sink	Preschool Kitchen	1 of 1	Tap	left	<1
38	416305	Main Building	Sink	Preschool Kitchen	1 of 1	Sprayer	right	<1
39	416307	Main Building	Fountain with Bottle Filler	Next To Rm113	1 of 1	Water Bottle Filler	center	<1
40	416308	Main Building	Fountain/Tap Combo	Rm306	1 of 1	Water Fountain	right	<1
41	416309	Main Building	Fountain with Bottle Filler	Next To Rm113	1 of 1	Water Fountain	right	<1
42	416310	Main Building	Fountain	Next To Rm306	1 of 1	Water Fountain	center	<1
43	416312	Main Building	Fountain/Tap Combo	Rm305	1 of 2(fountain off)	Tap	left	<1
44	416313	Main Building	Fountain/Tap Combo	Rm111	1 of 1	Tap	left	<1
45	416314	Main Building	Fountain/Tap Combo	Rm305	2 of 2(fountain off)	Tap	left	<1

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
46	416316	Main Building	Fountain/Tap Combo	Rm304	1 of 1	Tap	left	<1
47	416319	Main Building	Sink	Kitchen	1 of 1	Tap	center	<1
48	417761	Main Building	Fountain with Bottle Filler	Next To 204a	1 of 1	Water Fountain	right	<1
49	417763	Main Building	Fountain/Tap Combo	Library Office	1 of 1	Tap	left	<1
50	417767	Main Building	Fountain/Tap Combo	Rm202	1 of 1	Tap	left	<1
51	417769	Main Building	Fountain/Tap Combo	Rm202	1 of 1	Water Fountain	right	<1
52	417771	Main Building	Fountain/Tap Combo	Rm204	1 of 1	Tap	left	<1
53	417773	Main Building	Fountain/Tap Combo	Rm204	1 of 1	Water Fountain	right	<1
54	417775	Main Building	Fountain/Tap Combo	Rm206	1 of 1	Tap	left	<1
55	417779	Main Building	Sink	Staff Lounge	1 of 1	Tap	center	<1
56	417781	Main Building	Fountain/Tap Combo	Rm209	1 of 1	Tap	left	<1
57	417783	Main Building	Fountain/Tap Combo	Rm209	1 of 1	Water Fountain	right	<1

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
58	417787	Main Building	Fountain/Tap Combo	Rm211	1 of 1	Water Fountain	right	<1
59	417789	Main Building	Fountain/Tap Combo	Rm213	1 of 1	Tap	left	<1
60	417791	Main Building	Fountain/Tap Combo	Rm213	1 of 1	Water Fountain	right	<1
61	417793	Main Building	Fountain	Next To Rm213	1 of 1	Water Fountain	center	<1
62	417795	Main Building	Fountain/Tap Combo	Rm215	1 of 1	Tap	left	<1
63	417797	Main Building	Fountain/Tap Combo	Rm215	1 of 1	Water Fountain	right	<1
64	417798	Main Building	Fountain with Bottle Filler	Next To 204a	1 of 1	Water Bottle Filler	center	<1
65	417799	Main Building	Fountain/Tap Combo	Rm217	1 of 1	Tap	left	<1