

# Lead in School Drinking Water Report

## Bailey Gatzert Elementary School



### EXPLANATION OF TESTING AND RESULTS

Results in this report represent sampling conducted by Washington State Department of Health (DOH). Per [RCW 28A.210.410](#) sampling and testing protocols, samples were collected as first-draw. Depending on size of the school(s) and number of drinking water fixtures, multiple dates for collecting samples may have been necessary to meet sampling and testing protocols.

[RCW 28A.210.410](#) does not require remediation for fixtures testing at 5 ppb and under. DOH offers post-remediation testing only for outlets that initially tested above 5 ppb. After a school completes remediation, DOH will provide up to two post-remediation sampling visits. If after the second post-remediation sampling, outlets test above 5 ppb, the district will be responsible for finding a contractor to conduct additional sampling and testing. For questions regarding sampling, testing, and results, please email: [leadfreekids@doh.wa.gov](mailto:leadfreekids@doh.wa.gov).

## DEFINITIONS

Fixture Housing  
Location

Room/space where  
fixture is located  
(i.e. room number,  
gym, playground)

Fixture Housing Type

Structure that contains  
the individual fixtures  
where water samples  
were collected from.  
Fixture housing may  
contain one or more  
individual fixture for  
sampling.

Fixture Location  
Details

Location within a  
room or space where  
fixture housing is  
located, starting to the  
left of the entrance and  
rotating clockwise, of  
the total number of  
fixture housings in a  
room or space  
(e.g. 1/5, 2/5)

Fixture Type

Tap, Sprayer, Water  
Fountain, Water Bottle  
Filler, Ice maker

Fixture Position

Left, Center, Right

Date(s) collected: 2025-10-15, 2025-10-17

Date(s) analyzed: 2025-10-29, 2025-10-30

.	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
1	417720	Main Building	Fountain/Tap Combo	Rm3	1 of 2	Tap	left	77
2	417726	Main Building	Sink	Nurses Office	1 of 1	Tap	center	21
3	417749	Main Building	Fountain/Tap Combo	Rm24	1 of 1	Tap	left	20
4	417770	Main Building	Fountain/Tap Combo	Rm9	1 of 1	Tap	left	18
5	417784	Main Building	Fountain/Tap Combo	Rm6	1 of 1	Tap	left	16
6	417737	Main Building	Fountain/Tap Combo	Rm26	1 of 1	Tap	left	13
7	417758	Main Building	Fountain/Tap Combo	Rm20	1 of 1	Water Fountain	right	12
8	417745	Main Building	Fountain/Tap Combo	Rm14	1 of 1	Tap	left	11
9	417755	Main Building	Fountain/Tap Combo	Rm13	1 of 1	Tap	left	11
10	417762	Main Building	Fountain/Tap Combo	Rm11	1 of 1	Tap	left	11

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
11	417766	Main Building	Fountain/Tap Combo	Rm10	1 of 1	Tap	left	11
12	417725	Main Building	Fountain/Tap Combo	Rm18	1 of 1	Tap	left	10
13	417744	Main Building	Fountain/Tap Combo	Rm22	1 of 1	Tap	left	10
14	417788	Main Building	Fountain/Tap Combo	Rm4	1 of 1	Tap	left	10
15	417780	Main Building	Fountain/Tap Combo	Rm7	1 of 1	Tap	left	9
16	417728	Main Building	Sink	Health Room	1 of 1	Tap	center	8
17	417752	Main Building	Fountain/Tap Combo	Rm21	1 of 1	Tap	left	8
18	417759	Main Building	Fountain/Tap Combo	Rm12	1 of 1	Tap	left	8
19	417729	Main Building	Fountain/Tap Combo	Rm17	1 of 1	Tap	left	7
20	417724	Main Building	Sink - Multi-Compartment	Rm3	2 of 2	Tap	center	6
21	417736	Main Building	Sink	Kitchen	1 of 1	Tap	center	6
22	417733	Main Building	Fountain/Tap Combo	Rm16	1 of 1	Tap	left	3

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
23	417727	Main Building	Fountain/Tap Combo	Rm18	1 of 1	Water Fountain	right	1
24	417740	Main Building	Fountain/Tap Combo	Rm23	1 of 1	Tap	left	1
25	417776	Main Building	Fountain/Tap Combo	Rm8	1 of 1	Tap	left	1
26	417721	Main Building	Fountain/Tap Combo	Rm19	1 of 1	Tap	left	<1
27	417722	Main Building	Fountain/Tap Combo	Rm3	1 of 2	Water Fountain	right	<1
28	417723	Main Building	Fountain/Tap Combo	Rm19	1 of 1	Water Fountain	right	<1
29	417730	Main Building	Sink - Multi-Compartment	Staff Lounge	1 of 1	Tap	center	<1
30	417731	Main Building	Fountain/Tap Combo	Rm17	1 of 1	Water Fountain	right	<1
31	417732	Main Building	Fountain with Bottle Filler	Commons	1 of 1	Water Bottle Filler	center	<1
32	417734	Main Building	Fountain with Bottle Filler	Commons	1 of 1	Water Fountain	right	<1
33	417735	Main Building	Fountain/Tap Combo	Rm16	1 of 1	Water Fountain	right	<1

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
34	417738	Main Building	Sink	Kitchen	1 of 1	Sprayer	center	<1
35	417739	Main Building	Fountain/Tap Combo	Rm26	1 of 1	Water Fountain	right	<1
36	417741	Main Building	Fountain/Tap Combo	Rm15	1 of 1	Tap	left	<1
37	417742	Main Building	Fountain/Tap Combo	Rm23	1 of 1	Water Fountain	right	<1
38	417743	Main Building	Fountain/Tap Combo	Rm15	1 of 1	Water Fountain	right	<1
39	417746	Main Building	Fountain/Tap Combo	Rm22	1 of 1	Water Fountain	right	<1
40	417747	Main Building	Fountain/Tap Combo	Rm14	1 of 1	Water Fountain	right	<1
41	417748	Main Building	Fountain with Bottle Filler	Across From 22	1 of 1	Water Bottle Filler	center	<1
42	417750	Main Building	Fountain with Bottle Filler	Across From 22	1 of 1	Water Fountain	right	<1
43	417751	Main Building	Fountain/Tap Combo	Rm24	1 of 1	Water Fountain	right	<1
44	417753	Main Building	Fountain	Next To Rm24	1 of 1	Water Fountain	right	<1
45	417754	Main Building	Fountain/Tap Combo	Rm21	1 of 1	Water Fountain	right	<1

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
46	417756	Main Building	Fountain/Tap Combo	Rm20	1 of 1	Tap	left	<1
47	417757	Main Building	Fountain/Tap Combo	Rm13	1 of 1	Water Fountain	right	<1
48	417760	Main Building	Fountain/Tap Combo	Rm12	1 of 1	Water Fountain	right	<1
49	417764	Main Building	Fountain/Tap Combo	Rm11	1 of 1	Water Fountain	right	<1
50	417768	Main Building	Fountain/Tap Combo	Rm10	1 of 1	Water Fountain	right	<1
51	417772	Main Building	Fountain/Tap Combo	Rm9	1 of 1	Water Fountain	right	<1
52	417774	Main Building	Fountain	Across From 8	1 of 1	Water Fountain	right	<1
53	417778	Main Building	Fountain/Tap Combo	Rm8	1 of 1	Water Fountain	right	<1
54	417782	Main Building	Fountain/Tap Combo	Rm7	1 of 1	Water Fountain	right	<1
55	417786	Main Building	Fountain/Tap Combo	Rm6	1 of 1	Water Fountain	right	<1
56	417790	Main Building	Fountain/Tap Combo	Rm4	1 of 1	Water Fountain	right	<1