

Lead in School Drinking Water Report

Beacon Hill Int'l Elementary School



EXPLANATION OF TESTING AND RESULTS

Results in this report represent sampling conducted by Washington State Department of Health (DOH). Per [RCW 28A.210.410](#) sampling and testing protocols, samples were collected as first-draw. Depending on size of the school(s) and number of drinking water fixtures, multiple dates for collecting samples may have been necessary to meet sampling and testing protocols.

[RCW 28A.210.410](#) does not require remediation for fixtures testing at 5 ppb and under. DOH offers post-remediation testing only for outlets that initially tested above 5 ppb. After a school completes remediation, DOH will provide up to two post-remediation sampling visits. If after the second post-remediation sampling, outlets test above 5 ppb, the district will be responsible for finding a contractor to conduct additional sampling and testing. For questions regarding sampling, testing, and results, please email: leadfreekids@doh.wa.gov.

DEFINITIONS

Fixture Housing
Location

Room/space where
fixture is located
(i.e. room number,
gym, playground)

Fixture Housing Type

Structure that contains
the individual fixtures
where water samples
were collected from.
Fixture housing may
contain one or more
individual fixture for
sampling.

Fixture Location
Details

Location within a
room or space where
fixture housing is
located, starting to the
left of the entrance and
rotating clockwise, of
the total number of
fixture housings in a
room or space
(e.g. 1/5, 2/5)

Fixture Type

Tap, Sprayer, Water
Fountain, Water Bottle
Filler, Ice maker

Fixture Position

Left, Center, Right

Date(s) collected: 2025-10-18

Date(s) analyzed: 2025-10-30

.	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
1	417854	Main Building	Fountain/Tap Combo	Rm131	1 of 1	Tap	left	18
2	417826	Main Building	Sink	C-Pod Medical	1 of 1	Tap	center	8
3	417822	Main Building	Fountain/Tap Combo	Kindergarten Two	1 of 1	Tap	left	6
4	417809	Main Building	Fountain/Tap Combo	B-Pod	1 of 1	Tap	left	5
5	417819	Main Building	Fountain/Tap Combo	A-Pod	1 of 1	Tap	left	5
6	417802	Main Building	Sink	Health Room	1 of 1	Tap	center	4
7	417821	Main Building	Fountain/Tap Combo	A-Pod	1 of 1	Water Fountain	right	4
8	417827	Main Building	Sink	Kitchen	1 of 1	Tap	center	4
9	417801	Main Building	Fountain/Tap Combo	Gym	1 of 2	Tap	left	3
10	417808	Main Building	Fountain/Tap Combo	Kindergarten 1	1 of 1	Tap	left	3
11	417812	Main Building	Fountain/Tap Combo	Kindergarten Bathrooms	1 of 2	Tap	left	3

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
12	417807	Main Building	Fountain/Tap Combo	Gym	2 of 2	Water Fountain	right	2
13	417811	Main Building	Fountain/Tap Combo	B-Pod	1 of 1	Water Fountain	right	2
14	417816	Main Building	Fountain/Tap Combo	Kindergarten Bathrooms	2 of 2	Tap	left	2
15	417828	Main Building	Fountain/Tap Combo	C-Pod236	1 of 1	Tap	left	2
16	417829	Main Building	Sink	Kitchen	1 of 1	Sprayer	center	2
17	417831	Main Building	Fountain/Tap Combo	Commons	1 of 3	Tap	left	2
18	417832	Main Building	Fountain/Tap Combo	C-Pod/D-Pod Bathrooms	1 of 1	Tap	left	2
19	417835	Main Building	Sink	Commons	2 of 3	Tap	center	2
20	417838	Main Building	Fountain/Tap Combo	D-Pod213	1 of 1	Tap	right	2
21	417840	Main Building	Fountain/Tap Combo	E-Pod127	1 of 1	Tap	left	2
22	417842	Main Building	Fountain/Tap Combo	E-Pod 127	1 of 1	Water Fountain	right	2
23	417844	Main Building	Fountain/Tap Combo	Rm125	1 of 1	Tap	left	2

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
24	417848	Main Building	Fountain/Tap Combo	Rm130	1 of 1	Tap	left	2
25	417850	Main Building	Fountain/Tap Combo	Rm130	1 of 1	Tap	left	2
26	417805	Main Building	Fountain/Tap Combo	Gym	2 of 2	Tap	left	1
27	417833	Main Building	Fountain/Tap Combo	Commons	1 of 3	Water Fountain	right	1
28	417837	Main Building	Fountain/Tap Combo	Commons	3 of 3	Tap	left	1
29	417852	Main Building	Fountain	Rm132	1 of 1	Water Fountain	right	1
30	417800	Main Building	Fountain	Main Entrance	1 of 1	Water Fountain	right	<1
31	417803	Main Building	Fountain/Tap Combo	Gym	1 of 2	Water Fountain	right	<1
32	417804	Main Building	Fountain with Bottle Filler	Across From 267	1 of 1	Water Bottle Filler	center	<1
33	417806	Main Building	Fountain with Bottle Filler	Across From 267	1 of 1	Water Fountain	right	<1
34	417810	Main Building	Fountain/Tap Combo	Kindergarten 1	1 of 1	Water Fountain	right	<1
35	417813	Main Building	Fountain/Tap Combo	B-Pod Bathrooms	1 of 1	Tap	left	<1

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
36	417814	Main Building	Fountain/Tap Combo	Kindergarten Bathrooms	1 of 2	Water Fountain	right	<1
37	417815	Main Building	Fountain/Tap Combo	A-Pod Bathrooms	1 of 1	Tap	left	<1
38	417817	Main Building	Fountain/Tap Combo	A-Pod Bathrooms	1 of 1	Water Fountain	right	<1
39	417818	Main Building	Fountain/Tap Combo	Kindergarten Bathrooms	2 of 2	Water Fountain	right	<1
40	417820	Main Building	Sink	Rm250	1 of 1	Tap	center	<1
41	417823	Main Building	Fountain - Multi-Level	Next To 126	1 of 1	Water Fountain	left	<1
42	417824	Main Building	Fountain/Tap Combo	Kindergarten Two	1 of 1	Water Fountain	right	<1
43	417825	Main Building	Fountain - Multi-Level	Next To 126	1 of 1	Water Fountain	right	<1
44	417830	Main Building	Fountain/Tap Combo	Cpod236	1 of 1	Water Fountain	right	<1
45	417834	Main Building	Fountain/Tap Combo	C-Pod/D-Pod Bathrooms	1 of 1	Water Fountain	right	<1
46	417836	Main Building	Fountain/Tap Combo	D-Pod213	1 of 1	Water Fountain	left	<1

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
47	417839	Main Building	Fountain/Tap Combo	Commons	3 of 3	Water Fountain	center	<1
48	417846	Main Building	Fountain/Tap Combo	Rm125	1 of 1	Water Fountain	right	<1
49	417856	Main Building	Fountain/Tap Combo	Rm131	1 of 1	Water Fountain	right	<1
50	417858	Main Building	Sink	Rm135	1 of 1	Tap	center	<1