

# Lead in School Drinking Water Report

## Cleveland High School



### EXPLANATION OF TESTING AND RESULTS

Results in this report represent sampling conducted by Washington State Department of Health (DOH). Per [RCW 28A.210.410](#) sampling and testing protocols, samples were collected as first-draw. Depending on size of the school(s) and number of drinking water fixtures, multiple dates for collecting samples may have been necessary to meet sampling and testing protocols.

[RCW 28A.210.410](#) does not require remediation for fixtures testing at 5 ppb and under. DOH offers post-remediation testing only for outlets that initially tested above 5 ppb. After a school completes remediation, DOH will provide up to two post-remediation sampling visits. If after the second post-remediation sampling, outlets test above 5 ppb, the district will be responsible for finding a contractor to conduct additional sampling and testing. For questions regarding sampling, testing, and results, please email: [leadfreekids@doh.wa.gov](mailto:leadfreekids@doh.wa.gov).

## DEFINITIONS

Fixture Housing  
Location

Room/space where  
fixture is located  
(i.e. room number,  
gym, playground)

Fixture Housing Type

Structure that contains  
the individual fixtures  
where water samples  
were collected from.  
Fixture housing may  
contain one or more  
individual fixture for  
sampling.

Fixture Location  
Details

Location within a  
room or space where  
fixture housing is  
located, starting to the  
left of the entrance and  
rotating clockwise, of  
the total number of  
fixture housings in a  
room or space  
(e.g. 1/5, 2/5)

Fixture Type

Tap, Sprayer, Water  
Fountain, Water Bottle  
Filler, Ice maker

Fixture Position

Left, Center, Right

Date(s) collected: 2025-10-25

Date(s) analyzed: 2025-11-05, 2025-11-12

.	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
1	415050	Main Building	Sink	Room 1176	1 of 1	Tap	center	11
2	415055	Main Building	Sink	Room 1167	1 of 1	Tap	center	11
3	415054	Main Building	Sink	Room 1161	1 of 1	Tap	center	8
4	415053	Main Building	Sink	1166 A	1 of 1	Tap	center	5
5	415095	Building 2 (South Building)	Sink - Multi-Compartment	Room 2264	4 of 5. West wall	Tap	left	5
6	415051	Main Building	Sink	Room 1172	1 of 1	Tap	center	4
7	415052	Main Building	Sink	Room 1170	1 of 1	Tap	center	4
8	415056	Main Building	Sink	Room 1113	1 of 1	Tap	center	4
9	415060	Main Building	Sink	Attendance Office	1 of 1	Tap	center	4
10	415093	Building 2 (South Building)	Sink - Multi-Compartment	Room 2264	2 of 5. West side of island	Tap	left	4
11	415046	Gymnasium (North Building)	Sink	Kitchen	2 of 2	Tap	center	3
12	415049	Main Building	Fountain/Tap Combo	Room 1180	1 of 1	Tap	center	3

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
13	415099	Building 2 (South Building)	Sink	Room 2214	1 of 1	Tap	center	3
14	415044	Gymnasium (North Building)	Sink - Multi-Compartment	Kitchen	1 of 2	Tap	center	2
15	415045	Gymnasium (North Building)	Sink - Multi-Compartment	Kitchen	1 of 2	Sprayer	center	2
16	415062	Main Building	Sink	Room 1136	1 of 1	Tap	center	2
17	415063	Main Building	Sink	Room 1140	1 of 1	Tap	center	2
18	415064	Main Building	Sink	Room 1141	1 of 1	Tap	center	2
19	415066	Main Building	Sink	Room 1242	1 of 1	Tap	center	2
20	415067	Main Building	Sink	Room. 1240	1 of 1	Tap	center	2
21	415070	Main Building	Sink	Room 1207	1 of 1	Tap	center	2
22	415073	Main Building	Sink	Library Office	1 of 1	Tap	center	2
23	415085	Building 2 (South Building)	Sink	2002e Work Room	1 of 1	Tap	center	2
24	415089	Building 2 (South Building)	Sink	Room 2215	1 of 1	Tap	center	2
25	415090	Building 2 (South Building)	Sink	Room 2214	1 of 1	Tap	center	2
26	415091	Building 2 (South Building)	Sink	Room 2253	1 of 1	Tap	center	2

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
27	415092	Building 2 (South Building)	Sink - Multi-Compartment	Room 2264	1 of 5. Sink closest to lab prep 2264A	Tap	center	2
28	415094	Building 2 (South Building)	Sink - Multi-Compartment	Room 2264	3 of 5. West side of island	Tap	right	2
29	415096	Building 2 (South Building)	Sink - Multi-Compartment	Room 2264	5 of 5. West wall	Tap	right	2
30	411404	Gymnasium (North Building)	Sink	Training Room 3029	1 of 2	Tap	center	1
31	415040	Gymnasium (North Building)	Fountain - Multi-Level	Consessions Hallway	1 of 1	Water Fountain	left	1
32	415047	Gymnasium (North Building)	Fountain - Multi-Level	Hallway Across From Custodial 3104	1 of 1	Water Fountain	left	1
33	415048	Gymnasium (North Building)	Fountain - Multi-Level	Hallway Across From Custodial 3104	1 of 1	Water Bottle Filler	right	1
34	415059	Main Building	Sink	Room 1103	1 of 1	Tap	center	1

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
35	415065	Main Building	Sink	Room 1239	1 of 1	Tap	center	1
36	415071	Main Building	Sink	Room 1211	1 of 1	Tap	center	1
37	415084	Building 2 (South Building)	Sink	Work Room 2050d	1 of 1	Tap	center	1
38	415086	Building 2 (South Building)	Sink	Room 2010	1 of 1	Tap	center	1
39	411400	Gymnasium (North Building)	Fountain with Bottle Filler	Boys Locker Room	1 of 1	Water Fountain	left	<1
40	411401	Gymnasium (North Building)	Fountain - Multi-Level	Boys Locker Room	1 of 1	Water Fountain	right	<1
41	411402	Gymnasium (North Building)	Fountain - Multi-Level	Girls Locker Room	1 of 1	Water Fountain	right	<1
42	411403	Gymnasium (North Building)	Fountain - Multi-Level	Girls Locker Room	1 of 1	Water Fountain	left	<1
43	411406	Gymnasium (North Building)	Ice Machine	Training Room 3029	2 of 2	Ice Machine	right	<1
44	415041	Gymnasium (North Building)	Fountain - Multi-Level	Consessions Hallway	1 of 1	Water Fountain	right	<1
45	415042	Gymnasium (North Building)	Fountain - Multi-Level	Weight Room	1 of 1	Water Fountain	left	<1
46	415043	Gymnasium (North Building)	Fountain - Multi-Level	Weight Room	1 of 1	Water Fountain	right	<1

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
47	415057	Main Building	Fountain with Bottle Filler	Hallway Next To Room 1103	1 of 1	Water Bottle Filler	center	<1
48	415058	Main Building	Fountain with Bottle Filler	Hallway Next To Room 1103	1 of 1	Water Fountain	right	<1
49	415061	Main Building	Fountain	Hallway Next To Room 1135	1 of 1	Water Fountain	right	<1
50	415068	Main Building	Fountain - Multi-Level	Hallway Next To Room 1205	1 of 1	Water Fountain	left	<1
51	415069	Main Building	Fountain - Multi-Level	Hallway Next To Room 1205	1 of 1	Water Fountain	right	<1
52	415072	Main Building	Fountain	3rd Floor Next To Elevator	1 of 1	Water Fountain	right	<1
53	415074	Main Building	Fountain	Hallway Next To Room 1305	1 of 1	Water Fountain	right	<1
54	415080	Building 2 (South Building)	Fountain - Multi-Level with Bottle Filler	Hallway Next To Electrical 2067	1 of 1	Water Fountain	left	<1
55	415081	Building 2 (South Building)	Fountain - Multi-Level with Bottle Filler	Hallway Next To Electrical 2067	1 of 1	Water Bottle Filler	center	<1
56	415082	Building 2 (South Building)	Fountain - Multi-Level with Bottle Filler	Hallway Next To Electrical 2067	1 of 1	Water Fountain	right	<1

.	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
57	415087	Building 2 (South Building)	Fountain - Multi-Level	Hallway Across From Custodial 2213	1 of 1	Water Fountain	left	<1
58	415088	Building 2 (South Building)	Fountain - Multi-Level	Hallway Across From Custodial 2213	1 of 1	Water Fountain	right	<1
59	415097	Building 2 (South Building)	Fountain - Multi-Level	Across From 2113 ldf	1 of 1	Water Fountain	left	<1
60	415098	Building 2 (South Building)	Fountain - Multi-Level	Across From 2113 ldf	1 of 1	Water Fountain	right	<1