

Lead in School Drinking Water Report

Dunlap Elementary School



EXPLANATION OF TESTING AND RESULTS

Results in this report represent sampling conducted by Washington State Department of Health (DOH). Per [RCW 28A.210.410](#) sampling and testing protocols, samples were collected as first-draw. Depending on size of the school(s) and number of drinking water fixtures, multiple dates for collecting samples may have been necessary to meet sampling and testing protocols.

[RCW 28A.210.410](#) does not require remediation for fixtures testing at 5 ppb and under. DOH offers post-remediation testing only for outlets that initially tested above 5 ppb. After a school completes remediation, DOH will provide up to two post-remediation sampling visits. If after the second post-remediation sampling, outlets test above 5 ppb, the district will be responsible for finding a contractor to conduct additional sampling and testing. For questions regarding sampling, testing, and results, please email: leadfreekids@doh.wa.gov.

DEFINITIONS

Fixture Housing
Location

Room/space where
fixture is located
(i.e. room number,
gym, playground)

Fixture Housing Type

Structure that contains
the individual fixtures
where water samples
were collected from.
Fixture housing may
contain one or more
individual fixture for
sampling.

Fixture Location
Details

Location within a
room or space where
fixture housing is
located, starting to the
left of the entrance and
rotating clockwise, of
the total number of
fixture housings in a
room or space
(e.g. 1/5, 2/5)

Fixture Type

Tap, Sprayer, Water
Fountain, Water Bottle
Filler, Ice maker

Fixture Position

Left, Center, Right

Date(s) collected: 2025-10-22

Date(s) analyzed: 2025-10-30, 2025-11-04

.	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
1	415160	Main Building	Fountain/Tap Combo	Room 104	1 of 1	Tap	center	65
2	415236	Main Building	Fountain/Tap Combo	Room 106b	1 of 1	Tap	center	19
3	415179	Main Building	Fountain/Tap Combo	2nd Floor Work Room	1 of 1	Water Fountain	right	15
4	415171	Main Building	Fountain/Tap Combo	Library Office	1 of 1	Tap	center	12
5	415232	Main Building	Sink	Room 109	1 of 1	Tap	center	9
6	415195	Main Building	Fountain/Tap Combo	Room 203	1 of 1	Water Fountain	right	8
7	415178	Main Building	Fountain/Tap Combo	2nd Floor Work Room	1 of 1	Tap	center	7
8	415192	Main Building	Fountain/Tap Combo	Room 202	1 of 1	Tap	center	7
9	415234	Main Building	Fountain/Tap Combo	Room 107	1 of 1	Tap	center	6
10	415174	Main Building	Fountain/Tap Combo	Room 213	1 of 1	Water Fountain	right	5

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
11	415161	Main Building	Fountain/Tap Combo	Room 104	1 of 1	Water Fountain	right	4
12	415173	Main Building	Fountain/Tap Combo	Room 213	1 of 1	Tap	center	3
13	415220	Main Building	Fountain/Tap Combo	Room 112	1 of 1	Tap	center	3
14	415233	Main Building	Fountain/Tap Combo	Room 106b	1 of 1	Tap	center	3
15	415237	Main Building	Fountain/Tap Combo	Room 106b	1 of 1	Water Fountain	right	3
16	415167	Main Building	Fountain/Tap Combo	Work Room	1 of 1	Water Fountain	right	2
17	415169	Main Building	Fountain/Tap Combo	Room 102	1 of 1	Tap	center	2
18	415172	Main Building	Fountain/Tap Combo	Library Office	1 of 1	Water Fountain	right	2
19	415193	Main Building	Fountain/Tap Combo	Room 202	1 of 1	Water Fountain	right	2
20	415196	Main Building	Fountain/Tap Combo	Room 204	1 of 1	Tap	center	2
21	415198	Main Building	Fountain/Tap Combo	Room 205	1 of 1	Tap	center	2

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
22	415231	Main Building	Fountain/Tap Combo	Room 108	1 of 1	Water Fountain	right	2
23	415162	Main Building	Fountain/Tap Combo	Health Room	1 of 1	Tap	center	1
24	415163	Main Building	Fountain/Tap Combo	Health Room	1 of 1	Water Fountain	right	1
25	415166	Main Building	Fountain/Tap Combo	Work Room	1 of 1	Tap	center	1
26	415170	Main Building	Fountain/Tap Combo	Room 102	1 of 1	Water Fountain	right	1
27	415180	Main Building	Fountain/Tap Combo	Room 207	1 of 1	Tap	center	1
28	415183	Main Building	Fountain/Tap Combo	Room 208	1 of 1	Water Fountain	right	1
29	415186	Main Building	Fountain/Tap Combo	Room 210	1 of 1	Tap	center	1
30	415194	Main Building	Fountain/Tap Combo	Room 203	1 of 1	Tap	center	1
31	415224	Main Building	Sink	Kitchen	1 of 1	Tap	center	1
32	415226	Main Building	Fountain/Tap Combo	Room 110	1 of 2	Tap	left	1

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
33	415235	Main Building	Fountain/Tap Combo	Room 107	1 of 1	Water Fountain	right	1
34	414960	Main Building	Fountain/Tap Combo	Room 206	1 of 1	Tap	center	<1
35	414961	Main Building	Fountain/Tap Combo	Room 206	1 of 1	Water Fountain	right	<1
36	415164	Main Building	Fountain/Tap Combo	Room 103	1 of 1	Tap	center	<1
37	415165	Main Building	Fountain/Tap Combo	Room 103	1 of 1	Water Fountain	right	<1
38	415168	Main Building	Sink	Staff Room	1 of 1	Tap	center	<1
39	415175	Main Building	Fountain/Tap Combo	Room 212	1 of 1	Tap	center	<1
40	415176	Main Building	Fountain/Tap Combo	Room 212	1 of 1	Water Fountain	right	<1
41	415177	Main Building	Fountain	Hallway Outside Of Room 212	1 of 1	Water Fountain	right	<1
42	415181	Main Building	Fountain/Tap Combo	Room 207	1 of 1	Water Fountain	right	<1
43	415182	Main Building	Fountain/Tap Combo	Room 208	1 of 1	Tap	center	<1

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
44	415184	Main Building	Fountain/Tap Combo	Room 209	1 of 1	Tap	center	<1
45	415185	Main Building	Fountain/Tap Combo	Room 209	1 of 1	Water Fountain	right	<1
46	415187	Main Building	Fountain/Tap Combo	Room 210	1 of 1	Water Fountain	right	<1
47	415188	Main Building	Fountain/Tap Combo	Room 211	1 of 1	Tap	center	<1
48	415189	Main Building	Fountain/Tap Combo	Room 211	1 of 1	Water Fountain	right	<1
49	415190	Main Building	Fountain/Tap Combo	Room 201	1 of 1	Tap	center	<1
50	415191	Main Building	Fountain/Tap Combo	Room 201	1 of 1	Water Fountain	right	<1
51	415197	Main Building	Fountain/Tap Combo	Room 204	1 of 1	Water Fountain	right	<1
52	415199	Main Building	Fountain/Tap Combo	Room 205	1 of 1	Water Fountain	right	<1
53	415218	Main Building	Fountain with Bottle Filler	Main Entrance Foyer	1 of 1	Water Bottle Filler	center	<1
54	415219	Main Building	Fountain with Bottle Filler	Main Entrance Foyer	1 of 1	Water Fountain	right	<1

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
55	415221	Main Building	Sink	Room 111	1 of 1	Tap	center	<1
56	415222	Main Building	Fountain with Bottle Filler	Hallway Outside Of Lunch Room	1 of 1	Water Bottle Filler	center	<1
57	415223	Main Building	Fountain with Bottle Filler	Hallway Outside Of Lunchroom	1 of 1	Water Fountain	right	<1
58	415225	Main Building	Fountain	Hallway Outside Of Gym	1 of 1	Water Fountain	right	<1
59	415227	Main Building	Fountain/Tap Combo	Room 110	1 of 2	Water Fountain	left	<1
60	415228	Main Building	Fountain/Tap Combo	Room 110	2 of 2	Tap	right	<1
61	415229	Main Building	Fountain/Tap Combo	Room 110	2 of 2	Water Fountain	right	<1
62	415230	Main Building	Fountain/Tap Combo	Room 108	1 of 1	Tap	center	<1
63	415238	Main Building	Fountain/Tap Combo	Room 105	1 of 1	Tap	center	<1
64	415239	Main Building	Fountain/Tap Combo	Room 105	1 of 1	Water Fountain	right	<1