

Lead in School Drinking Water Report

Seattle World School



EXPLANATION OF TESTING AND RESULTS

Results in this report represent sampling conducted by Washington State Department of Health (DOH). Per [RCW 28A.210.410](#) sampling and testing protocols, samples were collected as first-draw. Depending on size of the school(s) and number of drinking water fixtures, multiple dates for collecting samples may have been necessary to meet sampling and testing protocols.

[RCW 28A.210.410](#) does not require remediation for fixtures testing at 5 ppb and under. DOH offers post-remediation testing only for outlets that initially tested above 5 ppb. After a school completes remediation, DOH will provide up to two post-remediation sampling visits. If after the second post-remediation sampling, outlets test above 5 ppb, the district will be responsible for finding a contractor to conduct additional sampling and testing. For questions regarding sampling, testing, and results, please email: leadfreekids@doh.wa.gov.

DEFINITIONS

Fixture Housing
Location

Room/space where
fixture is located
(i.e. room number,
gym, playground)

Fixture Housing Type

Structure that contains
the individual fixtures
where water samples
were collected from.
Fixture housing may
contain one or more
individual fixture for
sampling.

Fixture Location
Details

Location within a
room or space where
fixture housing is
located, starting to the
left of the entrance and
rotating clockwise, of
the total number of
fixture housings in a
room or space
(e.g. 1/5, 2/5)

Fixture Type

Tap, Sprayer, Water
Fountain, Water Bottle
Filler, Icemaker

Fixture Position

Left, Center, Right

Date(s) collected: 2025-11-13

Date(s) analyzed: 2025-11-20, 2025-11-21

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
1	417288	Main Bldg	Sink	Conference Rm112	1 of 1	Tap	center	3
2	417305	Main Bldg	Fountain	Gym	1 of 1	Water Fountain	center	3
3	417285	Main Bldg	Fountain/Tap Combo	Rm511	1 of 4	Water Fountain	left	2
4	417292	Main Bldg	Sink	Rm108	1 of 1	Tap	center	1
5	417306	Main Bldg	Fountain/Tap Combo	Rm500	1 of 1	Water Fountain	left	1
6	417280	Main Bldg	Fountain - Multi-Level with Bottle Filler	Main Entrance	1 of 1	Water Fountain	left	<1
7	417281	Main Bldg	Fountain with Bottle Filler	Across From South Stair 031	1 of 1	Water Bottle Filler	center	<1
8	417282	Main Bldg	Fountain - Multi-Level with Bottle Filler	Main Entrance	1 of 1	Water Bottle Filler	center	<1
9	417283	Main Bldg	Fountain with Bottle Filler	Across From South Stair 031	1 of 1	Water Fountain	right	<1
10	417284	Main Bldg	Fountain - Multi-Level with Bottle Filler	Main Entrance	1 of 1	Water Fountain	right	<1

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
11	417286	Main Bldg	Sink	Admin Workroom	1 of 1	Tap	center	<1
12	417287	Main Bldg	Fountain/Tap Combo	Rm511	1 of 4	Tap	right	<1
13	417289	Main Bldg	Fountain/Tap Combo	Rm511	2 of 4	Water Fountain	left	<1
14	417290	Main Bldg	Sink	Staff Lounge	1 of 1	Tap	center	<1
15	417291	Main Bldg	Fountain/Tap Combo	Rm511	2 of 4	Tap	right	<1
16	417293	Main Bldg	Fountain/Tap Combo	Rm511	3 of 4	Water Fountain	left	<1
17	417294	Main Bldg	Sink	Kitchen	1 of 1	Tap	center	<1
18	417295	Main Bldg	Fountain/Tap Combo	Rm511	3 of 4	Tap	right	<1
19	417296	Main Bldg	Sink	Kitchen	1 of 1	Sprayer	center	<1
20	417297	Main Bldg	Fountain/Tap Combo	Rm511	4 of 4	Water Fountain	left	<1
21	417298	Main Bldg	Sink	Multipurpose Rm201	1 of 1	Tap	center	<1
22	417299	Main Bldg	Fountain/Tap Combo	Rm511	4 of 4	Tap	right	<1

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
23	417300	Main Bldg	Fountain/Tap Combo	Music Rm	1 of 1	Water Fountain	left	<1
24	417301	Main Bldg	Fountain - Multi-Level	Upstairs Fountain	1 of 1	Water Fountain	left	<1
25	417302	Main Bldg	Sink	Library Office	1 of 1	Tap	center	<1
26	417303	Gymnasium Bldg	Fountain - Multi-Level	Upstairs Fountain	1 of 1	Water Fountain	right	<1
27	417304	Main Bldg	Fountain/Tap Combo	Music Rm	1 of 1	Tap	right	<1
28	417308	Main Bldg	Fountain/Tap Combo	Rm500	1 of 1	Tap	left	<1
29	417310	Main Bldg	Sink	Dental 409	1 of 1	Tap	center	<1
30	417312	Main Bldg	Sink	Across From Flex Office 404	1 of 1	Tap	center	<1
31	417314	Main Bldg	Sink	Exam 411	1 of 1	Tap	center	<1
32	417316	Main Bldg	Sink	Exam 412	1 of 1	Tap	center	<1
33	417318	Main Bldg	Sink	Rm407	1 of 1	Tap	center	<1