

Lead in School Drinking Water Report

Dearborn Park Intl'l Elementary School



EXPLANATION OF TESTING AND RESULTS

Results in this report represent sampling conducted by Washington State Department of Health (DOH). Per [RCW 28A.210.410](#) sampling and testing protocols, samples were collected as first-draw. Depending on size of the school(s) and number of drinking water fixtures, multiple dates for collecting samples may have been necessary to meet sampling and testing protocols.

[RCW 28A.210.410](#) does not require remediation for fixtures testing at 5 ppb and under. DOH offers post-remediation testing only for outlets that initially tested above 5 ppb. After a school completes remediation, DOH will provide up to two post-remediation sampling visits. If after the second post-remediation sampling, outlets test above 5 ppb, the district will be responsible for finding a contractor to conduct additional sampling and testing. For questions regarding sampling, testing, and results, please email: leadfreekids@doh.wa.gov.

DEFINITIONS

Fixture Housing
Location

Room/space where
fixture is located
(i.e. room number,
gym, playground)

Fixture Housing Type

Structure that contains
the individual fixtures
where water samples
were collected from.
Fixture housing may
contain one or more
individual fixture for
sampling.

Fixture Location
Details

Location within a
room or space where
fixture housing is
located, starting to the
left of the entrance and
rotating clockwise, of
the total number of
fixture housings in a
room or space
(e.g. 1/5, 2/5)

Fixture Type

Tap, Sprayer, Water
Fountain, Water Bottle
Filler, Ice maker

Fixture Position

Left, Center, Right

Date(s) collected: 2025-10-23

Date(s) analyzed: 2025-10-30, 2025-10-31

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
1	414976	Main Building	Fountain	Library Fountain	1 of 1	Water Fountain	right	5
2	414964	Preschool Building	Sink	Preschool Room Kitchen	1 of 3. Deep mop style sink	Tap	center	2
3	414966	Preschool Building	Sink	Pre School Kitchen	3 of 3	Tap	center	2
4	414968	Main Building	Sink	Family Room	1 of 1	Tap	center	2
5	414970	Main Building	Sink	Library Office	1 of 1	Tap	center	2
6	414989	Main Building	Fountain/Tap Combo	Room 202	1 of 1	Tap	center	2
7	414977	Main Building	Sink	Room 211	1 of 1	Tap	center	1
8	414982	Main Building	Sink	Kitchen	1 of 1	Tap	center	1
9	414991	Main Building	Fountain/Tap Combo	Room 203	1 of 1	Tap	center	1
10	414962	Preschool Building	Sink	Science/Art Room	1 of 1	Tap	center	<1

.	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
11	414963	Preschool Building	Sink	Preschool Room	1 of 1	Tap	right	<1
12	414965	Preschool Building	Sink - Multi-Compartment	Preschool Room Kitchen	2 of 3	Tap	center	<1
13	414967	Main Building	Sink	Staff Lounge	1 of 1	Tap	center	<1
14	414969	Main Building	Sink	Work Room	1 of 1	Tap	center	<1
15	414971	Main Building	Fountain/Tap Combo	Pod A	1 of 2	Tap	left	<1
16	414972	Main Building	Fountain/Tap Combo	Pod A	1 of 2	Water Fountain	left	<1
17	414973	Main Building	Fountain/Tap Combo	Pod A	2 of 2	Tap	right	<1
18	414974	Main Building	Fountain/Tap Combo	Pod A	2 of 2	Water Fountain	right	<1
19	414975	Main Building	Sink	Teacher Resource Room 24	1 of 1	Tap	center	<1
20	414978	Main Building	Fountain/Tap Combo	Pod D	1 of 2	Tap	left	<1
21	414979	Main Building	Fountain/Tap Combo	Pod D	1 of 2	Water Fountain	left	<1

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
22	414980	Main Building	Fountain/Tap Combo	Pod D	2 of 2	Tap	right	<1
23	414981	Main Building	Fountain/Tap Combo	Pod D	2 of 2	Water Fountain	right	<1
24	414983	Main Building	Fountain - Multi-Level	Commons	1 of 2	Water Fountain	left	<1
25	414984	Main Building	Fountain - Multi-Level	Commons	1 of 2	Water Bottle Filler	right	<1
26	414985	Main Building	Sink	Commons	2 of 2	Tap	center	<1
27	414986	Main Building	Sink	Room 131	1 of 1	Tap	center	<1
28	414987	Main Building	Sink	Room 130	1 of 1	Tap	center	<1
29	414988	Main Building	Sink	Music Room	1 of 1	Tap	center	<1
30	414990	Main Building	Fountain/Tap Combo	Room 202	1 of 1	Water Fountain	right	<1
31	414992	Main Building	Fountain/Tap Combo	Room 203	1 of 1	Water Fountain	right	<1
32	414993	Main Building	Fountain with Bottle Filler	Mid Level Hallway	1 of 1	Water Bottle Filler	center	<1
33	414994	Main Building	Fountain with Bottle Filler	Mid Level Hallway	1 of 1	Water Fountain	right	<1

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
34	414995	Main Building	Fountain/Tap Combo	Pod B	1 of 2	Tap	left	<1
35	414996	Main Building	Fountain/Tap Combo	Pod B	1 of 2	Water Fountain	left	<1
36	414997	Main Building	Fountain/Tap Combo	Pod B	2 of 2	Tap	right	<1
37	414998	Main Building	Fountain/Tap Combo	Pod B	2 of 2	Water Fountain	right	<1
38	414999	Main Building	Fountain/Tap Combo	Pod C	1 of 2	Tap	left	<1
39	415000	Main Building	Fountain/Tap Combo	Pod C	1 of 2	Water Fountain	left	<1
40	415001	Main Building	Fountain/Tap Combo	Pod C	2 of 2	Tap	right	<1
41	415002	Main Building	Fountain/Tap Combo	Pod C	2 of 2	Water Fountain	right	<1
42	415003	Main Building	Sink	Pod C Nurses Office	1 of 1	Tap	center	<1
43	415004	Main Building	Sink	Main Office Nurses Office	1 of 1	Tap	center	<1

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
44	415005	Main Building	Fountain/Tap Combo	Pod E	1 of 2	Tap	left	<1
45	415006	Main Building	Fountain/Tap Combo	Pod E	1 of 2	Water Fountain	left	<1
46	415007	Main Building	Fountain/Tap Combo	Pod E	2 of 2	Tap	right	<1
47	415008	Main Building	Fountain/Tap Combo	Pod E	2 of 2	Water Fountain	right	<1
48	415009	Main Building	Sink	Teacher Prep Room 204 Pod E	1 of 1	Tap	center	<1