

# Lead in School Drinking Water Report

## Gatewood Elementary School



### EXPLANATION OF TESTING AND RESULTS

Results in this report represent sampling conducted by Washington State Department of Health (DOH). Per [RCW 28A.210.410](#) sampling and testing protocols, samples were collected as first-draw. Depending on size of the school(s) and number of drinking water fixtures, multiple dates for collecting samples may have been necessary to meet sampling and testing protocols.

[RCW 28A.210.410](#) does not require remediation for fixtures testing at 5 ppb and under. DOH offers post-remediation testing only for outlets that initially tested above 5 ppb. After a school completes remediation, DOH will provide up to two post-remediation sampling visits. If after the second post-remediation sampling, outlets test above 5 ppb, the district will be responsible for finding a contractor to conduct additional sampling and testing. For questions regarding sampling, testing, and results, please email: [leadfreekids@doh.wa.gov](mailto:leadfreekids@doh.wa.gov).

## DEFINITIONS

Fixture Housing  
Location

Room/space where  
fixture is located  
(i.e. room number,  
gym, playground)

Fixture Housing Type

Structure that contains  
the individual fixtures  
where water samples  
were collected from.  
Fixture housing may  
contain one or more  
individual fixture for  
sampling.

Fixture Location  
Details

Location within a  
room or space where  
fixture housing is  
located, starting to the  
left of the entrance and  
rotating clockwise, of  
the total number of  
fixture housings in a  
room or space  
(e.g. 1/5, 2/5)

Fixture Type

Tap, Sprayer, Water  
Fountain, Water Bottle  
Filler, Ice maker

Fixture Position

Left, Center, Right

Date(s) collected: 2025-11-08

Date(s) analyzed: 2025-11-14

.	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
1	415549	Main Building	Fountain/Tap Combo	Room 10	1 of 1	Tap	center	17
2	415553	Main Building	Fountain/Tap Combo	Room 12	1 of 1	Tap	center	13
3	415557	Main Building	Fountain/Tap Combo	Room 9	1 of 1	Tap	center	12
4	415540	Main Building	Fountain/Tap Combo	Room 5	1 of 1	Tap	center	11
5	415551	Main Building	Fountain/Tap Combo	Room 11	1 of 1	Tap	center	11
6	415561	Main Building	Fountain/Tap Combo	Room 15	1 of 1	Tap	center	11
7	415568	Main Building	Sink	Work Room 203	1 of 1	Tap	center	11
8	415575	Main Building	Fountain/Tap Combo	Room 19	1 of 1	Tap	center	11
9	415538	Main Building	Fountain/Tap Combo	Room 6	1 of 1	Tap	center	10
10	415536	Main Building	Fountain/Tap Combo	Room 7	1 of 1	Tap	center	9

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
11	415543	Main Building	Fountain/Tap Combo	Room 3	1 of 1	Tap	center	9
12	415559	Main Building	Fountain/Tap Combo	Room 14	1 of 1	Tap	center	9
13	415545	Main Building	Fountain/Tap Combo	Room 4	1 of 1	Tap	center	8
14	415528	Main Building	Fountain/Tap Combo	Room 1	1 of 1	Tap	center	7
15	415571	Main Building	Fountain/Tap Combo	Room 20	1 of 1	Tap	center	7
16	415523	Main Building	Sink	Kitchen	1 of 1	Tap	center	6
17	415555	Main Building	Fountain/Tap Combo	Room 13	1 of 1	Tap	center	6
18	415558	Main Building	Fountain/Tap Combo	Room 9	1 of 1	Water Fountain	right	6
19	415534	Main Building	Fountain/Tap Combo	Room 8	1 of 1	Tap	center	5
20	415564	Main Building	Fountain/Tap Combo	Nurses Office	1 of 1	Tap	center	4
21	415567	Main Building	Sink	Office D	1 of 1	Tap	center	4
22	415569	Main Building	Sink	Staff Lounge	1 of 1	Tap	center	4

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
23	415573	Main Building	Fountain/Tap Combo	Room 16	1 of 1	Tap	center	4
24	415524	Main Building	Sink	Kitchen	1 of 1	Sprayer	center	3
25	415542	Main Building	Fountain	Hallway Outside Of Room 3	1 of 1	Water Fountain	right	2
26	415566	Main Building	Fountain/Tap Combo	Nurses Office	1 of 1	Water Fountain	right	2
27	415570	Main Building	Fountain	Hallway Outside Of Work Room 203	1 of 1	Water Fountain	right	2
28	415548	Main Building	Fountain	Hallway Outside Of Room 10	1 of 1	Water Fountain	right	1
29	415578	Main Building	Fountain/Tap Combo	Room 18	1 of 1	Tap	center	1
30	415525	Main Building	Fountain with Bottle Filler	Outside Of Commons	1 of 1	Water Bottle Filler	center	<1
31	415526	Main Building	Fountain with Bottle Filler	Outside Of Commons	1 of 1	Water Fountain	right	<1
32	415527	Main Building	Fountain	Outside Of Gym Office	1 of 1	Water Fountain	right	<1
33	415530	Main Building	Fountain/Tap Combo	Room 1	1 of 1	Water Fountain	right	<1

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
34	415531	Main Building	Fountain/Tap Combo	Room 2	1 of 1	Tap	center	<1
35	415532	Main Building	Fountain/Tap Combo	Room 2	1 of 1	Water Fountain	right	<1
36	415533	Main Building	Fountain	Hallway Next To Room 8	1 of 1	Water Fountain	right	<1
37	415535	Main Building	Fountain/Tap Combo	Room 8	1 of 1	Water Fountain	right	<1
38	415537	Main Building	Fountain/Tap Combo	Room 7	1 of 1	Water Fountain	right	<1
39	415539	Main Building	Fountain/Tap Combo	Room 6	1 of 1	Water Fountain	right	<1
40	415541	Main Building	Fountain/Tap Combo	Room 5	1 of 1	Water Fountain	right	<1
41	415544	Main Building	Fountain/Tap Combo	Room 3	1 of 1	Water Fountain	right	<1
42	415546	Main Building	Fountain/Tap Combo	Room 4	1 of 1	Water Fountain	right	<1
43	415550	Main Building	Fountain/Tap Combo	Room 10	1 of 1	Water Fountain	right	<1
44	415552	Main Building	Fountain/Tap Combo	Room 11	1 of 1	Water Fountain	right	<1

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
45	415554	Main Building	Fountain/Tap Combo	Room 12	1 of 1	Water Fountain	right	<1
46	415556	Main Building	Fountain/Tap Combo	Room 13	1 of 1	Water Fountain	right	<1
47	415560	Main Building	Fountain/Tap Combo	Room 14	1 of 1	Water Fountain	right	<1
48	415562	Main Building	Fountain/Tap Combo	Room 15	1 of 1	Water Fountain	right	<1
49	415563	Main Building	Fountain	Hallway Outside Of Room 15	1 of 1	Water Fountain	right	<1
50	415572	Main Building	Fountain/Tap Combo	Room 20	1 of 1	Water Fountain	right	<1
51	415574	Main Building	Fountain/Tap Combo	Room 16	1 of 1	Water Fountain	right	<1
52	415576	Main Building	Fountain/Tap Combo	Room 19	1 of 1	Water Fountain	right	<1
53	415577	Main Building	Fountain	Fountain Outside Of Room 18	1 of 1	Water Fountain	right	<1
54	415579	Main Building	Fountain/Tap Combo	Room 18	1 of 1	Water Fountain	right	<1
55	415580	Main Building	Fountain/Tap Combo	Room 17	1 of 1	Tap	center	<1

.	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
56	415582	Main Building	Fountain/Tap Combo	Room 17	1 of 1	Water Fountain	right	<1