

Lead in School Drinking Water Report

Madison Middle School



EXPLANATION OF TESTING AND RESULTS

Results in this report represent sampling conducted by Washington State Department of Health (DOH). Per [RCW 28A.210.410](#) sampling and testing protocols, samples were collected as first-draw. Depending on size of the school(s) and number of drinking water fixtures, multiple dates for collecting samples may have been necessary to meet sampling and testing protocols.

[RCW 28A.210.410](#) does not require remediation for fixtures testing at 5 ppb and under. DOH offers post-remediation testing only for outlets that initially tested above 5 ppb. After a school completes remediation, DOH will provide up to two post-remediation sampling visits. If after the second post-remediation sampling, outlets test above 5 ppb, the district will be responsible for finding a contractor to conduct additional sampling and testing. For questions regarding sampling, testing, and results, please email: leadfreetkids@doh.wa.gov.

DEFINITIONS

Fixture Housing Location	Room/space where fixture is located (i.e. room number, gym, playground)
Fixture Housing Type	Structure that contains the individual fixtures where water samples were collected from. Fixture housing may contain one or more individual fixture for sampling.
Fixture Location Details	Location within a room or space where fixture housing is located, starting to the left of the entrance and rotating clockwise, of the total number of fixture housings in a room or space (e.g. 1/5, 2/5)
Fixture Type	Tap, Sprayer, Water Fountain, Water Bottle Filler, Icemaker
Fixture Position	Left, Center, Right

Date(s) collected: 2025-12-10

Date(s) analyzed: 2025-12-16, 2025-12-30

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
1	414542	Main Building	Sink	Room 117	1 of 1	Tap	center	232
2	414539	Main Building	Sink	Student Store	1 of 1	Tap	center	35
3	414572	Main Building	Sink - Multi-Compartment	Room L217	1 of 1	Tap	center	22
4	414569	Gym Building	Sink	Concessions	1 of 1	Tap	center	20
5	414525	Main Building	Sink	Room 103d	1 of 1	Tap	center	15
6	414531	Main Building	Pot Filler	Kitchen	2 of 2	Sprayer	center	11
7	414534	Main Building	Fountain/Tap Combo	Band Room	1 of 1	Tap	center	10
8	414540	Main Building	Sink	Staff Lounge	1 of 1	Tap	center	8
9	414527	Main Building	Sink	Room 103k	1 of 1	Tap	center	7
10	414553	Main Building	Sink	Room 213	1 of 1	Tap	center	7
11	414560	Main Building	Sink - Multi-Compartment	Room 303	1 of 1	Tap	center	7
12	414541	Main Building	Sink	Library Office	1 of 1	Tap	center	6
13	414554	Main Building	Sink - Multi-Compartment	Pod Sink Outside Of Room 212	1 of 1	Tap	center	6

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
14	414561	Main Building	Sink - Multi-Compartment	Room 313	1 of 1	Tap	center	6
15	414564	Main Building	Sink - Multi-Compartment	Pod Sink Outside Of Room 315	1 of 1	Tap	center	6
16	414528	Main Building	Sink - Multi-Compartment	Room 104a	1 of 1	Tap	center	5
17	414544	Main Building	Sink	Room 118	1 of 1	Tap	center	5
18	414551	Main Building	Sink - Multi-Compartment	Pod Sink Outside Of Room 206	1 of 1	Tap	center	5
19	414559	Main Building	Sink - Multi-Compartment	Pod Sink Outside Of Room 306	1 of 1	Tap	center	5
20	414548	Main Building	Sink	Room 113a	1 of 1	Tap	center	4
21	414575	Main Building	Sink - Multi-Compartment	Room L209	1 of 1	Tap	center	4
22	414576	Main Building	Sink	L200a	1 of 1	Tap	center	4
23	414526	Main Building	Sink	Room 103e	1 of 1	Tap	center	3
24	414543	Main Building	Sink - Multi-Compartment	Room 117a	1 of 1	Tap	center	3
25	414547	Main Building	Sink	Room 116	1 of 1	Tap	center	3
26	414549	Main Building	Sink	Office 101f	1 of 1	Tap	center	3
27	414552	Main Building	Sink	Room 203	1 of 1	Tap	center	3

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
28	414573	Main Building	Sink - Multi-Compartment	Hallway Outside Of Room L218	1 of 1	Tap	center	3
29	414523	Main Building	Fountain - Multi-Level	Room 103	1 of 2	Water Fountain	left	2
30	414529	Main Building	Sink - Multi-Compartment	Kitchen	1 of 2	Tap	center	2
31	414533	Main Building	Fountain - Multi-Level	Hallway Outside Of Kitchen	1 of 1	Water Fountain	left	2
32	414535	Main Building	Fountain/Tap Combo	Band Room	1 of 1	Water Fountain	right	2
33	414565	Gym Building	Fountain - Multi-Level	Foyer	1 of 1	Water Fountain	right	2
34	414566	Gym Building	Fountain - Multi-Level	Foyer	1 of 1	Water Fountain	left	2
35	414567	Gym Building	Fountain - Multi-Level	Gym	1 of 1	Water Fountain	right	2
36	414522	Main Building	Fountain - Multi-Level	Room 103	1 of 2	Water Fountain	right	1
37	414557	Main Building	Fountain - Multi-Level	Hallway Outside Of Room 304	1 of 1	Water Fountain	right	1
38	414520	Main Building	Fountain - Multi-Level	Hallway Outside Of Room 103	1 of 1	Water Fountain	right	<1

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
39	414521	Main Building	Fountain - Multi-Level	Hallway Outside Of Room 103	1 of 1	Water Fountain	left	<1
40	414524	Main Building	Sink	Room 103	2 of 2	Tap	center	<1
41	414530	Main Building	Sink - Multi-Compartment	Kitchen	1 of 2	Sprayer	center	<1
42	414532	Main Building	Fountain - Multi-Level	Hallway Outside Of Kitchen	1 of 1	Water Fountain	right	<1
43	414536	Main Building	Fountain - Multi-Level with Bottle Filler	Commons	1 of 1	Water Bottle Filler	center	<1
44	414537	Main Building	Fountain - Multi-Level with Bottle Filler	Commons	1 of 1	Water Fountain	left	<1
45	414538	Main Building	Fountain - Multi-Level with Bottle Filler	Commons	1 of 1	Water Fountain	right	<1
46	414545	Main Building	Fountain - Multi-Level	Hallway Next To Room 116	1 of 1	Water Fountain	right	<1
47	414546	Main Building	Fountain - Multi-Level	Hallway Next To Room 116	1 of 1	Water Fountain	left	<1
48	414550	Main Building	Fountain - Multi-Level	Hallway Outside Of Room 204	1 of 1	Water Fountain	right	<1

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
49	414555	Main Building	Fountain - Multi-Level	Hallway Outside Of Room 213	1 of 1	Water Fountain	right	<1
50	414556	Main Building	Fountain - Multi-Level	Hallway Outside Of Room 212	1 of 1	Water Fountain	left	<1
51	414558	Main Building	Fountain - Multi-Level	Outside Of Room 304	1 of 1	Water Fountain	left	<1
52	414562	Main Building	Fountain - Multi-Level	Hallway Outside Of Room 315	1 of 1	Water Fountain	right	<1
53	414563	Main Building	Fountain - Multi-Level	Hallway Outside Of Room 315	1 of 1	Water Fountain	left	<1
54	414568	Gym Building	Fountain - Multi-Level	Gym	1 of 1	Water Fountain	left	<1
55	414570	Main Building	Fountain - Multi-Level	Hallway Next To Room L221	1 of 1	Water Fountain	right	<1
56	414571	Main Building	Fountain - Multi-Level	Hallway Next To Room L221	1 of 1	Water Fountain	left	<1
57	414574	Main Building	Fountain - Multi-Level	Hallway Next To Room L209	1 of 1	Water Fountain	left	<1