

Lead in School Drinking Water Report

Chief Sealth International High School



EXPLANATION OF TESTING AND RESULTS

Results in this report represent sampling conducted by Washington State Department of Health (DOH). Per [RCW 28A.210.410](#) sampling and testing protocols, samples were collected as first-draw. Depending on size of the school(s) and number of drinking water fixtures, multiple dates for collecting samples may have been necessary to meet sampling and testing protocols.

[RCW 28A.210.410](#) does not require remediation for fixtures testing at 5 ppb and under. DOH offers post-remediation testing only for outlets that initially tested above 5 ppb. After a school completes remediation, DOH will provide up to two post-remediation sampling visits. If after the second post-remediation sampling, outlets test above 5 ppb, the district will be responsible for finding a contractor to conduct additional sampling and testing. For questions regarding sampling, testing, and results, please email: leadfreetkids@doh.wa.gov.

DEFINITIONS

| | |
|--------------------------|---|
| Fixture Housing Location | Room/space where fixture is located (i.e. room number, gym, playground) |
| Fixture Housing Type | Structure that contains the individual fixtures where water samples were collected from. Fixture housing may contain one or more individual fixture for sampling. |
| Fixture Location Details | Location within a room or space where fixture housing is located, starting to the left of the entrance and rotating clockwise, of the total number of fixture housings in a room or space (e.g. 1/5, 2/5) |
| Fixture Type | Tap, Sprayer, Water Fountain, Water Bottle Filler, Icemaker |
| Fixture Position | Left, Center, Right |

Date(s) collected: 2025-12-12

Date(s) analyzed: 2025-12-17, 2025-12-30

| | Sample ID | Building Name | Fixture Housing Type | Fixture Location | Fixture Location Details | Fixture Type | Fixture Position | Lead Test Result (ppb) |
|----|-----------|---------------|--------------------------|---------------------------|--------------------------|---------------------|------------------|------------------------|
| 1 | 414158 | Main Building | Sink - Multi-Compartment | Room 141c | 1 of 1 | Tap | center | 22 |
| 2 | 414148 | Main Building | Sink - Multi-Compartment | Room 204c | 1 of 1 | Tap | center | 17 |
| 3 | 414150 | Main Building | Sink | Room 214a | 2 of 2 | Tap | right | 15 |
| 4 | 414136 | Main Building | Fountain - Multi-Level | Hallway Next To Room 274 | 1 of 1 | Water Bottle Filler | left | 7 |
| 5 | 414137 | Main Building | Fountain - Multi-Level | Hallway Next To Room 274 | 1 of 1 | Water Fountain | right | 4 |
| 6 | 414149 | Main Building | Sink | Room 214a | 1 of 2 | Tap | left | 4 |
| 7 | 414140 | Main Building | Fountain - Multi-Level | Hallway Next To Room 237a | 1 of 1 | Water Bottle Filler | left | 3 |
| 8 | 414125 | Main Building | Sink - Multi-Compartment | Room 222 | 1 of 1 | Tap | center | 2 |
| 9 | 414144 | Main Building | Sink | Room 220b | 2 of 2. Next to restroom | Tap | center | 2 |
| 10 | 414170 | Main Building | Fountain - Multi-Level | Boys Locker Room | 1 of 1 | Water Fountain | right | 2 |
| 11 | 414120 | Main Building | Sink | Staff Work Room | 1 of 1 | Tap | center | 1 |

| | Sample ID | Building Name | Fixture Housing Type | Fixture Location | Fixture Location Details | Fixture Type | Fixture Position | Lead Test Result (ppb) |
|----|-----------|---------------|---|-----------------------------------|--------------------------|---------------------|------------------|------------------------|
| 12 | 414126 | Main Building | Fountain - Multi-Level | Hallway Next To Room 228 | 1 of 1 | Water Bottle Filler | left | 1 |
| 13 | 414133 | Main Building | Sink - Multi-Compartment | Room 228 | 6 of 8. Station 6 | Tap | center | 1 |
| 14 | 414141 | Main Building | Fountain with Bottle Filler | Hallway Next To Room 237a | 1 of 1 | Water Fountain | right | 1 |
| 15 | 414152 | Main Building | Fountain - Multi-Level | Hallway Across From 214e | 1 of 1 | Water Fountain | right | 1 |
| 16 | 414121 | Main Building | Fountain - Multi-Level with Bottle Filler | Hallway Next To Attendance Office | 1 of 1 | Water Bottle Filler | center | <1 |
| 17 | 414122 | Main Building | Fountain - Multi-Level with Bottle Filler | Hallway Next To Attendance Office | 1 of 1 | Water Fountain | left | <1 |
| 18 | 414123 | Main Building | Fountain - Multi-Level with Bottle Filler | Hallway Next To Attendance Office | 1 of 1 | Water Fountain | right | <1 |
| 19 | 414124 | Main Building | Sink - Multi-Compartment | Room 220 | 1 of 1 | Tap | center | <1 |
| 20 | 414127 | Main Building | Fountain - Multi-Level | Hallway Next To Room 228 | 1 of 1 | Water Fountain | right | <1 |
| 21 | 414128 | Main Building | Sink - Multi-Compartment | Room 228 | 1 of 8. Station 1 | Tap | center | <1 |

| | Sample ID | Building Name | Fixture Housing Type | Fixture Location | Fixture Location Details | Fixture Type | Fixture Position | Lead Test Result (ppb) |
|----|-----------|---------------|-----------------------------|------------------------------|--------------------------|---------------------|------------------|------------------------|
| 22 | 414129 | Main Building | Sink - Multi-Compartment | Room 228 | 2 of 8. Station 2 | Tap | center | <1 |
| 23 | 414130 | Main Building | Sink - Multi-Compartment | Room 228 | 3 of 8. Station 3 | Tap | center | <1 |
| 24 | 414131 | Main Building | Sink - Multi-Compartment | Room 228 | 4 of 8. Station 4 | Tap | center | <1 |
| 25 | 414132 | Main Building | Sink - Multi-Compartment | Room 228 | 5 of 8. Station 5 | Tap | center | <1 |
| 26 | 414134 | Main Building | Sink - Multi-Compartment | Room 228 | 7 of 8. Station 7 | Tap | center | <1 |
| 27 | 414135 | Main Building | Sink - Multi-Compartment | Room 228 | 8 of 8. Station 8 | Tap | center | <1 |
| 28 | 414138 | Main Building | Fountain with Bottle Filler | Hallway Next To Room 257 | 1 of 1 | Water Bottle Filler | center | <1 |
| 29 | 414139 | Main Building | Fountain with Bottle Filler | Hallway Next To Room 257 | 1 of 1 | Water Fountain | right | <1 |
| 30 | 414142 | Main Building | Fountain | Hallway Across From Room 233 | 1 of 1 | Water Fountain | right | <1 |
| 31 | 414143 | Main Building | Sink | Room 220b | 1 of 2 | Tap | center | <1 |
| 32 | 414145 | Main Building | Fountain | Hallway Next To Room 209 | 1 of 1 | Water Fountain | right | <1 |

| | Sample ID | Building Name | Fixture Housing Type | Fixture Location | Fixture Location Details | Fixture Type | Fixture Position | Lead Test Result (ppb) |
|----|-----------|---------------|---|------------------------------|--------------------------|---------------------|------------------|------------------------|
| 33 | 414146 | Main Building | Fountain - Multi-Level | Auditorium | 1 of 1 | Water Fountain | left | <1 |
| 34 | 414147 | Main Building | Fountain - Multi-Level | Auditorium | 1 of 1 | Water Fountain | right | <1 |
| 35 | 414151 | Main Building | Fountain - Multi-Level | Hallway Across From 214e | 1 of 1 | Water Fountain | left | <1 |
| 36 | 414153 | Main Building | Fountain - Multi-Level | Cafeteria | 1 of 1 | Water Bottle Filler | left | <1 |
| 37 | 414154 | Main Building | Fountain - Multi-Level | Cafeteria | 1 of 1 | Water Fountain | right | <1 |
| 38 | 414155 | Main Building | Fountain - Multi-Level with Bottle Filler | Hallway Outside Of Room 151 | 1 of 1 | Water Bottle Filler | center | <1 |
| 39 | 414156 | Main Building | Fountain - Multi-Level with Bottle Filler | Hallway Outside Of Room. 151 | 1 of 1 | Water Fountain | left | <1 |
| 40 | 414157 | Main Building | Fountain - Multi-Level with Bottle Filler | Hallway Outside Of Room 151 | 1 of 1 | Water Fountain | right | <1 |
| 41 | 414159 | Main Building | Fountain - Multi-Level | Gym | 1 of 2 | Water Bottle Filler | left | <1 |
| 42 | 414160 | Main Building | Fountain - Multi-Level | Gym | 1 of 2 | Water Fountain | right | <1 |

| | Sample ID | Building Name | Fixture Housing Type | Fixture Location | Fixture Location Details | Fixture Type | Fixture Position | Lead Test Result (ppb) |
|----|-----------|---------------|------------------------|------------------|---|----------------|------------------|------------------------|
| 43 | 414161 | Main Building | Fountain - Multi-Level | Gym | 2 of 2. Across from 196A | Water Fountain | left | <1 |
| 44 | 414162 | Main Building | Fountain - Multi-Level | Gym | 2 of 2. Across from 196A | Water Fountain | right | <1 |
| 45 | 414163 | Main Building | Fountain - Multi-Level | Gym Foyer | 1 of 2. East side next to women's restroom | Water Fountain | left | <1 |
| 46 | 414164 | Main Building | Fountain - Multi-Level | Gym Foyer | 1 of 2. East side next to women's restroom | Water Fountain | right | <1 |
| 47 | 414165 | Main Building | Fountain - Multi-Level | Gym Foyer | 2 of 2. West side next to men's restroom | Water Fountain | left | <1 |

| | Sample ID | Building Name | Fixture Housing Type | Fixture Location | Fixture Location Details | Fixture Type | Fixture Position | Lead Test Result (ppb) |
|----|-----------|---------------|------------------------|-------------------|---|----------------|------------------|------------------------|
| 48 | 414166 | Main Building | Fountain - Multi-Level | Gym Foyer | 2 of 2. West side next to men's restroom | Water Fountain | right | <1 |
| 49 | 414167 | Main Building | Fountain - Multi-Level | Girls Locker Room | 1 of 1 | Water Fountain | left | <1 |
| 50 | 414168 | Main Building | Fountain - Multi-Level | Girls Locker Room | 1 of 1 | Water Fountain | right | <1 |
| 51 | 414169 | Main Building | Fountain - Multi-Level | Boys Locker Room | 1 of 1 | Water Fountain | left | <1 |