

Lead in School Drinking Water Report

Denny International Middle School



EXPLANATION OF TESTING AND RESULTS

Results in this report represent sampling conducted by Washington State Department of Health (DOH). Per [RCW 28A.210.410](#) sampling and testing protocols, samples were collected as first-draw. Depending on size of the school(s) and number of drinking water fixtures, multiple dates for collecting samples may have been necessary to meet sampling and testing protocols.

[RCW 28A.210.410](#) does not require remediation for fixtures testing at 5 ppb and under. DOH offers post-remediation testing only for outlets that initially tested above 5 ppb. After a school completes remediation, DOH will provide up to two post-remediation sampling visits. If after the second post-remediation sampling, outlets test above 5 ppb, the district will be responsible for finding a contractor to conduct additional sampling and testing. For questions regarding sampling, testing, and results, please email: leadfreetkids@doh.wa.gov.

DEFINITIONS

Fixture Housing Location	Room/space where fixture is located (i.e. room number, gym, playground)
Fixture Housing Type	Structure that contains the individual fixtures where water samples were collected from. Fixture housing may contain one or more individual fixture for sampling.
Fixture Location Details	Location within a room or space where fixture housing is located, starting to the left of the entrance and rotating clockwise, of the total number of fixture housings in a room or space (e.g. 1/5, 2/5)
Fixture Type	Tap, Sprayer, Water Fountain, Water Bottle Filler, Icemaker
Fixture Position	Left, Center, Right

Date(s) collected: 2025-12-11

Date(s) analyzed: 2025-12-16, 2025-12-30

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
1	414622	Main Building	Fountain/Tap Combo	Room 154	2 of 2	Water Fountain	right	19
2	414606	Main Building	Pot Filler	Kitchen Across From 180	7 of 8	Tap	center	17
3	414620	Main Building	Fountain/Tap Combo	Room 154	1 of 2	Water Fountain	left	12
4	414626	Main Building	Fountain/Tap Combo	Room 158	2 of 2	Water Fountain	right	6
5	414618	Main Building	Fountain/Tap Combo	Hallway Across From Room 154	1 of 1	Water Fountain	right	5
6	414638	Main Building	Sink	Room 278	1 of 1	Tap	center	5
7	414088	Main Building	Sink	Room 378	1 of 1	Tap	center	4
8	414091	Main Building	Fountain/Tap Combo	Across From Room 354	1 of 1	Tap	center	4
9	414603	Main Building	Pot Filler	Kitchen Across From 180c	4 of 8	Tap	center	4
10	414634	Main Building	Fountain/Tap Combo	Room 148	1 of 2	Tap	left	4
11	414636	Main Building	Fountain/Tap Combo	Room 148	2 of 2	Tap	right	4

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
12	414614	Main Building	Sink	Room 177	1 of 1	Tap	center	3
13	414630	Main Building	Fountain/Tap Combo	Room 144	1 of 2	Tap	left	3
14	414631	Main Building	Fountain/Tap Combo	Room 144	1 of 2	Water Fountain	left	3
15	414633	Main Building	Fountain/Tap Combo	Room 144	2 of 2	Water Fountain	right	3
16	414637	Main Building	Fountain/Tap Combo	Room 148	2 of 2	Water Fountain	right	3
17	414083	Main Building	Fountain/Tap Combo	Hallway Across From Room 244	1 of 1	Tap	center	2
18	414092	Main Building	Fountain/Tap Combo	Across From Room 354	1 of 1	Water Fountain	right	2
19	414095	Main Building	Fountain/Tap Combo	Hallway Across From Room 344	1 of 1	Tap	center	2
20	414097	Main Building	Sink	Library Office	1 of 1	Tap	center	2
21	414605	Main Building	Sink	Kitchen 180j	6 of 8	Tap	right	2
22	414617	Main Building	Fountain/Tap Combo	Hallway Across From Room 154	1 of 1	Tap	center	2
23	414621	Main Building	Fountain/Tap Combo	Room 154	2 of 2	Tap	right	2

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
24	414623	Main Building	Fountain/Tap Combo	Room 158	1 of 2	Tap	left	2
25	414624	Main Building	Fountain/Tap Combo	Room 158	1 of 2	Water Fountain	left	2
26	414628	Main Building	Fountain/Tap Combo	Hallway Across From Room 144	1 of 1	Tap	center	2
27	414629	Main Building	Fountain/Tap Combo	Hallway Across From Room 144	1 of 1	Water Fountain	right	2
28	414632	Main Building	Fountain/Tap Combo	Room 144	2 of 2	Tap	right	2
29	414635	Main Building	Fountain/Tap Combo	Room 148	1 of 2	Water Fountain	left	2
30	414084	Main Building	Fountain/Tap Combo	Hallway Across From Room 244	1 of 1	Water Fountain	right	1
31	414096	Main Building	Fountain/Tap Combo	Hallway Across From Room 344	1 of 1	Water Fountain	right	1
32	414607	Main Building	Sink	Kitchen 180j	8 of 8	Sprayer	right	1
33	414610	Main Building	Fountain	Gym	1 of 3. In between 170H and 170J	Water Fountain	right	1

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
34	414625	Main Building	Fountain/Tap Combo	Room 158	2 of 2	Tap	right	1
35	414639	Main Building	Sink	Office Next To Room 202d	1 of 1	Tap	center	1
36	414080	Main Building	Fountain - Multi-Level	Hallway Next To Room 250b	1 of 1	Water Fountain	left	<1
37	414081	Main Building	Fountain - Multi-Level	Hallway Next To Room 250b	1 of 1	Water Fountain	right	<1
38	414082	Main Building	Fountain - Multi-Level	Hallway Next To Room 240b	1 of 1	Water Fountain	right	<1
39	414085	Main Building	Fountain - Multi-Level	Next To Room 281	1 of 1	Water Fountain	right	<1
40	414086	Main Building	Sink - Multi-Compartment	Room 284a	1 of 1	Tap	center	<1
41	414087	Main Building	Sink	Room 288	1 of 1	Tap	center	<1
42	414089	Main Building	Fountain - Multi-Level	Hallway Next To 350b	1 of 1	Water Fountain	left	<1
43	414090	Main Building	Fountain - Multi-Level	Hallway Next To 350b	1 of 1	Water Fountain	right	<1
44	414093	Main Building	Fountain - Multi-Level	Next To Room 340b	1 of 1	Water Fountain	left	<1

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
45	414094	Main Building	Fountain - Multi-Level	Hallway Next To 340b	1 of 1	Water Fountain	right	<1
46	414600	Main Building	Sink - Multi-Compartment	Kitchen. Across From 180b	1 of 8	Tap	center	<1
47	414601	Main Building	Sink	Kitchen. Wall Along 180j	2 of 8	Tap	left	<1
48	414602	Main Building	Sink	Kitchen. Wall Along 180j	3 of 8	Tap	right	<1
49	414604	Main Building	Sink - Multi-Compartment	Kitchen Across From 180c	5 of 8	Tap	center	<1
50	414608	Main Building	Fountain with Bottle Filler	Next To Custodial 176	1 of 1	Water Bottle Filler	center	<1
51	414609	Main Building	Fountain with Bottle Filler	Next To Custodial 176	1 of 1	Water Fountain	right	<1
52	414611	Main Building	Fountain	Gym	2 of 3. Next to 170M	Water Fountain	right	<1
53	414612	Main Building	Fountain	Gym	3 of 3. Next to 170D	Water Fountain	right	<1
54	414613	Main Building	Sink - Multi-Compartment	181e	1 of 1	Tap	center	<1

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
55	414615	Main Building	Fountain - Multi-Level	Hallway In Between Restrooms Next To 150b	1 of 1	Water Fountain	left	<1
56	414616	Main Building	Fountain - Multi-Level	Hallway In Between Restrooms Next To 150b	1 of 1	Water Fountain	right	<1
57	414619	Main Building	Fountain/Tap Combo	Room 154	1 of 2	Tap	left	<1
58	414627	Main Building	Fountain - Multi-Level	Hallway Across From Room 142	1 of 1	Water Fountain	left	<1