

# Lead in School Drinking Water Report

## Cooper (Pathfinder) Elementary School



### EXPLANATION OF TESTING AND RESULTS

Results in this report represent sampling conducted by Washington State Department of Health (DOH). Per [RCW 28A.210.410](#) sampling and testing protocols, samples were collected as first-draw. Depending on size of the school(s) and number of drinking water fixtures, multiple dates for collecting samples may have been necessary to meet sampling and testing protocols.

[RCW 28A.210.410](#) does not require remediation for fixtures testing at 5 ppb and under. DOH offers post-remediation testing only for outlets that initially tested above 5 ppb. After a school completes remediation, DOH will provide up to two post-remediation sampling visits. If after the second post-remediation sampling, outlets test above 5 ppb, the district will be responsible for finding a contractor to conduct additional sampling and testing. For questions regarding sampling, testing, and results, please email: [leadfreekids@doh.wa.gov](mailto:leadfreekids@doh.wa.gov).

## DEFINITIONS

Fixture Housing  
Location

Room/space where  
fixture is located  
(i.e. room number,  
gym, playground)

Fixture Housing Type

Structure that contains  
the individual fixtures  
where water samples  
were collected from.  
Fixture housing may  
contain one or more  
individual fixture for  
sampling.

Fixture Location  
Details

Location within a  
room or space where  
fixture housing is  
located, starting to the  
left of the entrance and  
rotating clockwise, of  
the total number of  
fixture housings in a  
room or space  
(e.g. 1/5, 2/5)

Fixture Type

Tap, Sprayer, Water  
Fountain, Water Bottle  
Filler, Ice maker

Fixture Position

Left, Center, Right

Date(s) collected: 2025-11-06

Date(s) analyzed: 2025-11-19, 2025-11-21

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
1	415145	Main Building	Sink	Nurses Office	1 of 1	Tap	center	5
2	411251	Main Building	Fountain/Tap Combo	Room 223	1 of 1	Tap	center	4
3	411265	Main Building	Fountain - Multi-Level	Hallway Next To Room 311	1 of 1	Water Fountain	right	3
4	411277	Main Building	Fountain - Multi-Level	Hallway Next To Room 322	1 of 1	Water Fountain	left	3
5	415142	Main Building	Fountain/Tap Combo	Room 214	1 of 1	Tap	center	3
6	415151	Main Building	Fountain/Tap Combo	Room 123	1 of 1	Tap	center	3
7	411253	Main Building	Fountain/Tap Combo	Room 112	1 of 1	Water Fountain	right	2
8	415149	Main Building	Fountain/Tap Combo	Room 124	1 of 1	Tap	center	2
9	415158	Main Building	Fountain/Tap Combo	Room 118	1 of 1	Tap	center	2
10	411252	Main Building	Fountain/Tap Combo	Room 112	1 of 1	Tap	center	1

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
11	411254	Main Building	Fountain/Tap Combo	Room 111	1 of 1	Tap	center	1
12	411256	Main Building	Fountain/Tap Combo	Room 110	1 of 1	Tap	center	1
13	411262	Main Building	Fountain/Tap Combo	Room 106	1 of 1	Tap	center	1
14	411270	Main Building	Fountain/Tap Combo	Room 309	1 of 1	Tap	center	1
15	411276	Main Building	Fountain - Multi-Level	Hallway Next To Room 322	1 of 1	Water Fountain	right	1
16	411278	Main Building	Fountain/Tap Combo	Room 317	1 of 1	Tap	center	1
17	415148	Main Building	Fountain - Multi-Level	Bottom Floor Next To Elevator	1 of 1	Water Fountain	left	1
18	415156	Main Building	Fountain/Tap Combo	Room 119	1 of 1	Tap	center	1
19	415280	Main Building	Sink	Room 318	1 of 3	Tap	left	1
20	415286	Main Building	Fountain/Tap Combo	Room 321	1 of 1	Tap	center	1
21	411249	Main Building	Sink	Kitchen	1 of 1	Sprayer	center	<1
22	411250	Main Building	Sink	Work Room	1 of 1	Tap	center	<1

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
23	411255	Main Building	Fountain/Tap Combo	Room 111	1 of 1	Water Fountain	right	<1
24	411257	Main Building	Fountain/Tap Combo	Room 110	1 of 1	Water Fountain	right	<1
25	411258	Main Building	Fountain/Tap Combo	Room 109	1 of 1	Tap	center	<1
26	411259	Main Building	Fountain/Tap Combo	Room 109	1 of 1	Water Fountain	right	<1
27	411260	Main Building	Fountain/Tap Combo	Room 107	1 of 1	Tap	center	<1
28	411261	Main Building	Fountain/Tap Combo	Room 107	1 of 1	Water Fountain	right	<1
29	411263	Main Building	Fountain/Tap Combo	Room 106	1 of 1	Water Fountain	right	<1
30	411264	Main Building	Sink	Library Office	1 of 1	Tap	center	<1
31	411266	Main Building	Fountain/Tap Combo	Room 311	1 of 1	Tap	center	<1
32	411267	Main Building	Fountain/Tap Combo	Room 311	1 of 1	Water Fountain	right	<1
33	411268	Main Building	Fountain/Tap Combo	Room 310	1 of 1	Tap	center	<1

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
34	411269	Main Building	Fountain/Tap Combo	Room 310	1 of 1	Water Fountain	right	<1
35	411271	Main Building	Fountain/Tap Combo	Room 309	1 of 1	Water Fountain	right	<1
36	411272	Main Building	Fountain/Tap Combo	Room 307	1 of 1	Tap	center	<1
37	411273	Main Building	Fountain/Tap Combo	Room 307	1 of 1	Water Fountain	right	<1
38	411274	Main Building	Fountain/Tap Combo	Room 306	1 of 1	Tap	center	<1
39	411275	Main Building	Fountain/Tap Combo	Room 306	1 of 1	Water Fountain	right	<1
40	411279	Main Building	Fountain/Tap Combo	Room 317	1 of 1	Water Fountain	right	<1
41	415137	Main Building	Fountain/Tap Combo	Room 223	1 of 1	Water Fountain	right	<1
42	415138	Main Building	Fountain/Tap Combo	Room 210	1 of 1	Tap	center	<1
43	415139	Main Building	Fountain/Tap Combo	Room 210	1 of 1	Water Fountain	right	<1
44	415140	Main Building	Fountain - Multi-Level	Hallway Outside Of Room 214	1 of 1	Water Fountain	right	<1

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
45	415141	Main Building	Fountain - Multi-Level	Hallway Outside Of Room 214	1 of 1	Water Fountain	left	<1
46	415143	Main Building	Fountain/Tap Combo	Room 214	1 of 1	Water Fountain	right	<1
47	415144	Main Building	Sink - Multi-Compartment	Staff Lounge	1 of 1	Tap	center	<1
48	415146	Main Building	Sink	Workroom 201a	1 of 1	Tap	center	<1
49	415147	Main Building	Fountain - Multi-Level	Bottom Floor Next To Elevator	1 of 1	Water Fountain	right	<1
50	415150	Main Building	Fountain/Tap Combo	Room 124	1 of 1	Water Fountain	right	<1
51	415152	Main Building	Fountain/Tap Combo	Room 122	1 of 1	Tap	center	<1
52	415153	Main Building	Fountain/Tap Combo	Room 122	1 of 1	Water Fountain	right	<1
53	415154	Main Building	Fountain/Tap Combo	Room 121	1 of 1	Tap	center	<1
54	415155	Main Building	Fountain/Tap Combo	Room 121	1 of 1	Water Fountain	right	<1
55	415157	Main Building	Fountain/Tap Combo	Room 119	1 of 1	Water Fountain	right	<1

---

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
56	415159	Main Building	Fountain/Tap Combo	Room 118	1 of 1	Water Fountain	right	<1
57	415281	Main Building	Sink	Room 318	2 of 3	Tap	center	<1
58	415282	Main Building	Fountain/Tap Combo	Room 318	3 of 3	Tap	right	<1
59	415283	Main Building	Fountain/Tap Combo	Room 318	3 of 3	Water Fountain	right	<1
60	415284	Main Building	Fountain/Tap Combo	Room 320	1 of 1	Tap	center	<1
61	415285	Main Building	Fountain/Tap Combo	Room 320	1 of 1	Water Fountain	right	<1
62	415287	Main Building	Fountain/Tap Combo	Room 321	1 of 1	Water Fountain	right	<1

---