

Lead in School Drinking Water Report

Daniel Bagley Elementary School



EXPLANATION OF TESTING AND RESULTS

Results in this report represent sampling conducted by Washington State Department of Health (DOH). Per [RCW 28A.210.410](#) sampling and testing protocols, samples were collected as first-draw. Depending on size of the school(s) and number of drinking water fixtures, multiple dates for collecting samples may have been necessary to meet sampling and testing protocols.

[RCW 28A.210.410](#) does not require remediation for fixtures testing at 5 ppb and under. DOH offers post-remediation testing only for outlets that initially tested above 5 ppb. After a school completes remediation, DOH will provide up to two post-remediation sampling visits. If after the second post-remediation sampling, outlets test above 5 ppb, the district will be responsible for finding a contractor to conduct additional sampling and testing. For questions regarding sampling, testing, and results, please email: leadfreekids@doh.wa.gov.

DEFINITIONS

Fixture Housing
Location

Room/space where
fixture is located
(i.e. room number,
gym, playground)

Fixture Housing Type

Structure that contains
the individual fixtures
where water samples
were collected from.
Fixture housing may
contain one or more
individual fixture for
sampling.

Fixture Location
Details

Location within a
room or space where
fixture housing is
located, starting to the
left of the entrance and
rotating clockwise, of
the total number of
fixture housings in a
room or space
(e.g. 1/5, 2/5)

Fixture Type

Tap, Sprayer, Water
Fountain, Water Bottle
Filler, Ice maker

Fixture Position

Left, Center, Right

Date(s) collected: 2026-02-05

Date(s) analyzed: 2026-02-21

	Sample ID	Sample Collected Date	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
1	397584	2026-02-05	Main Building	Fountain Tap Combo	Rm212	1 of 1	Tap	left	3
2	397598	2026-02-05	Main Building	Fountain Tap Combo	Rm217	1 of 1	Water Fountain	right	2
3	397089	2026-02-05	Main Building	Fountain Tap Combo	Rm137	1 of 1	Tap	left	1
4	397093	2026-02-05	Main Building	Fountain Tap Combo	Rm201	1 of 1	Tap	left	1
5	397579	2026-02-05	Main Building	Fountain Tap Combo	Rm138	1 of 1	Tap	left	1
6	397596	2026-02-05	Main Building	Fountain Tap Combo	Rm220	1 of 1	Water Fountain	right	1
7	397073	2026-02-05	Main Building	Sink	Kitchen	1 of 1	Tap	center	<1
8	397074	2026-02-05	Main Building	Sink	Cafeteria	1 of 2	Tap	center	<1
9	397075	2026-02-05	Main Building	Fountain - Multi-level with Bottle Filler	Cafeteria	2 of 2	Water Fountain	left	<1
10	397076	2026-02-05	Main Building	Fountain - Multi-level with Bottle Filler	Cafeteria	2 of 2	Water Fountain	right	<1

	Sample ID	Sample Collected Date	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
11	397077	2026-02-05	Main Building	Fountain - Multi-level with Bottle Filler	Cafeteria	2 of 2	Water Bottle Filler	right	<1
12	397078	2026-02-05	New Gym and Covered Play Building	Fountain - Multi-level with Bottle Filler	Outside Gym	1 of 1	Water Fountain	left	<1
13	397079	2026-02-05	New Gym and Covered Play Building	Fountain - Multi-level with Bottle Filler	Outside Gym	1 of 1	Water Fountain	right	<1
14	397080	2026-02-05	Main Building	Fountain Tap Combo	Rm138	1 of 1	Water Fountain	right	<1
15	397081	2026-02-05	Main Building	Fountain Tap Combo	Rm149	1 of 1	Tap	left	<1
16	397082	2026-02-05	Main Building	Fountain Tap Combo	Rm149	1 of 1	Water Fountain	right	<1
17	397083	2026-02-05	Main Building	Fountain Tap Combo	Rm148	1 of 1	Tap	left	<1
18	397084	2026-02-05	Main Building	Fountain Tap Combo	Rm148	1 of 1	Water Fountain	right	<1
19	397085	2026-02-05	Main Building	Fountain Tap Combo	Rm146	1 of 1	Tap	left	<1
20	397086	2026-02-05	Main Building	Fountain Tap Combo	Rm146	1 of 1	Water Fountain	right	<1

	Sample ID	Sample Collected Date	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
21	397087	2026-02-05	Main Building	Fountain Tap Combo	Rm139	1 of 1	Tap	left	<1
22	397088	2026-02-05	Main Building	Fountain Tap Combo	Rm139	1 of 1	Water Fountain	right	<1
23	397090	2026-02-05	Main Building	Fountain Tap Combo	Rm137	1 of 1	Water Fountain	right	<1
24	397091	2026-02-05	Main Building	Fountain Tap Combo	Rm135	1 of 1	Tap	left	<1
25	397092	2026-02-05	Main Building	Fountain Tap Combo	Rm135	1 of 1	Water Fountain	right	<1
26	397094	2026-02-05	Main Building	Fountain Tap Combo	Rm201	1 of 1	Water Fountain	right	<1
27	397095	2026-02-05	Main Building	Fountain Tap Combo	Rm202	1 of 1	Tap	left	<1
28	397096	2026-02-05	Main Building	Fountain Tap Combo	Rm202	1 of 1	Water Fountain	right	<1
29	397097	2026-02-05	Main Building	Fountain Tap Combo	Rm205	1 of 1	Tap	left	<1
30	397098	2026-02-05	Main Building	Fountain Tap Combo	Rm205	1 of 1	Water Fountain	right	<1
31	397099	2026-02-05	Main Building	Fountain Tap Combo	Rm206	1 of 1	Tap	left	<1

	Sample ID	Sample Collected Date	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
32	397100	2026-02-05	Main Building	Fountain Tap Combo	Rm219	1 of 1	Water Fountain	right	<1
33	397101	2026-02-05	Main Building	Fountain Tap Combo	Rm223	1 of 1	Tap	left	<1
34	397102	2026-02-05	Main Building	Fountain Tap Combo	Rm223	1 of 1	Water Fountain	right	<1
35	397103	2026-02-05	Main Building	Fountain Tap Combo	Rm224	1 of 1	Tap	left	<1
36	397104	2026-02-05	Main Building	Fountain Tap Combo	Rm224	1 of 1	Water Fountain	right	<1
37	397105	2026-02-05	Main Building	Fountain Tap Combo	Rm226	1 of 1	Tap	left	<1
38	397106	2026-02-05	Main Building	Fountain Tap Combo	Rm226	1 of 1	Water Fountain	right	<1
39	397107	2026-02-05	Main Building	Fountain Tap Combo	Rm227	1 of 1	Tap	left	<1
40	397108	2026-02-05	Main Building	Fountain Tap Combo	Rm227	1 of 1	Water Fountain	right	<1
41	397560	2026-02-05	New Gym and Covered Play Building	Fountain - Multi-level with Bottle Filler	Outside Gym	1 of 1	Water Bottle Filler	right	<1
42	397561	2026-02-05	Main Building	Fountain Tap Combo	Rm119	1 of 1	Tap	center	<1

	Sample ID	Sample Collected Date	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
43	397562	2026-02-05	Main Building	Fountain Tap Combo	Rm119	1 of 1	Water Fountain	right	<1
44	397563	2026-02-05	Main Building	Sink	Rm109	1 of 1	Tap	center	<1
45	397564	2026-02-05	Main Building	Sink	Rm102	1 of 1	Tap	center	<1
46	397565	2026-02-05	Main Building	Fountain Tap Combo	Rm121	1 of 1	Tap	right	<1
47	397566	2026-02-05	Main Building	Fountain Tap Combo	Rm121	1 of 1	Water Fountain	right	<1
48	397567	2026-02-05	Main Building	Sink	Rm128	1 of 1	Tap	center	<1
49	397568	2026-02-05	Main Building	Fountain - Multi-level with Bottle Filler	Right Of Rm128	1 of 1	Water Fountain	left	<1
50	397569	2026-02-05	Main Building	Fountain - Multi-level with Bottle Filler	Right Of Rm128	1 of 1	Water Fountain	right	<1
51	397570	2026-02-05	Main Building	Fountain - Multi-level with Bottle Filler	Right Of Rm128	1 of 1	Water Bottle Filler	right	<1
52	397571	2026-02-05	Main Building	Fountain Tap Combo	Rm131	1 of 1	Tap	right	<1
53	397572	2026-02-05	Main Building	Fountain Tap Combo	Rm131	1 of 1	Water Fountain	left	<1

	Sample ID	Sample Collected Date	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
54	397573	2026-02-05	Main Building	Sink - Multi-compartment	Rm133	1 of 1	Tap	center	<1
55	397574	2026-02-05	Main Building	Fountain Tap Combo	Rm136	1 of 1	Tap	left	<1
56	397575	2026-02-05	Main Building	Fountain Tap Combo	Rm136	1 of 1	Water Fountain	right	<1
57	397576	2026-02-05	Main Building	Fountain - Multi-level with Bottle Filler	Across Rm138	1 of 1	Water Fountain	left	<1
58	397577	2026-02-05	Main Building	Fountain - Multi-level with Bottle Filler	Across Rm138	1 of 1	Water Fountain	right	<1
59	397578	2026-02-05	Main Building	Fountain - Multi-level with Bottle Filler	Across Rm138	1 of 1	Water Bottle Filler	right	<1
60	397580	2026-02-05	Main Building	Fountain Tap Combo	Rm206	1 of 1	Water Fountain	right	<1
61	397581	2026-02-05	Main Building	Fountain - Multi-level with Bottle Filler	Across Rm206	1 of 1	Tap	left	<1
62	397582	2026-02-05	Main Building	Fountain - Multi-level with Bottle Filler	Across Rm206	1 of 1	Water Fountain	right	<1

	Sample ID	Sample Collected Date	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
63	397583	2026-02-05	Main Building	Fountain - Multi-level with Bottle Filler	Across Rm206	1 of 1	Water Bottle Filler	right	<1
64	397585	2026-02-05	Main Building	Fountain Tap Combo	Rm212	1 of 1	Water Fountain	right	<1
65	397586	2026-02-05	Main Building	Fountain Tap Combo	Rm211	1 of 1	Tap	left	<1
66	397587	2026-02-05	Main Building	Fountain Tap Combo	Rm211	1 of 1	Water Fountain	right	<1
67	397588	2026-02-05	Main Building	Sink	Rm214	1 of 1	Tap	center	<1
68	397589	2026-02-05	Main Building	Fountain Tap Combo	Rm216	1 of 1	Tap	right	<1
69	397590	2026-02-05	Main Building	Fountain Tap Combo	Rm216	1 of 1	Water Fountain	left	<1
70	397591	2026-02-05	Main Building	Fountain Tap Combo	Rm218	1 of 1	Tap	left	<1
71	397592	2026-02-05	Main Building	Fountain Tap Combo	Rm218	1 of 1	Water Fountain	right	<1
72	397593	2026-02-05	Main Building	Fountain Tap Combo	Rm215	1 of 1	Tap	left	<1
73	397594	2026-02-05	Main Building	Fountain Tap Combo	Rm215	1 of 1	Water Fountain	right	<1

	Sample ID	Sample Collected Date	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
74	397595	2026-02-05	Main Building	Fountain Tap Combo	Rm220	1 of 1	Tap	left	<1
75	397597	2026-02-05	Main Building	Fountain Tap Combo	Rm217	1 of 1	Tap	left	<1
76	397599	2026-02-05	Main Building	Fountain Tap Combo	Rm219	1 of 1	Tap	left	<1
