

# Lead in School Drinking Water Report

## Loyal Heights Elementary School



### EXPLANATION OF TESTING AND RESULTS

Results in this report represent sampling conducted by Washington State Department of Health (DOH). Per [RCW 28A.210.410](#) sampling and testing protocols, samples were collected as first-draw. Depending on size of the school(s) and number of drinking water fixtures, multiple dates for collecting samples may have been necessary to meet sampling and testing protocols.

[RCW 28A.210.410](#) does not require remediation for fixtures testing at 5 ppb and under. DOH offers post-remediation testing only for outlets that initially tested above 5 ppb. After a school completes remediation, DOH will provide up to two post-remediation sampling visits. If after the second post-remediation sampling, outlets test above 5 ppb, the district will be responsible for finding a contractor to conduct additional sampling and testing. For questions regarding sampling, testing, and results, please email: [leadfreekids@doh.wa.gov](mailto:leadfreekids@doh.wa.gov).

## DEFINITIONS

Fixture Housing  
Location

Room/space where  
fixture is located  
(i.e. room number,  
gym, playground)

Fixture Housing Type

Structure that contains  
the individual fixtures  
where water samples  
were collected from.  
Fixture housing may  
contain one or more  
individual fixture for  
sampling.

Fixture Location  
Details

Location within a  
room or space where  
fixture housing is  
located, starting to the  
left of the entrance and  
rotating clockwise, of  
the total number of  
fixture housings in a  
room or space  
(e.g. 1/5, 2/5)

Fixture Type

Tap, Sprayer, Water  
Fountain, Water Bottle  
Filler, Ice maker

Fixture Position

Left, Center, Right

Date(s) collected: 2026-02-12

Date(s) analyzed: 2026-02-23

	Sample ID	Sample Collected Date	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
1	397160	2026-02-12	Main Building with 2018 Addition	Fountain Tap Combo	Rm122	1 of 1	Water Fountain	right	<1
2	397161	2026-02-12	Main Building with 2018 Addition	Fountain	Right Of Rm122	1 of 1	Water Fountain	center	<1
3	397162	2026-02-12	Main Building with 2018 Addition	Fountain Tap Combo	Rm121	1 of 1	Tap	left	<1
4	397163	2026-02-12	Main Building with 2018 Addition	Fountain Tap Combo	Rm121	1 of 1	Water Fountain	right	<1
5	397164	2026-02-12	Main Building with 2018 Addition	Fountain Tap Combo	Rm123	1 of 1	Tap	left	<1
6	397165	2026-02-12	Main Building with 2018 Addition	Fountain Tap Combo	Rm123	1 of 1	Water Fountain	right	<1
7	397166	2026-02-12	Main Building with 2018 Addition	Fountain Tap Combo	Rm118	1 of 1	Tap	left	<1

	Sample ID	Sample Collected Date	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
8	397167	2026-02-12	Main Building with 2018 Addition	Fountain Tap Combo	Rm118	1 of 1	Water Fountain	right	<1
9	397168	2026-02-12	Main Building with 2018 Addition	Sink	Library	1 of 1	Tap	center	<1
10	397169	2026-02-12	Main Building with 2018 Addition	Fountain Tap Combo	Rm110	1 of 1	Tap	left	<1
11	397170	2026-02-12	Main Building with 2018 Addition	Fountain Tap Combo	Rm110	1 of 1	Water Fountain	right	<1
12	397171	2026-02-12	Main Building with 2018 Addition	Fountain Tap Combo	Rm109	1 of 1	Tap	left	<1
13	397172	2026-02-12	Main Building with 2018 Addition	Fountain Tap Combo	Rm109	1 of 1	Water Fountain	right	<1
14	397173	2026-02-12	Main Building with 2018 Addition	Fountain - Multi-level with Bottle Filler	Left Of Rm105	1 of 1	Water Fountain	left	<1
15	397174	2026-02-12	Main Building with 2018 Addition	Fountain - Multi-level with Bottle Filler	Left Of Rm105	1 of 1	Water Fountain	right	<1

	Sample ID	Sample Collected Date	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
16	397175	2026-02-12	Main Building with 2018 Addition	Fountain - Multi-level with Bottle Filler	Left Of Rm105	2 of 1	Water Bottle Filler	right	<1
17	397176	2026-02-12	Main Building with 2018 Addition	Sink	Rm105	1 of 1	Tap	center	<1
18	397177	2026-02-12	Main Building with 2018 Addition	Fountain Tap Combo	Rm102	1 of 1	Tap	right	<1
19	397178	2026-02-12	Main Building with 2018 Addition	Fountain Tap Combo	Rm102	1 of 1	Water Fountain	left	<1
20	397179	2026-02-12	Main Building with 2018 Addition	Sink	Rm101a	1 of 1	Tap	center	<1
21	397180	2026-02-12	Main Building with 2018 Addition	Fountain Tap Combo	Rm211	1 of 1	Water Fountain	right	<1
22	397181	2026-02-12	Main Building with 2018 Addition	Fountain Tap Combo	Rm213	1 of 1	Tap	left	<1
23	397182	2026-02-12	Main Building with 2018 Addition	Fountain Tap Combo	Rm213	1 of 1	Water Fountain	right	<1

	Sample ID	Sample Collected Date	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
24	397183	2026-02-12	Main Building with 2018 Addition	Fountain Tap Combo	Rm212	1 of 1	Tap	left	<1
25	397184	2026-02-12	Main Building with 2018 Addition	Fountain Tap Combo	Rm212	1 of 1	Water Fountain	right	<1
26	397185	2026-02-12	Main Building with 2018 Addition	Fountain Tap Combo	Rm215	1 of 1	Tap	left	<1
27	397186	2026-02-12	Main Building with 2018 Addition	Fountain Tap Combo	Rm215	1 of 1	Water Fountain	right	<1
28	397187	2026-02-12	Main Building with 2018 Addition	Fountain Tap Combo	Rm216	1 of 1	Tap	left	<1
29	397188	2026-02-12	Main Building with 2018 Addition	Fountain Tap Combo	Rm216	1 of 1	Water Fountain	right	<1
30	397189	2026-02-12	Main Building with 2018 Addition	Fountain Tap Combo	Rm218	1 of 1	Tap	left	<1
31	397190	2026-02-12	Main Building with 2018 Addition	Fountain Tap Combo	Rm218	1 of 1	Water Fountain	right	<1

	Sample ID	Sample Collected Date	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
32	397191	2026-02-12	Main Building with 2018 Addition	Fountain Tap Combo	Rm219	1 of 1	Tap	left	<1
33	397192	2026-02-12	Main Building with 2018 Addition	Fountain Tap Combo	Rm219	1 of 1	Water Fountain	right	<1
34	397193	2026-02-12	Main Building with 2018 Addition	Sink	Rm220	1 of 1	Tap	center	<1
35	397194	2026-02-12	Main Building with 2018 Addition	Fountain Tap Combo	Rm221	1 of 1	Tap	left	<1
36	397195	2026-02-12	Main Building with 2018 Addition	Fountain Tap Combo	Rm221	1 of 1	Water Fountain	right	<1
37	397196	2026-02-12	Main Building with 2018 Addition	Fountain - Multi-level with Bottle Filler	Across Rm221	1 of 1	Water Fountain	right	<1
38	397197	2026-02-12	Main Building with 2018 Addition	Fountain - Multi-level with Bottle Filler	Across Rm221	1 of 1	Water Bottle Filler	right	<1
39	397198	2026-02-12	Main Building with 2018 Addition	Fountain - Multi-level with Bottle Filler	Across Rm221	1 of 1	Water Fountain	left	<1

	Sample ID	Sample Collected Date	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
40	397199	2026-02-12	Main Building with 2018 Addition	Fountain Tap Combo	Rm225	1 of 1	Tap	left	<1
41	397648	2026-02-12	Main Building with 2018 Addition	Sink - Multi-compartment	Kitchen	1 of 1	Tap	center	<1
42	397649	2026-02-12	Main Building with 2018 Addition	Sink - Multi-compartment	Kitchen	1 of 1	Sprayer	center	<1
43	397650	2026-02-12	Main Building with 2018 Addition	Fountain - Multi-level with Bottle Filler	Cafeteria	1 of 1	Water Fountain	left	<1
44	397651	2026-02-12	Main Building with 2018 Addition	Fountain - Multi-level with Bottle Filler	Cafeteria	1 of 1	Water Fountain	right	<1
45	397652	2026-02-12	Main Building with 2018 Addition	Fountain - Multi-level with Bottle Filler	Cafeteria	1 of 1	Water Bottle Filler	right	<1
46	397653	2026-02-12	Main Building with 2018 Addition	Fountain Tap Combo	Rm004	1 of 1	Tap	center	<1
47	397654	2026-02-12	Main Building with 2018 Addition	Fountain Tap Combo	Rm004	1 of 1	Water Fountain	right	<1

	Sample ID	Sample Collected Date	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
48	397655	2026-02-12	Main Building with 2018 Addition	Fountain Tap Combo	Rm005	1 of 1	Tap	left	<1
49	397656	2026-02-12	Main Building with 2018 Addition	Fountain Tap Combo	Rm005	1 of 1	Water Fountain	right	<1
50	397657	2026-02-12	Main Building with 2018 Addition	Fountain Tap Combo	Rm124	1 of 1	Tap	left	<1
51	397658	2026-02-12	Main Building with 2018 Addition	Fountain Tap Combo	Rm124	1 of 1	Water Fountain	right	<1
52	397659	2026-02-12	Main Building with 2018 Addition	Fountain Tap Combo	Rm122	1 of 1	Tap	left	<1
53	397660	2026-02-12	Main Building with 2018 Addition	Fountain Tap Combo	Rm101	1 of 1	Tap	left	<1
54	397661	2026-02-12	Main Building with 2018 Addition	Fountain Tap Combo	Rm101	1 of 1	Water Fountain	right	<1
55	397662	2026-02-12	Main Building with 2018 Addition	Sink	Rm100a	1 of 1	Tap	center	<1

	Sample ID	Sample Collected Date	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
56	397663	2026-02-12	Main Building with 2018 Addition	Fountain - Multi-level	Right Of Rm284	1 of 1	Water Fountain	left	<1
57	397664	2026-02-12	Main Building with 2018 Addition	Fountain - Multi-level	Right Of Rm284	1 of 1	Water Fountain	right	<1
58	397665	2026-02-12	Main Building with 2018 Addition	Fountain Tap Combo	Rm201	1 of 1	Tap	left	<1
59	397666	2026-02-12	Main Building with 2018 Addition	Fountain Tap Combo	Rm201	1 of 1	Water Fountain	right	<1
60	397667	2026-02-12	Main Building with 2018 Addition	Fountain Tap Combo	Rm202	1 of 1	Tap	left	<1
61	397668	2026-02-12	Main Building with 2018 Addition	Fountain Tap Combo	Rm202	1 of 1	Water Fountain	right	<1
62	397669	2026-02-12	Main Building with 2018 Addition	Fountain Tap Combo	Rm204	1 of 1	Tap	left	<1
63	397670	2026-02-12	Main Building with 2018 Addition	Fountain Tap Combo	Rm204	1 of 1	Water Fountain	right	<1

	Sample ID	Sample Collected Date	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
64	397671	2026-02-12	Main Building with 2018 Addition	Fountain Tap Combo	Rm205	1 of 1	Tap	left	<1
65	397672	2026-02-12	Main Building with 2018 Addition	Fountain Tap Combo	Rm205	1 of 1	Water Fountain	right	<1
66	397673	2026-02-12	Main Building with 2018 Addition	Fountain Tap Combo	Rm207	1 of 1	Tap	left	<1
67	397674	2026-02-12	Main Building with 2018 Addition	Fountain Tap Combo	Rm207	1 of 1	Water Fountain	right	<1
68	397675	2026-02-12	Main Building with 2018 Addition	Fountain Tap Combo	Rm206	1 of 1	Tap	left	<1
69	397676	2026-02-12	Main Building with 2018 Addition	Fountain Tap Combo	Rm206	1 of 1	Water Fountain	right	<1
70	397677	2026-02-12	Main Building with 2018 Addition	Fountain Tap Combo	Rm208	1 of 1	Tap	left	<1
71	397678	2026-02-12	Main Building with 2018 Addition	Fountain Tap Combo	Rm208	1 of 1	Water Fountain	right	<1

	Sample ID	Sample Collected Date	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
72	397679	2026-02-12	Main Building with 2018 Addition	Fountain Tap Combo	Rm211	1 of 1	Tap	left	<1
73	397680	2026-02-12	Main Building with 2018 Addition	Fountain Tap Combo	Rm225	1 of 1	Water Fountain	right	<1
74	397681	2026-02-12	Main Building with 2018 Addition	Fountain Tap Combo	Rm224	1 of 1	Tap	left	<1
75	397682	2026-02-12	Main Building with 2018 Addition	Fountain Tap Combo	Rm224	1 of 1	Water Fountain	right	<1
76	397683	2026-02-12	Main Building with 2018 Addition	Fountain Tap Combo	Rm226	1 of 1	Tap	left	<1
77	397684	2026-02-12	Main Building with 2018 Addition	Fountain Tap Combo	Rm226	1 of 1	Water Fountain	right	<1
78	397685	2026-02-12	Main Building with 2018 Addition	Fountain Tap Combo	Rm229	1 of 1	Tap	left	<1
79	397686	2026-02-12	Main Building with 2018 Addition	Fountain Tap Combo	Rm229	1 of 1	Water Fountain	right	<1

---

	Sample ID	Sample Collected Date	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
80	397687	2026-02-12	Main Building with 2018 Addition	Fountain Tap Combo	Rm228	1 of 1	Tap	left	<1
81	397688	2026-02-12	Main Building with 2018 Addition	Fountain Tap Combo	Rm228	1 of 1	Water Fountain	right	<1
82	397689	2026-02-12	Main Building with 2018 Addition	Fountain Tap Combo	Rm230	1 of 1	Tap	left	<1
83	397690	2026-02-12	Main Building with 2018 Addition	Fountain Tap Combo	Rm230	1 of 1	Water Fountain	right	<1
84	397691	2026-02-12	Main Building with 2018 Addition	Fountain Tap Combo	Rm232	1 of 1	Tap	left	<1
85	397692	2026-02-12	Main Building with 2018 Addition	Fountain Tap Combo	Rm232	1 of 1	Water Fountain	right	<1
86	397693	2026-02-12	Main Building with 2018 Addition	Fountain Tap Combo	Rm233	1 of 1	Water Fountain	right	<1
87	397694	2026-02-12	Main Building with 2018 Addition	Fountain Tap Combo	Rm233	1 of 1	Tap	left	<1

---