

Lead in School Drinking Water Report

West Seattle Elementary School



EXPLANATION OF TESTING AND RESULTS

Results in this report represent sampling conducted by Washington State Department of Health (DOH). Per [RCW 28A.210.410](#) sampling and testing protocols, samples were collected as first-draw. Depending on size of the school(s) and number of drinking water fixtures, multiple dates for collecting samples may have been necessary to meet sampling and testing protocols.

[RCW 28A.210.410](#) does not require remediation for fixtures testing at 5 ppb and under. DOH offers post-remediation testing only for outlets that initially tested above 5 ppb. After a school completes remediation, DOH will provide up to two post-remediation sampling visits. If after the second post-remediation sampling, outlets test above 5 ppb, the district will be responsible for finding a contractor to conduct additional sampling and testing. For questions regarding sampling, testing, and results, please email: leadfreekids@doh.wa.gov.

DEFINITIONS

Fixture Housing
Location

Room/space where
fixture is located
(i.e. room number,
gym, playground)

Fixture Housing Type

Structure that contains
the individual fixtures
where water samples
were collected from.
Fixture housing may
contain one or more
individual fixture for
sampling.

Fixture Location
Details

Location within a
room or space where
fixture housing is
located, starting to the
left of the entrance and
rotating clockwise, of
the total number of
fixture housings in a
room or space
(e.g. 1/5, 2/5)

Fixture Type

Tap, Sprayer, Water
Fountain, Water Bottle
Filler, Ice maker

Fixture Position

Left, Center, Right

Date(s) collected: 2026-03-26

Date(s) analyzed: 2026-04-03, 2026-04-06

	Sample ID	Sample Collected Date	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
1	406655	2026-03-26	Main Building	Sink	Rm114g	2 of 2 across from fridge	Tap	center	18
2	406646	2026-03-26	Main Building	Sink - Multi-compartment	Kitchen	2 of 2 left of ovens	Tap	left	9
3	406652	2026-03-26	Main Building	Sink - Multi-compartment	Rm114m	1 of 1	Tap	right	5
4	406644	2026-03-26	Main Building	Sink	Kitchen	1 of 2 right of ovens	Tap	center	4
5	406810	2026-03-26	Main Building	Fountain Tap Combo	Rm203	1 of 1	Water Fountain	right	4
6	406648	2026-03-26	Main Building	Sink - Multi-compartment	Kitchen	2 of 2 left of ovens	Tap	right	3
7	406651	2026-03-26	Main Building	Sink - Multi-compartment	Rm114m	1 of 1	Tap	left	3
8	406804	2026-03-26	Main Building	Fountain Tap Combo	Rm208	1 of 1	Tap	left	3

	Sample ID	Sample Collected Date	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
9	406809	2026-03-26	Main Building	Fountain Tap Combo	Rm203	1 of 1	Tap	left	3
10	406645	2026-03-26	Main Building	Sink	Kitchen	1 of 2 right of ovens	Sprayer	center	2
11	406654	2026-03-26	Main Building	Sink	Rm114g	1 of 2 right of stove	Tap	center	2
12	406658	2026-03-26	Main Building	Fountain Tap Combo	Rm109	1 of 1	Tap	center	2
13	406717	2026-03-26	Main Building	Fountain Tap Combo	Rm124	1 of 1	Water Fountain	right	2
14	406790	2026-03-26	Main Building	Fountain Tap Combo	Rm225	1 of 1	Tap	left	2
15	406791	2026-03-26	Main Building	Fountain Tap Combo	Rm225	1 of 1	Water Fountain	right	2
16	406796	2026-03-26	Main Building	Fountain Tap Combo	Rm221	1 of 1	Tap	left	2
17	406647	2026-03-26	Main Building	Sink - Multi-compartment	Kitchen	2 of 2 left of ovens	Sprayer	left	1
18	406714	2026-03-26	Main Building	Fountain Tap Combo	Rm123	1 of 1	Tap	center	1

	Sample ID	Sample Collected Date	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
19	406716	2026-03-26	Main Building	Fountain Tap Combo	Rm124	1 of 1	Tap	center	1
20	406812	2026-03-26	Main Building	Fountain Tap Combo	Rm202	1 of 1	Water Fountain	right	1
21	406649	2026-03-26	Main Building	Fountain - Multi-level with Bottle Filler	Cafeteria	1 of 1 bottle filler off	Water Fountain	left	<1
22	406650	2026-03-26	Main Building	Fountain - Multi-level with Bottle Filler	Cafeteria	1 of 1 bottle filler off	Water Fountain	right	<1
23	406653	2026-03-26	Main Building	Sink	Rm114a	1 of 1	Tap	center	<1
24	406656	2026-03-26	Main Building	Fountain	Between Cafeteria Bathrooms	1 of 1	Water Fountain	center	<1
25	406657	2026-03-26	Main Building	Sink	Rm110	1 of 1	Tap	center	<1
26	406659	2026-03-26	Main Building	Fountain Tap Combo	Rm109	1 of 1	Water Fountain	right	<1
27	406700	2026-03-26	Main Building	Sink	Staff Lounge	1 of 1	Tap	center	<1
28	406701	2026-03-26	Main Building	Sink	Rm107c	1 of 1	Tap	center	<1
29	406702	2026-03-26	Main Building	Sink	Rm107f	1 of 1	Tap	center	<1
30	406703	2026-03-26	Main Building	Sink	Rm105	1 of 1	Tap	center	<1

	Sample ID	Sample Collected Date	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
31	406704	2026-03-26	Main Building	Fountain - Multi-level with Bottle Filler	Across Rm107e	1 of 1	Water Fountain	left	<1
32	406705	2026-03-26	Main Building	Fountain - Multi-level with Bottle Filler	Across Rm107e	1 of 1	Water Bottle Filler	left	<1
33	406706	2026-03-26	Main Building	Fountain - Multi-level with Bottle Filler	Across Rm107e	1 of 1	Water Fountain	right	<1
34	406707	2026-03-26	Main Building	Sink	Right Of Rm107r	1 of 1	Tap	center	<1
35	406708	2026-03-26	Main Building	Fountain Tap Combo	Rm120	1 of 1	Tap	center	<1
36	406709	2026-03-26	Main Building	Fountain Tap Combo	Rm120	1 of 1	Water Fountain	right	<1
37	406710	2026-03-26	Main Building	Fountain Tap Combo	Rm121	1 of 1	Tap	center	<1
38	406711	2026-03-26	Main Building	Fountain Tap Combo	Rm121	1 of 1	Water Fountain	right	<1
39	406712	2026-03-26	Main Building	Fountain Tap Combo	Rm125	1 of 1	Tap	right	<1
40	406713	2026-03-26	Main Building	Fountain Tap Combo	Rm125	1 of 1	Water Fountain	left	<1

	Sample ID	Sample Collected Date	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
41	406715	2026-03-26	Main Building	Fountain Tap Combo	Rm123	1 of 1	Water Fountain	right	<1
42	406718	2026-03-26	Main Building	Fountain Tap Combo	Rm125a	1 of 1	Tap	left	<1
43	406719	2026-03-26	Main Building	Fountain Tap Combo	Rm125a	1 of 1	Water Fountain	right	<1
44	406720	2026-03-26	Main Building	Fountain Tap Combo	Rm126	1 of 1	Tap	right	<1
45	406721	2026-03-26	Main Building	Fountain Tap Combo	Rm126	1 of 1	Water Fountain	left	<1
46	406722	2026-03-26	Main Building	Fountain Tap Combo	Rm127	1 of 1	Tap	right	<1
47	406723	2026-03-26	Main Building	Fountain Tap Combo	Rm127	1 of 1	Water Fountain	left	<1
48	406724	2026-03-26	Main Building	Fountain Tap Combo	Rm128	1 of 1	Tap	right	<1
49	406725	2026-03-26	Main Building	Fountain Tap Combo	Rm128	1 of 1	Water Fountain	left	<1
50	406726	2026-03-26	Main Building	Fountain Tap Combo	Rm129	1 of 1	Tap	right	<1
51	406727	2026-03-26	Main Building	Fountain Tap Combo	Rm129	1 of 1	Water Fountain	left	<1

	Sample ID	Sample Collected Date	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
52	406728	2026-03-26	Main Building	Fountain Tap Combo	Rm240	1 of 1	Tap	left	<1
53	406729	2026-03-26	Main Building	Fountain Tap Combo	Rm240	1 of 1	Water Fountain	right	<1
54	406730	2026-03-26	Main Building	Fountain Tap Combo	Rm241	1 of 1	Tap	left	<1
55	406731	2026-03-26	Main Building	Fountain Tap Combo	Rm241	1 of 1	Water Fountain	right	<1
56	406732	2026-03-26	Main Building	Fountain Tap Combo	Rm239	1 of 1	Tap	left	<1
57	406733	2026-03-26	Main Building	Fountain Tap Combo	Rm239	1 of 1	Water Fountain	right	<1
58	406734	2026-03-26	Main Building	Fountain Tap Combo	Rm238	1 of 1	Tap	left	<1
59	406735	2026-03-26	Main Building	Fountain Tap Combo	Rm238	1 of 1	Water Fountain	right	<1
60	406736	2026-03-26	Main Building	Fountain Tap Combo	Rm237	1 of 1	Tap	left	<1
61	406737	2026-03-26	Main Building	Fountain Tap Combo	Rm237	1 of 1	Water Fountain	right	<1
62	406738	2026-03-26	Main Building	Fountain Tap Combo	Rm236	1 of 1	Tap	right	<1

	Sample ID	Sample Collected Date	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
63	406739	2026-03-26	Main Building	Fountain Tap Combo	Rm236	1 of 1	Water Fountain	left	<1
64	406780	2026-03-26	Main Building	Fountain Tap Combo	Rm235	1 of 1	Tap	right	<1
65	406781	2026-03-26	Main Building	Fountain Tap Combo	Rm235	1 of 1	Water Fountain	left	<1
66	406782	2026-03-26	Main Building	Fountain Tap Combo	Rm234	1 of 1	Tap	right	<1
67	406783	2026-03-26	Main Building	Fountain Tap Combo	Rm234	1 of 1	Water Fountain	left	<1
68	406784	2026-03-26	Main Building	Fountain - Multi-level with Bottle Filler	Right Of Rm230	1 of 1	Water Fountain	left	<1
69	406785	2026-03-26	Main Building	Fountain - Multi-level with Bottle Filler	Right Of Rm230	1 of 1	Water Bottle Filler	left	<1
70	406786	2026-03-26	Main Building	Fountain - Multi-level with Bottle Filler	Right Of Rm230	1 of 1	Water Fountain	right	<1
71	406787	2026-03-26	Main Building	Sink	Rm229	1 of 1	Tap	center	<1
72	406788	2026-03-26	Main Building	Fountain Tap Combo	Rm227	1 of 1	Tap	right	<1

	Sample ID	Sample Collected Date	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
73	406789	2026-03-26	Main Building	Fountain Tap Combo	Rm227	1 of 1	Water Fountain	left	<1
74	406792	2026-03-26	Main Building	Sink - Multi-compartment	Rm226	1 of 2	Tap	left	<1
75	406793	2026-03-26	Main Building	Sink - Multi-compartment	Rm226	1 of 2	Tap	right	<1
76	406794	2026-03-26	Main Building	Fountain Tap Combo	Rm226	2 of 2	Tap	left	<1
77	406795	2026-03-26	Main Building	Fountain Tap Combo	Rm226	2 of 2	Water Fountain	right	<1
78	406797	2026-03-26	Main Building	Fountain Tap Combo	Rm221	1 of 1	Water Fountain	right	<1
79	406798	2026-03-26	Main Building	Fountain Tap Combo	Rm220	1 of 1	Tap	left	<1
80	406799	2026-03-26	Main Building	Fountain Tap Combo	Rm220	1 of 1	Water Fountain	right	<1
81	406800	2026-03-26	Main Building	Fountain Tap Combo	Rm219	1 of 1	Tap	left	<1
82	406801	2026-03-26	Main Building	Fountain Tap Combo	Rm219	1 of 1	Water Fountain	right	<1
83	406802	2026-03-26	Main Building	Fountain Tap Combo	Rm209	1 of 1	Tap	left	<1

	Sample ID	Sample Collected Date	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
84	406803	2026-03-26	Main Building	Fountain Tap Combo	Rm209	1 of 1	Water Fountain	right	<1
85	406805	2026-03-26	Main Building	Fountain Tap Combo	Rm208	1 of 1	Water Fountain	right	<1
86	406806	2026-03-26	Main Building	Fountain - Multi-level with Bottle Filler	Across Rm218	1 of 1	Water Fountain	left	<1
87	406807	2026-03-26	Main Building	Fountain - Multi-level with Bottle Filler	Across Rm218	1 of 1	Water Bottle Filler	left	<1
88	406808	2026-03-26	Main Building	Fountain - Multi-level with Bottle Filler	Across Rm218	1 of 1	Water Fountain	right	<1
89	406811	2026-03-26	Main Building	Fountain Tap Combo	Rm202	1 of 1	Tap	left	<1
