

# Lead in School Drinking Water Report

## Magnolia Elementary School



### EXPLANATION OF TESTING AND RESULTS

Results in this report represent sampling conducted by Washington State Department of Health (DOH). Per [RCW 28A.210.410](#) sampling and testing protocols, samples were collected as first-draw. Depending on size of the school(s) and number of drinking water fixtures, multiple dates for collecting samples may have been necessary to meet sampling and testing protocols.

[RCW 28A.210.410](#) does not require remediation for fixtures testing at 5 ppb and under. DOH offers post-remediation testing only for outlets that initially tested above 5 ppb. After a school completes remediation, DOH will provide up to two post-remediation sampling visits. If after the second post-remediation sampling, outlets test above 5 ppb, the district will be responsible for finding a contractor to conduct additional sampling and testing. For questions regarding sampling, testing, and results, please email: [leadfreekids@doh.wa.gov](mailto:leadfreekids@doh.wa.gov).

## DEFINITIONS

Fixture Housing  
Location

Room/space where  
fixture is located  
(i.e. room number,  
gym, playground)

Fixture Housing Type

Structure that contains  
the individual fixtures  
where water samples  
were collected from.  
Fixture housing may  
contain one or more  
individual fixture for  
sampling.

Fixture Location  
Details

Location within a  
room or space where  
fixture housing is  
located, starting to the  
left of the entrance and  
rotating clockwise, of  
the total number of  
fixture housings in a  
room or space  
(e.g. 1/5, 2/5)

Fixture Type

Tap, Sprayer, Water  
Fountain, Water Bottle  
Filler, Ice maker

Fixture Position

Left, Center, Right

Date(s) collected: 2026-03-27

Date(s) analyzed: 2026-04-03, 2026-04-07, 2026-04-08

	Sample ID	Sample Collected Date	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
1	406847	2026-03-27	Main Building	Fountain Tap Combo	Rm1132	1 of 1	Water Fountain	left	2
2	406830	2026-03-27	Main Building	Sink	Rm1118b	1 of 1	Tap	center	1
3	406856	2026-03-27	Main Building	Fountain Tap Combo	Rm2124	1 of 1	Water Fountain	left	1
4	406813	2026-03-27	Main Building	Sink	Kitchen	1 of 1	Tap	center	<1
5	406814	2026-03-27	Main Building	Fountain - Multi-level with Bottle Filler	Gym Bathrooms	1 of 1	Water Fountain	left	<1
6	406815	2026-03-27	Main Building	Fountain - Multi-level with Bottle Filler	Gym Bathrooms	1 of 1	Water Fountain	right	<1
7	406816	2026-03-27	Main Building	Fountain - Multi-level with Bottle Filler	Gym Bathrooms	1 of 1	Water Bottle Filler	right	<1
8	406817	2026-03-27	Main Building	Sink	Community Kitchen	1 of 1	Tap	center	<1
9	406818	2026-03-27	Main Building	Fountain Tap Combo	Rm1202	1 of 1	Tap	right	<1
10	406819	2026-03-27	Main Building	Fountain Tap Combo	Rm1202	1 of 1	Water Fountain	left	<1

	Sample ID	Sample Collected Date	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
11	406820	2026-03-27	Main Building	Fountain Tap Combo	Rm1102	1 of 1 fountain off	Tap	right	<1
12	406821	2026-03-27	Main Building	Fountain Tap Combo	Rm1104	1 of 1	Tap	right	<1
13	406822	2026-03-27	Main Building	Fountain Tap Combo	Rm1104	1 of 1	Water Fountain	left	<1
14	406823	2026-03-27	Main Building	Fountain Tap Combo	Rm1103	1 of 1	Tap	right	<1
15	406824	2026-03-27	Main Building	Fountain Tap Combo	Rm1103	1 of 1	Water Fountain	left	<1
16	406825	2026-03-27	Main Building	Fountain Tap Combo	Rm1106	1 of 1	Tap	right	<1
17	406826	2026-03-27	Main Building	Fountain Tap Combo	Rm1106	1 of 1	Water Fountain	left	<1
18	406827	2026-03-27	Main Building	Fountain - Multi-level with Bottle Filler	Across Rm1106	1 of 1	Water Fountain	left	<1
19	406828	2026-03-27	Main Building	Fountain - Multi-level with Bottle Filler	Across Rm1106	1 of 1	Water Fountain	right	<1
20	406829	2026-03-27	Main Building	Fountain - Multi-level with Bottle Filler	Across Rm1106	1 of 1	Water Bottle Filler	right	<1

	Sample ID	Sample Collected Date	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
21	406831	2026-03-27	Main Building	Sink	Rm1118c	1 of 1	Tap	center	<1
22	406832	2026-03-27	Main Building	Fountain - Multi-level with Bottle Filler	Across Rm1118a	1 of 1	Water Fountain	left	<1
23	406833	2026-03-27	Main Building	Fountain - Multi-level with Bottle Filler	Across Rm1118a	1 of 1	Water Fountain	right	<1
24	406834	2026-03-27	Main Building	Fountain - Multi-level with Bottle Filler	Across Rm1118a	1 of 1	Water Bottle Filler	right	<1
25	406835	2026-03-27	Main Building	Fountain Tap Combo	Rm1121	1 of 1	Tap	right	<1
26	406836	2026-03-27	Main Building	Fountain Tap Combo	Rm1121	1 of 1	Water Fountain	left	<1
27	406837	2026-03-27	Main Building	Fountain Tap Combo	Rm1120	1 of 1	Tap	right	<1
28	406838	2026-03-27	Main Building	Fountain Tap Combo	Rm1120	1 of 1	Water Fountain	left	<1
29	406839	2026-03-27	Main Building	Sink	Rm1125	1 of 1	Tap	center	<1
30	406840	2026-03-27	Main Building	Fountain Tap Combo	Rm1124	1 of 1 Fountain off	Tap	right	<1

	Sample ID	Sample Collected Date	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
31	406841	2026-03-27	Main Building	Fountain Tap Combo	Rm1126	1 of 1	Tap	right	<1
32	406842	2026-03-27	Main Building	Fountain Tap Combo	Rm1126	1 of 1	Water Fountain	left	<1
33	406843	2026-03-27	Main Building	Fountain Tap Combo	Rm1130	1 of 1 fountain off	Tap	right	<1
34	406844	2026-03-27	Main Building	Fountain Tap Combo	Rm1131	1 of 1	Tap	right	<1
35	406845	2026-03-27	Main Building	Fountain Tap Combo	Rm1131	1 of 1	Water Fountain	left	<1
36	406846	2026-03-27	Main Building	Fountain Tap Combo	Rm1132	1 of 1	Tap	right	<1
37	406848	2026-03-27	Main Building	Fountain Tap Combo	Rm1133	1 of 1	Tap	right	<1
38	406849	2026-03-27	Main Building	Fountain Tap Combo	Rm1133	1 of 1	Water Fountain	left	<1
39	406850	2026-03-27	Main Building	Fountain Tap Combo	Rm1134	1 of 1	Tap	right	<1
40	406851	2026-03-27	Main Building	Fountain Tap Combo	Rm1134	1 of 1	Water Fountain	left	<1
41	406852	2026-03-27	Main Building	Fountain Tap Combo	Rm1135	1 of 1	Tap	right	<1

	Sample ID	Sample Collected Date	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
42	406853	2026-03-27	Main Building	Fountain Tap Combo	Rm1135	1 of 1	Water Fountain	left	<1
43	406854	2026-03-27	Main Building	Sink	Library	1 of 1	Tap	center	<1
44	406855	2026-03-27	Main Building	Fountain Tap Combo	Rm2124	1 of 1	Tap	right	<1
45	406857	2026-03-27	Main Building	Fountain Tap Combo	Rm2126	1 of 1	Tap	left	<1
46	406858	2026-03-27	Main Building	Fountain Tap Combo	Rm2126	1 of 1	Water Fountain	right	<1
47	406859	2026-03-27	Main Building	Fountain Tap Combo	Rm2128	1 of 1	Tap	right	<1
48	418160	2026-03-27	Main Building	Fountain Tap Combo	Rm2128	1 of 1	Water Fountain	left	<1
49	418161	2026-03-27	Main Building	Fountain - Multi-level with Bottle Filler	Outside Library	1 of 1	Water Fountain	left	<1
50	418162	2026-03-27	Main Building	Fountain - Multi-level with Bottle Filler	Outside Library	1 of 1	Water Fountain	right	<1
51	418163	2026-03-27	Main Building	Fountain - Multi-level with Bottle Filler	Outside Library	1 of 1	Water Bottle Filler	right	<1

	Sample ID	Sample Collected Date	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
52	418164	2026-03-27	Main Building	Fountain Tap Combo	Rm2101	1 of 1	Tap	right	<1
53	418165	2026-03-27	Main Building	Fountain Tap Combo	Rm2101	1 of 1	Water Fountain	left	<1
54	418166	2026-03-27	Main Building	Fountain Tap Combo	Rm2102	1 of 1	Tap	right	<1
55	418167	2026-03-27	Main Building	Fountain Tap Combo	Rm2102	1 of 1	Water Fountain	left	<1
56	418168	2026-03-27	Main Building	Fountain Tap Combo	Rm2103	1 of 1	Tap	right	<1
57	418169	2026-03-27	Main Building	Fountain Tap Combo	Rm2103	1 of 1	Water Fountain	left	<1
58	418170	2026-03-27	Main Building	Fountain Tap Combo	Rm2104	1 of 1	Tap	right	<1
59	418171	2026-03-27	Main Building	Fountain Tap Combo	Rm2104	1 of 1	Water Fountain	left	<1
60	418172	2026-03-27	Main Building	Fountain Tap Combo	Rm2105	1 of 1	Tap	right	<1
61	418173	2026-03-27	Main Building	Fountain Tap Combo	Rm2105	1 of 1	Water Fountain	left	<1
62	418174	2026-03-27	Main Building	Fountain Tap Combo	Rm2106	1 of 1	Tap	right	<1

	Sample ID	Sample Collected Date	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
63	418175	2026-03-27	Main Building	Fountain Tap Combo	Rm2106	1 of 1	Water Fountain	left	<1
64	418176	2026-03-27	Main Building	Fountain Tap Combo	Rm2108	1 of 1	Tap	right	<1
65	418177	2026-03-27	Main Building	Fountain Tap Combo	Rm2108	1 of 1	Water Fountain	left	<1
66	418178	2026-03-27	Main Building	Fountain Tap Combo	Rm2109	1 of 1	Tap	right	<1
67	418179	2026-03-27	Main Building	Fountain Tap Combo	Rm2109	1 of 1	Water Fountain	left	<1
68	418180	2026-03-27	Main Building	Fountain Tap Combo	Rm2112	1 of 1	Tap	right	<1
69	418181	2026-03-27	Main Building	Fountain Tap Combo	Rm2112	1 of 1	Water Fountain	left	<1
70	418182	2026-03-27	Main Building	Fountain Tap Combo	Rm2113	1 of 1 Fountain off	Tap	right	<1
71	418183	2026-03-27	Main Building	Fountain Tap Combo	Rm2114	1 of 1 fountain off	Tap	right	<1
72	418184	2026-03-27	Main Building	Fountain Tap Combo	Rm2116	1 of 1	Tap	right	<1

---

	Sample ID	Sample Collected Date	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
73	418185	2026-03-27	Main Building	Fountain Tap Combo	Rm2116	1 of 1	Water Fountain	left	<1
74	418186	2026-03-27	Main Building	Fountain Tap Combo	Rm2117	1 of 1 fountain off	Tap	right	<1
75	418187	2026-03-27	Main Building	Fountain Tap Combo	Rm2118	1 of 1 fountain off	Tap	right	<1
76	418188	2026-03-27	Main Building	Sink	Rm2119	1 of 1	Tap	center	<1

---