

Lead in School Drinking Water Report

Fairmount Park Elementary School



EXPLANATION OF TESTING AND RESULTS

Results in this report represent sampling conducted by Washington State Department of Health (DOH). Per [RCW 28A.210.410](#) sampling and testing protocols, samples were collected as first-draw. Depending on size of the school(s) and number of drinking water fixtures, multiple dates for collecting samples may have been necessary to meet sampling and testing protocols.

[RCW 28A.210.410](#) does not require remediation for fixtures testing at 5 ppb and under. DOH offers post-remediation testing only for outlets that initially tested above 5 ppb. After a school completes remediation, DOH will provide up to two post-remediation sampling visits. If after the second post-remediation sampling, outlets test above 5 ppb, the district will be responsible for finding a contractor to conduct additional sampling and testing. For questions regarding sampling, testing, and results, please email: leadfreekids@doh.wa.gov.

DEFINITIONS

Fixture Housing
Location

Room/space where
fixture is located
(i.e. room number,
gym, playground)

Fixture Housing Type

Structure that contains
the individual fixtures
where water samples
were collected from.
Fixture housing may
contain one or more
individual fixture for
sampling.

Fixture Location
Details

Location within a
room or space where
fixture housing is
located, starting to the
left of the entrance and
rotating clockwise, of
the total number of
fixture housings in a
room or space
(e.g. 1/5, 2/5)

Fixture Type

Tap, Sprayer, Water
Fountain, Water Bottle
Filler, Ice maker

Fixture Position

Left, Center, Right

Date(s) collected: 2025-11-07

Date(s) analyzed: 2025-11-18, 2025-11-21

.	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
1	415292	2014 Building	Sink	Daycare Kitchen	2 of 2	Tap	right	3
2	415485	2014 Building	Fountain/Tap Combo	Work Room 204c	1 of 1	Water Fountain	right	2
3	415503	2014 Building	Fountain/Tap Combo	Room 221	1 of 1	Water Fountain	right	2
4	415505	2014 Building	Fountain/Tap Combo	Room 222	1 of 1	Water Fountain	right	2
5	415511	2014 Building	Fountain/Tap Combo	Room 300	1 of 1	Tap	center	2
6	415512	2014 Building	Fountain/Tap Combo	Room 300	1 of 1	Water Fountain	right	2
7	415518	2014 Building	Fountain/Tap Combo	Room 303	1 of 1	Water Fountain	right	2
8	415288	2014 Building	Fountain/Tap Combo	Work Room	1 of 1	Tap	center	<1
9	415289	2014 Building	Sink - Multi-Compartment	Staff Lounge	1 of 1	Tap	center	<1
10	415290	2014 Building	Sink	Nurses Office	1 of 1	Tap	center	<1
11	415291	2014 Building	Sink	Daycare Kitchen	1 of 2	Tap	left	<1

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
12	415293	2014 Building	Fountain/Tap Combo	Room 104	1 of 1	Tap	center	<1
13	415294	2014 Building	Fountain/Tap Combo	Room 104	1 of 1	Water Fountain	right	<1
14	415295	2014 Building	Fountain/Tap Combo	Room 102	1 of 1	Tap	center	<1
15	415296	2014 Building	Fountain/Tap Combo	Room 102	1 of 1	Water Fountain	right	<1
16	415297	2014 Building	Fountain - Multi-Level	Hallway Next To Room 221	1 of 1	Water Fountain	left	<1
17	415298	2014 Building	Fountain - Multi-Level	Hallway Next To Room 221	1 of 1	Water Fountain	right	<1
18	415299	Main Building	Fountain - Multi-Level	Hallway Next To Room 301	1 of 1	Water Fountain	left	<1
19	415300	Main Building	Fountain - Multi-Level	Hallway Next To Room 301	1 of 1	Water Fountain	right	<1
20	415301	Main Building	Fountain - Multi-Level	Hallway Next To Room 227	1 of 1	Water Fountain	left	<1
21	415302	Main Building	Fountain - Multi-Level	Hallway Next To Room 227	1 of 1	Water Fountain	right	<1
22	415303	Main Building	Fountain - Multi-Level	Hallway Next To Room 210	1 of 1	Water Fountain	left	<1

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
23	415304	Main Building	Fountain - Multi-Level	Hallway Next To Room 210	1 of 1	Water Fountain	right	<1
24	415305	2014 Building	Fountain - Multi-Level with Bottle Filler	Commons	1 of 1	Water Fountain	left	<1
25	415306	2014 Building	Fountain - Multi-Level with Bottle Filler	Commons	1 of 1	Water Bottle Filler	center	<1
26	415307	2014 Building	Fountain - Multi-Level with Bottle Filler	Commons	1 of 1	Water Fountain	right	<1
27	415308	2014 Building	Sink - Multi-Compartment	Kitchen	1 of 1	Tap	center	<1
28	415309	Main Building	Fountain - Multi-Level	Courtyard	1 of 1	Water Fountain	left	<1
29	415310	Main Building	Fountain - Multi-Level	Courtyard	1 of 1	Water Fountain	right	<1
30	415311	Main Building	Sink	Art Room 04	1 of 2	Tap	left	<1
31	415312	Main Building	Sink	Art Room 04	2 of 2	Tap	right	<1
32	415313	Main Building	Fountain - Multi-Level with Bottle Filler	Gym	1 of 1	Water Fountain	left	<1

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
33	415314	Main Building	Fountain - Multi-Level with Bottle Filler	Gym	1 of 1	Water Bottle Filler	center	<1
34	415315	Main Building	Fountain - Multi-Level with Bottle Filler	Gym	1 of 1	Water Fountain	right	<1
35	415316	Main Building	Fountain/Tap Combo	Room 129	1 of 1	Tap	left	<1
36	415317	Main Building	Fountain/Tap Combo	Room 129	1 of 1	Water Fountain	right	<1
37	415318	2014 Building	Fountain/Tap Combo	Room 201	1 of 1	Tap	center	<1
38	415319	2014 Building	Fountain/Tap Combo	Room 201	1 of 1	Water Fountain	right	<1
39	415480	2014 Building	Fountain/Tap Combo	Room 203	1 of 1	Tap	center	<1
40	415481	2014 Building	Fountain/Tap Combo	Room 203	1 of 1	Water Fountain	right	<1
41	415482	2014 Building	Fountain/Tap Combo	Library	1 of 1	Tap	center	<1
42	415483	2014 Building	Fountain/Tap Combo	Library	1 of 1	Water Fountain	right	<1

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
43	415484	2014 Building	Fountain/Tap Combo	Work Room 204c	1 of 1	Tap	center	<1
44	415486	2014 Building	Fountain/Tap Combo	Room 206	1 of 1	Tap	center	<1
45	415487	2014 Building	Fountain/Tap Combo	Room 206	1 of 1	Water Fountain	right	<1
46	415488	2014 Building	Fountain/Tap Combo	Room 208	1 of 1	Tap	center	<1
47	415489	2014 Building	Fountain/Tap Combo	Room 208	1 of 1	Water Fountain	right	<1
48	415490	2014 Building	Fountain/Tap Combo	Room 210	1 of 1	Tap	center	<1
49	415491	2014 Building	Fountain/Tap Combo	Room 210	1 of 1	Water Fountain	right	<1
50	415492	2014 Building	Fountain/Tap Combo	Room 216	1 of 1	Tap	center	<1
51	415493	2014 Building	Fountain/Tap Combo	Room 216	1 of 1	Water Fountain	right	<1
52	415494	2014 Building	Fountain/Tap Combo	Room 217	1 of 1	Tap	center	<1
53	415495	2014 Building	Fountain/Tap Combo	Room 217	1 of 1	Water Fountain	right	<1

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
54	415496	2014 Building	Fountain/Tap Combo	Room 218	1 of 1	Tap	center	<1
55	415497	2014 Building	Fountain/Tap Combo	Room 218	1 of 1	Water Fountain	right	<1
56	415498	2014 Building	Fountain/Tap Combo	Room 219	1 of 1	Tap	center	<1
57	415499	2014 Building	Fountain/Tap Combo	Room 219	1 of 1	Water Fountain	right	<1
58	415500	2014 Building	Fountain/Tap Combo	Room 220	1 of 1	Tap	center	<1
59	415501	2014 Building	Fountain/Tap Combo	Room 220	1 of 1	Water Fountain	right	<1
60	415502	2014 Building	Fountain/Tap Combo	Room 221	1 of 1	Tap	center	<1
61	415504	2014 Building	Fountain/Tap Combo	Room 222	1 of 1	Tap	center	<1
62	415506	2014 Building	Fountain/Tap Combo	Room 224	1 of 1	Tap	center	<1
63	415507	2014 Building	Fountain/Tap Combo	Room 226	1 of 1	Tap	center	<1
64	415508	2014 Building	Fountain/Tap Combo	Room 226	1 of 1	Water Fountain	right	<1

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
65	415509	2014 Building	Fountain/Tap Combo	Room 227	1 of 1	Tap	center	<1
66	415510	2014 Building	Fountain/Tap Combo	Room 227	1 of 1	Water Fountain	right	<1
67	415513	2014 Building	Fountain/Tap Combo	Room 301	1 of 1	Tap	center	<1
68	415514	2014 Building	Fountain/Tap Combo	Room 301	1 of 1	Water Fountain	right	<1
69	415515	2014 Building	Fountain/Tap Combo	Room 302	1 of 1	Tap	center	<1
70	415516	2014 Building	Fountain/Tap Combo	Room 302	1 of 1	Water Fountain	right	<1
71	415517	2014 Building	Fountain/Tap Combo	Room 303	1 of 1	Tap	center	<1
72	415519	2014 Building	Fountain/Tap Combo	Room 304	1 of 1	Tap	center	<1
73	415520	2014 Building	Fountain/Tap Combo	Room 304	1 of 1	Water Fountain	right	<1
74	415521	2014 Building	Fountain/Tap Combo	Room 305	1 of 1	Tap	center	<1
75	415522	2014 Building	Fountain/Tap Combo	Room 305	1 of 1	Water Fountain	right	<1